

Application No.: 18-09-002
Exhibit No.: SCE-01A
Witnesses: B. Chiu
D. Daigler
P. Herrington
M. Jocelyn
L. Letizia
D. Tessler
T. Tran



(U 338-E)

Prepared Testimony in Support of Southern California Edison Company's Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Before the

Public Utilities Commission of the State of California

Rosemead, California
September 10, 2018

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents

| Section | Page | Witness |
|--|------|---------------|
| I. INTRODUCTION AND EXECUTIVE SUMMARY..... | 1 | P. Herrington |
| A. SCE Proposes Further Grid Hardening and Other Enhanced Measures to Address California’s “New Normal” of Year-Round, Potentially Catastrophic Wildfire Risk | 3 | |
| B. SCE Seeks Appropriate Ratemaking Mechanisms That Will Facilitate Incremental GS&RP Activities During This Proceeding and Allow Forecast Program Costs to be Included in Rates Upon a Final Decision | 7 | L. Letizia |
| II. SCE IS COMMITTED TO SAFELY OPERATING ITS ELECTRIC SYSTEM UNDER THE “NEW NORMAL” OF INCREASING WILDFIRE RISK IN CALIFORNIA..... | 9 | P. Herrington |
| A. California’s Wildfire Risk Landscape Has Changed Dramatically..... | 9 | |
| B. SCE’s Existing Efforts to Mitigate Wildfire Risk in Its Service Area..... | 14 | |
| 1. Existing Planning Activities | 16 | |
| 2. Existing Engineering and System Design Activities | 17 | |
| 3. Existing Grid Improvement Activities..... | 17 | |
| 4. Existing Vegetation Management and Other Inspection and Maintenance Program Activities | 17 | |
| 5. Existing Standard Operating Practices, Emergency Planning and Response, and Stakeholder Outreach Activities..... | 18 | |
| C. SCE’s GS&RP: Further Hardening the Electric System and Enhancing Utility Situational Awareness and Operational Capabilities | 20 | |
| 1. Creation of Program Management Office Focused on Addressing Increasing Wildfire Risk..... | 20 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | | Page | Witness |
|----------------|--|-------------|----------------|
| 2. | Overview of Key GS&RP Wildfire Mitigation Activities..... | 21 | |
| a) | Enhanced Grid Hardening..... | 21 | |
| b) | Enhanced Situational Awareness..... | 23 | |
| c) | Enhanced Operational Practices..... | 24 | |
| 3. | GS&RP Deployment Strategy and Prioritization Considerations..... | 24 | |
| 4. | GS&RP 2018-2020 Incremental Costs..... | 25 | |
| III. | THE GS&RP WAS DEVELOPED USING A RISK-INFORMED DECISION-MAKING PROCESS..... | 28 | B. Chiu |
| A. | Overview of SCE’s Risk-Informed Decision-Making Process..... | 28 | |
| 1. | Steps 1 and 2: Risk Identification and Evaluation..... | 29 | |
| 2. | Step 3: Risk Mitigation Identification..... | 33 | |
| 3. | Step 4: Risk Mitigation Evaluation..... | 35 | |
| 4. | Step 5: Decision-Making and Planning..... | 36 | |
| 5. | Step 6: Monitoring and Reporting..... | 36 | |
| B. | The GS&RP Aligns With, and Will Inform, SCE’s Upcoming RAMP Filing..... | 37 | |
| IV. | GS&RP PROJECTS..... | 38 | |
| A. | Portfolio Overview..... | 38 | |
| B. | Grid Hardening Projects..... | 40 | |
| 1. | Wildfire Covered Conductor Program..... | 40 | T. Tran |
| a) | Program Overview..... | 40 | |
| b) | What Exists Today..... | 42 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | Page | Witness |
|--|------|---------|
| (1) SCE’s Historical Use of Bare Conductor Wire..... | 42 | |
| (2) SCE’s Use of Covered Conductor and Industry Advances in Covered Conductor Design | 43 | |
| (3) The New WCCP and the Existing Overhead Conductor Program | 46 | |
| c) Effectiveness..... | 47 | |
| (1) Risk Analysis: Fault-to-Fire Mapping | 48 | |
| (2) Risk Analysis: Mitigation-to-Fault Mapping | 51 | |
| (3) Mitigation Effectiveness Factors and Mitigation-Cost Ratios..... | 52 | |
| (4) Risk Analysis Conclusions | 53 | |
| d) Forecast..... | 54 | |
| e) Detailed Program Description..... | 55 | |
| (1) Program Scope | 59 | |
| (2) Program Components..... | 62 | |
| (a) Poles..... | 63 | |
| (b) Tree Attachments | 66 | |
| f) Deployment Time | 69 | |
| g) Benefits | 70 | |
| 2. Remote-Controlled Automatic Reclosers (RARs) And Fast Curve Settings | 70 | |
| a) Program Overview | 70 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | Page | Witness |
|--|------|------------|
| b) What Exists Today | 71 | |
| c) Effectiveness | 72 | |
| d) Forecast | 73 | |
| e) Detailed Program Description | 74 | |
| (1) RAR Configurations and Installations | 74 | |
| (2) Fault Interruption | 75 | |
| (3) Fast Curve Operating Settings | 77 | |
| (4) Public Safety Power Shutoff | 78 | |
| (5) Recloser Relay Blocking | 79 | |
| f) Alternatives | 80 | |
| (1) Use Remote Controlled Switches (RCS) instead of RARs | 80 | |
| (2) Install RARs widely across HFRA circuits maximizing reliability and fault energy reduction | 80 | |
| 3. Fusing Mitigation | 81 | |
| a) Program Overview | 81 | |
| b) What Exists Today | 82 | |
| c) Effectiveness | 83 | |
| d) Forecast | 84 | |
| e) Detailed Program Description | 84 | |
| f) Alternatives | 87 | |
| C. Enhanced Situational Awareness | 88 | D. Daigler |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | | Page | Witness |
|----------------|---|-------------|----------------|
| 1. | HD Cameras..... | 90 | |
| | a) Program Overview | 90 | |
| | b) What Exists Today | 91 | |
| | c) Effectiveness | 91 | |
| | d) Forecast | 92 | |
| | e) Detailed Program Description..... | 92 | |
| | f) Alternatives Considered..... | 93 | |
| 2. | Weather Stations | 94 | |
| | a) Program Overview | 94 | |
| | b) What Exists Today | 94 | |
| | c) Effectiveness | 95 | |
| | d) Forecast | 95 | |
| | e) Detailed Program Description..... | 96 | |
| | f) Alternatives Considered..... | 97 | |
| 3. | Advanced Weather Modeling Tool (IBM Forecast on Demand System)..... | 98 | |
| | a) Program Overview | 98 | |
| | b) What Exists Today | 98 | |
| | c) Effectiveness | 98 | |
| | d) Forecast..... | 99 | |
| | e) Detailed Program Description..... | 99 | |
| | f) Alternatives Considered..... | 100 | |
| 4. | Advanced Modeling Computer Hardware | 100 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | | Page | Witness |
|----------------|---|-------------|----------------|
| a) | Program Overview | 100 | |
| b) | What Exists Today | 101 | |
| c) | Effectiveness | 101 | |
| d) | Forecast | 101 | |
| e) | Detailed Program Description..... | 102 | |
| f) | Alternatives Considered..... | 104 | |
| 5. | Asset Reliability and Risk Analytics | 104 | B. Chiu |
| a) | Program Overview | 104 | |
| b) | What Exists Today | 105 | |
| c) | Effectiveness | 105 | |
| d) | Forecast | 107 | |
| e) | Detailed Program Description..... | 107 | |
| | (1) Asset Risk Modelling..... | 107 | |
| | (2) Operational Analytics | 108 | |
| f) | Alternatives Considered..... | 109 | |
| 6. | Additional Required Staffing..... | 110 | D. Daigler |
| a) | Forecast..... | 111 | |
| D. | Enhanced Operational Practices | 111 | |
| 1. | Vegetation Management | 111 | M. Jocelyn |
| a) | Overview of Expanded Vegetation Management Activities | 111 | |
| b) | What Exists Today: SCE’s Vegetation Management-Related Activities and Associated Rate Recovery Mechanisms | 113 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| | Section | Page | Witness |
|----|--|-------------|----------------|
| | (1) 2018 GRC | 114 | |
| | (2) Drought CEMA..... | 116 | |
| | (3) Fire Hazard Prevention Memorandum Account | 116 | |
| c) | Forecast..... | 117 | |
| d) | Detailed Program Description: Expanded Vegetation Management Activity | 118 | |
| | (1) Dedicated Tree Inspection Process | 119 | |
| | (2) Tree-specific Threat Assessment and Inventory..... | 120 | |
| | (3) Enhanced Efforts to Obtain Property Owner Approval..... | 122 | |
| | (4) Risk-Based Tree Mitigation..... | 123 | |
| | (5) Program Management, Environmental Compliance and Quality Assurance..... | 124 | |
| e) | Deployment Schedule..... | 125 | |
| 2. | Infrared Inspection Program | 125 | B. Chiu |
| | a) Program Overview | 125 | |
| | b) What Exists Today..... | 126 | |
| | c) Effectiveness..... | 126 | |
| | d) Forecast..... | 127 | |
| | e) Detailed Program Description..... | 128 | |
| | f) Alternatives Considered..... | 128 | |
| 3. | PSPS Protocol Support Functions: Customer Communications and Line Patrols | 129 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | Page | Witness |
|---|------|------------|
| a) Overview..... | 129 | |
| b) What Exists Today..... | 129 | |
| c) Effectiveness..... | 129 | |
| (1) Customer Outreach Activities..... | 129 | |
| (2) Line Patrols..... | 130 | |
| d) Forecast..... | 131 | |
| e) Detailed Program Description..... | 131 | |
| (1) Customer Outreach Activities..... | 131 | |
| (2) Line Patrols..... | 133 | |
| 4. Mobile Generator Deployment..... | 133 | D. Daigler |
| a) Program Overview..... | 133 | |
| b) What Exists Today..... | 133 | |
| c) Effectiveness..... | 134 | |
| d) Forecast..... | 134 | |
| e) Detailed Program Description..... | 134 | |
| f) Alternatives Considered..... | 135 | |
| 5. Portable Community Power Trailers..... | 136 | |
| a) Program Overview..... | 136 | |
| b) What Exists Today..... | 136 | |
| c) Effectiveness..... | 137 | |
| d) Forecast..... | 137 | |
| e) Detailed Program Description..... | 137 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | | Page | Witness |
|----------------|---|-------------|----------------|
| | f) Alternatives Considered..... | 139 | |
| E. | Wildfire Mitigation Program Study Costs | 140 | T. Tran |
| | 1. Distribution Fault Anticipation Technology Program Study | 140 | |
| | 2. Advanced Unmanned Aerial Systems Study | 141 | |
| | 3. High Resolution Weather Forecast Study..... | 143 | |
| V. | COST RECOVERY | 145 | L. Letizia |
| A. | Summary of SCE’s Ratemaking Proposal | 145 | |
| B. | Overview of SCE’s Currently Authorized or Pending Ratemaking Mechanisms Associated with Wildfire Risk Reduction Cost Recovery | 146 | |
| | 1. Z-Factor..... | 146 | |
| | 2. Wildfire Expense Memorandum Account (WEMA)..... | 147 | |
| | 3. Catastrophic Event Memorandum Account (CEMA) – 2015 – 2016 Drought and 2016 Fires | 147 | |
| | 4. Fire Hazard Prevention Memorandum Account (FHPMA)..... | 149 | |
| | 5. Wildfires Customer Protections Memorandum Account (WCPMA) | 150 | |
| | 6. 2018 GRC | 151 | |
| C. | Description of Grid Resiliency Program Memorandum Account..... | 151 | |
| D. | Description of Grid Resiliency Program Balancing Account..... | 152 | |
| E. | Proposed Reasonableness Review of GS&RP Expenditures Forecast..... | 152 | |
| | 1. Proposed Reasonableness Threshold | 152 | |

SCE-01A: Prepared Testimony in Support of Southern California Edison Company’s Application for Approval of Its Grid Safety and Resiliency Program - Annotated

Table of Contents (Continued)

| Section | Page | Witness |
|---|-------------|----------------|
| 2. Proposed Review Process | 153 | B. Chiu |
| F. Rate Recovery of Recorded GS&RP Revenue Requirements | 153 | L. Letizia |
| G. Forecast GS&RP Revenue Requirements..... | 154 | D. Tessler |
| 1. Capital Expenditures and Additions | 154 | |
| a) Capital Additions and Plant-In-Service | 155 | |
| b) Depreciation Expense and Accumulated Depreciation | 156 | |
| 2. Rate of Return | 156 | |
| 3. O&M Expenses..... | 156 | |
| 4. Income Taxes | 157 | |

Appendix A Acronym List

Appendix B Witness Qualifications

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21

I.

INTRODUCTION AND EXECUTIVE SUMMARY

This testimony supports Southern California Edison Company’s (SCE) request for authorization to record and recover the reasonable costs of the Grid Safety and Resiliency Program (GS&RP) incurred in 2018 and forecasted through 2020 that were not forecasted in the 2018 General Rate Case Application (A.) 16-09-001 (2018 GRC). The GS&RP is designed to implement measures addressing emerging state policy directed at reducing wildfire risk, the increasing magnitude of which was brought to light in a series of devastating fires in the latter half of 2017. These unprecedented events have continued into 2018, and well before the typical “fire season”—ushering in a “new normal” of year-round exposure to potentially catastrophic wildfires. This increasing risk must be addressed: wildfires not only threaten the state’s residents and its economy, they also undermine its ambitious environmental policies for reducing greenhouse gas emissions.

Addressing wildfire risk requires enhanced approaches to the design, construction, operation, and maintenance of electric systems. Although wildfires happen for several reasons,¹ SCE fully agrees with Governor Brown that utilities have an important role in the statewide wildfire risk effort, and that even greater investments in wildfire-related safety enhancements to electric systems are needed.² President Picker also has noted that, for electric utilities, “the legislature has made it very clear that they expect us to do everything we can to prevent fires from [power lines owned by] regulated entities.”³ This direction is reflected in the recently approved Senate Bill (SB) 901, which provides that electric utilities must “construct, maintain,

¹ Among these, electric utilities historically contribute to the causes of up to ten percent of all wildfires in California.

² See Letter from Gov. Brown to Sen. Dodd and Assemb. Holden (July 24, 2018).

³ Audio: Statement of President Picker, California Public Utilities Commission Voting Meeting #3421, 28:34 – 28:46 (Aug. 9, 2018), available at http://www.adminmonitor.com/ca/cpuc/voting_meeting/20180809/.

1 and operate [their] electrical lines and equipment in a manner that will minimize the risk of
2 catastrophic wildfire posed by those electrical lines and equipment.”⁴

3 To that end, SCE’s GS&RP contemplates broader, more advanced measures than those
4 described in its 2018 GRC, which was filed before the devastating 2017 wildfires. The GS&RP
5 is a comprehensive program, incorporating leading practices and mitigation measures selected
6 based on their effectiveness and with appropriate consideration of resource allocation and
7 alternatives. These measures will help enhance the safety of the electrical system and make it
8 more resilient during wildfires, consistent with state policy. They will also benefit other key
9 stakeholders by, for example, improving fire agencies’ ability to detect and respond to emerging
10 fires in coordination with utility emergency management personnel.

11 These additional measures involve costs above amounts currently authorized in rates, or
12 requested in the 2018 GRC. SCE is therefore requesting through this Application that the
13 California Public Utilities Commission (Commission or CPUC) review the GS&RP and
14 authorize 2018-2020 program costs that are incremental to those requested in the 2018 GRC.
15 SCE also requests Commission approval of the following ratemaking mechanisms⁵ for
16 incremental program costs recorded prior to 2021, when its next GRC will take effect:

- 17 **1) An interim GS&RP Memorandum Account (GS&RPMA)**, to be effective as of
18 this Application’s filing date (September 10, 2018), to permit SCE to record
19 incremental program costs during this proceeding; and
- 20 **2) A two-way GS&RP Balancing Account (GS&RPBA)**, effective upon a final
21 Commission decision, to recover incremental costs associated with implementing this
22 program.

⁴ Senate Bill 901, 2017-2018 Reg. Sess. (Cal. 2018), *available at*
https://leginfo.legislature.ca.gov/faces/billTextClient.xhtml?bill_id=201720180SB901. To date, the
bill is awaiting the Governor’s signature.

⁵ Chapter V provides an overview of the Commission’s existing ratemaking mechanisms for recovering
costs related to wildfires and other significant system-wide events (e.g., the Catastrophic Event
Memorandum Account for system restoration costs and costs related to the drought, and the “Z-
Factor” mechanism for unforeseen, exogenous events outside the GRC).

1 The GS&RP costs that SCE expects to incur beyond 2020 will be addressed in SCE’s
2 upcoming 2021 and 2024 GRCs, which will be filed in September, 2019 and 2022, respectively.

3 **A. SCE Proposes Further Grid Hardening and Other Enhanced Measures to Address**
4 **California’s “New Normal” of Year-Round, Potentially Catastrophic Wildfire Risk**

5 California’s wildfire risk has increased in recent years due to climate change and other
6 factors like the growing wildland-urban interface and significant build-up of fuel, including on
7 federal and state forest lands.⁶ The magnitude of the increased threat and the significance of its
8 consequences did not become apparent until 2017, when California experienced five of the 20
9 most destructive fires in its history.⁷ 2017 was the costliest and deadliest year of wildfires on
10 record, which Governor Brown and other officials agree marked the beginning of an
11 unprecedented “new normal” of a year-round wildfire season.⁸ So far, this year is not disproving
12 that conclusion. In August alone, there were 15 large wildfires burning across the state; two of
13 which are among the top ten largest wildfires in California history.⁹ As of August 29, 2018,
14 these devastating fires have burned over 1,121,916 acres,¹⁰ damaged or destroyed more than

⁶ See e.g., Gov. Brown’s Executive Order B-52-18, issued on May 10, 2018, ordering several projects to improve forest conditions and increase fire protection. The order notes the pace and scale of prescribed fire, fuel reduction, and thinning of overly dense forests “are far below levels needed to restore and maintain forest health.”

⁷ CalFire, Fact Sheet *Top 20 Most Destructive California Wildfires* (August 20, 2018), available at http://www.fire.ca.gov/communications/downloads/fact_sheets/Top20_Destruction.pdf.

⁸ Ruben Vives et al., *Southern California’s Fire Devastation is the ‘New Normal’ Gov. Brown Says*, N.Y. TIMES (Dec. 2017), available at <http://www.latimes.com/local/lanow/la-me-socal-fires-20171210-story.html>; see also CA. Exec. Order No. B-52-18 (May, 2018), available at <https://www.gov.ca.gov/wp-content/uploads/2018/05/5.10.18-Forest-EO.pdf>.

⁹ The July 2018 Mendocino Complex Fire has been classified as the largest fire in state history, while the July 2018 Carr Fire has been classified as the seventh largest. CalFire, Fact Sheet *The Top 20 Largest California Wildfires* (August 29, 2018), available at http://www.fire.ca.gov/communications/downloads/fact_sheets/Top20_Acres.pdf. (Note that this website is updated daily, and the numbers may have increased since August 29, 2018)

¹⁰ National Interagency Fire Center (NIFC), *National Year-to-Date Report on Fires and Acres Burned by State and Agency* (August 29, 2018), available at <https://gacc.nifc.gov/sacc/predictive/intelligence/NationalYTDbyStateandAgency.pdf>. (Note that this website is updated daily, and the numbers may have increased since August 29, 2018)

1 2,500 structures,¹¹ and resulted in six fatalities.¹²

2 The 2017 and 2018 fires emphasize that California's wildfire risk has increased to the
3 point where the safety of our communities necessitates additional measures designed to address a
4 higher level of wildfire risk not contemplated by existing state standards or traditional utility fire
5 mitigation practices. Wildfire mitigation measures have been part of SCE's operational practices
6 for years, as high fire risk areas (HFRA) account for about 35 percent of SCE's service area.¹³
7 However, SCE shares the state's conclusion that the unprecedented changes in this risk area
8 require making further investments in utility infrastructure and enhancing operational practices.
9 Accordingly, SCE has comprehensively reviewed its fire mitigation strategies and developed
10 enhanced measures for areas where there is very high wildfire risk.

11 SCE intends to significantly expand its wildfire mitigation programs. SCE's efforts are
12 focused on wildfire prevention (i.e., reducing potential ignitions) and supporting suppression
13 (i.e., more rapid identification and assessment of wildfires), as well as enhancing system
14 resiliency. Among other things, SCE is:

- 15 • Deploying insulated, or "covered," conductor in key portions of the HFRA where it
16 was not previously needed to significantly reduce ignition sources caused by foreign
17 objects such as palm fronds, debris, metallic balloons, etc., contacting overhead lines,

¹¹ NIFC, *National Large Incident Year-to-Date Report* (August 29, 2018), available at <https://gacc.nifc.gov/sacc/predictive/intelligence/NationalLargeIncidentYTDReport.pdf>. (Note that this website is updated daily, and the numbers may have increased since August 29, 2018)

¹² Sarah Ravani and Lauren Hernandez, *California Wildfires: Firefighter's death the 6th of 2018; Yosemite Reopens*, S.F. CHRONICLE (August 14, 2018), available at <https://www.sfchronicle.com/california-wildfires/article/Mendocino-Complex-fires-claim-first-life-5-000-13154845.php#photo-15986939>.

¹³ SCE had previously identified locations in its service area as high fire risk prior to the release of the most recent CPUC High Fire Threat District maps with Tier 2 and Tier 3 designation (see Decision 17-12-024). To date, combining with the CPUC Tier 2 and Tier 3 designations (plus a small buffer), SCE's existing high fire risk areas plus the Tier 2 and Tier 3 locations make up approximately 35 percent of the total SCE service area.

1 and using fire resistant composite poles when appropriate to further improve system
2 resiliency;¹⁴

- 3 • Further enhancing its situational awareness capabilities to more quickly and fully
4 assess potential wildfire conditions and develop additional response plans; and
- 5 • Bolstering its operational practices to include, among other things, using infrared
6 cameras to inspect electrical equipment and implementing even more aggressive
7 vegetation management activities.

8 Many of the actions being taken will be done in collaboration with, and will benefit, key
9 stakeholders, including fire agencies. These actions will benefit system reliability, primarily in
10 the long term, and help mitigate shorter term reliability impacts associated with wildfire
11 mitigation measures such as de-energizing electric lines during extreme fire conditions.¹⁵

12 SCE developed this set of proposed wildfire mitigation activities based on a risk
13 assessment that considered the cost and risk mitigation effectiveness of each option compared to
14 other alternative measures. Given the need for immediate action, SCE is already implementing
15 some GS&RP activities such as deploying covered conductor on its highest fire risk circuits, and
16 installing additional weather stations and High Definition (HD) cameras in HFRA.¹⁶ However,
17 SCE anticipates it will take eight or more years to complete all program activities, at substantial
18 cost. Table I-1 below provides an overview of SCE's program deployment timeline through
19 2025, highlighting the program activities in this Application's scope.

¹⁴ As explained in Chapter IV, covered conductor is a more prudent mitigation solution compared to other alternatives, such as undergrounding lines.

¹⁵ See Section B.5 for a discussion about SCE's Public Safety Power Shutoff protocol. SCE's grid hardening measures will also help reduce the future deployment of PSPS.

¹⁶ SCE's HD cameras deployed at Santiago Peak help fire agencies respond to wildfires, and were able to capture what are believed to be the first images of the Holy Fire. See Kevin Sablan, *Holy fire time-lapse GIF captures smoke exploding into blaze*, O.C. Register (August 13, 2018), available at <https://www.ocregister.com/2018/08/13/these-holy-fire-gifs-show-how-quickly-the-blaze-grew-and-how-winds-pushed-it-forward/>.

**Table I-1
Grid Safety and Resiliency Program Deployment Timing**

| Key Areas | Current Request | | | 2021 | 2022 | 2023 | 2024 | 2025 |
|-----------------------|--|------|------|------|------|------|------|------|
| | 2018 | 2019 | 2020 | | | | | |
| Grid Hardening | Covered Conductor | | | | | | | |
| | Fuses | | | | | | | |
| | Auto Reclosers | | | | | | | |
| Situational Awareness | HD Cameras | | | | | | | |
| | Weather Stations | | | | | | | |
| | Adv. Modeling Computer Hardware | | | | | | | |
| Operational Practices | Vegetation Management, Infrared Inspection, PSPS, and Generators | | | | | | | |

1 SCE’s Application is focused solely on obtaining Commission approval of GS&RP
2 program activities and associated incremental forecast costs not included in the 2018 GRC.
3 This will allow SCE to recover costs associated with mitigation measures it believes can be
4 deployed in the near future, including deployment of covered conductor on approximately 600
5 circuit miles of the approximately 10,000 total circuit miles in SCE’s HFRA.¹⁷ Table I-2
6 summarizes program activities, forecast incremental costs, and the associated revenue
7 requirement in SCE’s request.¹⁸

¹⁷ SCE expects to continue advancing its understanding of enhanced fire risk mitigation measures, and refining its risk mitigation efforts as part of the GS&RP.

¹⁸ SCE’s estimates are based on the best information available at this time. As with any new program, SCE expects to refine work processes and tools that may impact spending levels. Additionally, factors outside of SCE’s control, such as limited material supplies or large events (e.g., storms) could divert internal resources or limit the availability of contractor resources and impact SCE’s ability to execute the proposed plan. SCE anticipates gaining additional information that will help refine and inform elements of SCE’s GS&RP that will extend into future GRCs.

Table I-2
Forecast of Incremental Costs and Revenue Requirements of GS&RP in the Near Term
(2018-2020)¹⁹

| Grid Safety & Resiliency Program | | | | | |
|---|-------------------------------------|-------------|-------------|-------------|--------------|
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | Capital (2018 Constant \$000) | 54,371 | 112,137 | 240,781 | \$407,290 |
| 2 | O&M (2018 Constant \$000) | 8,095 | 53,235 | 113,712 | \$175,042 |
| 3 | Revenue Requirement (Nominal \$000) | 10,490 | 67,349 | 151,233 | \$229,072 |

B. SCE Seeks Appropriate Ratemaking Mechanisms That Will Facilitate Incremental GS&RP Activities During This Proceeding and Allow Forecast Program Costs to be Included in Rates Upon a Final Decision

Once the Commission has issued a final decision in this proceeding, SCE proposes to include in rates a forecast of the GS&RP revenue requirement in distribution rates beginning in 2019 and to continue to include a forecast in distribution rates in 2020.²⁰ In addition, SCE proposes to establish: (1) the initial GS&RPMA, effective as of this Application’s filing date; and (2) the GS&RPBA, effective upon a final Commission decision. Both accounts will record actual GS&RP incremental Operations & Maintenance (O&M) expenses and capital-related revenue requirements (e.g., depreciation, return on rate base, property taxes, and income taxes) to provide for the recovery of all recorded GS&RP-related revenue requirements. Amounts recorded in the GS&RPMA would be transferred to the GS&RPBA upon a final Commission decision.²¹ GS&RP activities and costs forecasted for 2021 and beyond will be included in future GRC proceedings.

SCE respectfully requests the Commission authorize the GS&RPMA as of the date of this filing, to permit SCE to record incremental expenditures associated with immediate implementation of critical program activities, including deploying covered conductor in circuits

¹⁹ Refer to Work Paper Vol. 2 (Revenue Requirement)

²⁰ Recovery of the GS&RP revenue requirement will be included in SCE’s 2021 GRC revenue requirement request.

²¹ Once the GS&RPBA is established, SCE will cease recording entries in the GS&RPMA, and the balance recorded in the GS&RPMA will transfer to the GS&RPBA.

1 in HFRA. Because the Commission will perform a full reasonableness review of the scope of
2 the GS&RP activities and forecast costs in this proceeding, SCE also requests the Commission
3 establish a “reasonableness threshold” be set at 115% of the total GS&RP capital and O&M
4 forecast of \$582 million (2018 \$) over the 2018 – 2020 time period, or \$670 million (2018 \$).
5 SCE proposes that the total recorded spend up to \$670 million (2018 \$) be deemed reasonable
6 and any amount of total spend recorded in excess of these amounts will be subject to a traditional
7 reasonableness review in a future application.²²

8 To further support a “reasonableness threshold,” SCE proposes that a subsequent
9 reasonableness review of the GS&RP will not be required if the following two conditions are
10 met: (1) SCE’s GS&RP spending is less than or equal to the reasonableness threshold; and (2)
11 SCE manages the cost per circuit mile for the covered conductor program to up to 115% of the
12 estimated amount of \$428k/mile in 2018 supported in Chapter IV, Section B. If the cost for the
13 covered conductor program exceeds 115% of the estimated amount, or \$493k/mile, escalated
14 appropriately, then SCE will file an application to support why the costs to install covered
15 conductor were greater than that threshold. As described further in Chapter V.E, SCE selected
16 the 115% threshold because it is supported by generally accepted cost engineering practices.

²² The Commission would review GS&RP program costs under the threshold in SCE’s annual Energy Resource Recovery Account (ERRA) Review proceedings to ensure account entries are stated correctly and associated with GS&RP activities as defined and approved by the Commission in this proceeding.

II.

SCE IS COMMITTED TO SAFELY OPERATING ITS ELECTRIC SYSTEM UNDER THE “NEW NORMAL” OF INCREASING WILDFIRE RISK IN CALIFORNIA

In this Chapter, SCE summarizes the GS&RP and places it in context. That is, SCE first reviews California’s historical wildfire risk and explains how the state’s approach to managing this risk changed following the devastating 2017 wildfires and amid the continuing catastrophic fires ongoing in 2018.²³ SCE then summarizes its existing efforts to mitigate, either directly or indirectly, wildfire risk in its service area, including coordinating with state agencies and other key stakeholders. Many of SCE’s existing programs were included in SCE’s 2018 GRC, which was filed in 2016 and before the events giving rise to this Application. After providing this contextual information, SCE explains how its GS&RP will further address wildfire risk by hardening the electric grid and enhancing the utility’s situational awareness capabilities and operational practices in order to address the increased threat of wildfire.

A. California’s Wildfire Risk Landscape Has Changed Dramatically

Historically, California has experienced wildfires that are driven by the region’s warm climate, shrub-dominated landscape, rugged terrain, and extensive wildland-urban interface.²⁴ Between autumn and early spring, warm, arid Santa Ana winds increase the likelihood of wildfires and can cause ignited fires to expand rapidly.²⁵ Extreme heat events and reduced precipitation further enable wildfires by reducing fuel moisture and increasing flammability. Similarly, drought stress increases the prevalence of desiccated fuels, and is associated with

²³ Gov. Brown’s Exec. Order No. B-52-18 (May 10, 2018), available at <https://www.gov.ca.gov/wp-content/uploads/2018/05/5.10.18-Forest-EO.pdf>. The Governor described the 2017 wildfires as “the largest, deadliest, most destructive and costliest in state history” and ordered a number of actions to be taken across a variety of sectors to address the state’s fire risk.

²⁴ Yufang Jin et al., *Identification of Two Distinct Fire Regimes in Southern California: Implications for Economic Impact and Future Change*, 10 ENVTL. RES. LETTERS 094005, 1 (September 8, 2015), available at <http://iopscience.iop.org/article/10.1088/1748-9326/10/9/094005>.

²⁵ Tom Rolinski et al., *The Santa Ana Wildfire Threat Index: Methodology and Operational Implementation*, 31 AM. METEOROLOGICAL SOC’Y 1881, 1883. (Dec. 2016), available at <https://journals.ametsoc.org/doi/pdf/10.1175/WAF-D-15-0141.1>.

1 heightened wildfire size and severity. Drought events and bark beetle infestation also increase
2 tree mortality, which augments fuel load and fuel-driven fires.²⁶ SCE has been removing dead,
3 dying, and diseased trees that can fall into its lines, but large amounts of such trees remain
4 beyond its lines that can fuel fires once there is an ignition event.²⁷ On the non-climate side,
5 growth of the wildland-urban interface (i.e., the area where houses and wildland vegetation meet
6 or intermingle) can lead to more wildfire ignitions, heightened risks to public safety, and greater
7 costs associated with fires.²⁸

8 Coinciding with these historical risk factors, wildfire activity has increased in recent
9 decades.²⁹ Since 1979, while the number of fires in California decreased, the acreage burned per
10 year increased. Similarly, the average acres burned per fire has increased over the same time
11 period.³⁰

12 While the size and impact of California's wildfires has grown, recently our state
13 experienced a dramatic increase in year-round, devastating wildfires unlike anything seen
14 previously. This happened in 2017, which was a historic year for wildfires in the state. Southern
15 California experienced "unremitting" Santa Ana winds accompanied by extremely low humidity

²⁶ Scott Stephens et al., *Drought, Tree Mortality, and Wildfire in Forests Adapted to Frequent Fire*, 68 BIOSCIENCE 77, 78 (Feb. 2018), available at https://www.fs.fed.us/psw/publications/fettig/psw_2018_fettig002_stephens.pdf.

²⁷ These costs are recovered through a combination of base rates and CEMA filings.

²⁸ Alexandra D. Syphard et al., *Human Influence on California Fire Regimes*, 17 ECOLOGICAL APPLICATIONS 1388, 1398 (July 1, 2007), available at <https://esajournals.onlinelibrary.wiley.com/doi/pdf/10.1890/06-1128.1>.


²⁹ See National Oceanic and Atmospheric Administration, *Assessing Fire Hazard Risk In Southern California* (2018), available at <https://coast.noaa.gov/digitalcoast/stories/californiafire.html>; see also, John Abatzoglou & A. Park Williams, *Impact of Anthropogenic Climate Change on Wildfire Across Western US Forests*, PNAS, (October 18, 2016), available at <http://www.pnas.org/content/113/42/11770>.

³⁰ Calfire Redbooks, 2016 Wildfire Activity Statistics, available at http://www.fire.ca.gov/downloads/redbooks/2016_Redbook/2016_Redbook_FINAL.PDF.

(as low as one percent) with low single-digit readings even at the beaches. This resulted in “near apocalyptic” fires.³¹

As illustrated in Figure II-1, eight of the state’s 20 most destructive fires have happened in 2015 or more recently. Although there were no major destructive fires in 2016, six of the state’s 20 most destructive fires have occurred within the last year. This includes one of the state’s largest fires, the Thomas Fire, which occurred as late in the year as December 2017—an unprecedented event for a fire of this magnitude.

Figure II-1
Timeline of Most Destructive California Wildfires 2015-2018³²



According to CalFire, California agencies responded to over 7,000 fires in 2017.³³ After the 2017 wildfires, CalFire confirmed that California “now often experiences a year-round fire

³¹ Rong-Gong Lin II, *L.A.’s increasingly hot and dry autumns result in “these near-apocalyptic fires,”* L.A. Times (December 21, 2017), available at <http://www.latimes.com/local/lanow/la-me-ln-weather-thomas-fire-20171221-story.html>.

³² CalFire statistics as of 8/20/2018. Does not include Mendocino Complex fire, which is currently the largest in California’s history (acres burned) but not within the top 20 most destructive (structures destroyed). Structures include homes, outbuildings (barns, garages, sheds, etc.) and commercial properties destroyed.

³³ CalFire, *2016 Wildfire Activity Statistics*, CalFire Redbook 1 (2016), available at http://calfire.ca.gov/downloads/redbooks/2016_Redbook/2016_Redbook_Summary.pdf; CalFire,

1 season, with an increase in both the number and intensity of large, damaging fires over the last
2 decade.”³⁴ California’s traditional notion of a fire “season” is no longer true.³⁵ News agencies
3 have reported that “the weather conditions that fueled Southern California’s December
4 firestorms offer a window into a future that could include more destructive fires.”³⁶ It is also
5 worth noting that in December 2017 the state experienced some of the strongest winds on record
6 (up to 80 mph)³⁷ that present increasing risks for utility lines considering the large volume of
7 vegetation outside utility rights of way that could be blown from long distances into these lines.

8 Unfortunately, 2018 is shaping up to be another devastating year, with low precipitation,
9 returning drought conditions, and record-setting heat occurring as early as July 2018.³⁸ This
10 year, the state has seen the largest fire in its history with respect to acreage burned, the
11 Mendocino Complex Fire.³⁹ As of August 29, 2018, California’s wildfires have burned over

Incident Information Number of Fires and Acres in 2017, available at
http://cdfdata.fire.ca.gov/incidents/incidents_stats?year=2017.

³⁴ News Release, CalFire, Board of Forestry and Fire Protection and CALFIRE *Working to Increase Pace and Scale of Wildfire Prevention Activities* (Dec. 2017), available at http://www.fire.ca.gov/communications/downloads/newsreleases/2017/2017_BOF_CALFIRE_VTPP_EIR_newsrelease.pdf.

³⁵ Marissa Clifford, *In California, It’s Always Fire Season Now*, LA CURBED (June, 2018), available at <https://la.curbed.com/2018/6/5/17428734/wildfires-california-risk-prediction>.

³⁶ Rong-Gong Lin II, *L.A.’s increasingly hot and dry autumns result in “these near-apocalyptic fires,”* L.A. Times (December, 21, 2017), available at <http://www.latimes.com/local/lanow/la-me-ln-weather-thomas-fire-20171221-story.html>.

³⁷ In December 2017, the state for the first time experienced “purple” (i.e., extreme) winds capable of reaching 80 mph. Associated Press, *California wind hits unprecedented high—and so does fire danger* L.A. Times (December, 7, 2017), available at <http://www.latimes.com/local/lanow/la-me-ln-purple-wind-map-20171207-story.html>.

³⁸ National Interagency Fire Center, *Southern and Central California Monthly/Seasonal Outlook* (Aug. 2018), available at <https://gacc.nifc.gov/oscc/predictive/outlooks/myfiles/assessment.pdf>. (Note that this website is updated daily, and the numbers may have increased since August 2018)

³⁹ Eric Levenson, *A look at California’s largest wildfires by the numbers*, CNN (August 7, 2018), available at <https://www.cnn.com/2018/08/07/us/california-fire-numbers/index.html>.

1 1,121,916 acres,⁴⁰ damaged or destroyed more than 2,500 structures,⁴¹ and resulted in six
2 fatalities.⁴²

3 Experts had predicted that decades from now climate change would increase the risk of
4 these uncharacteristically large and severe wildfires, including a potential increase in the total
5 area burned.⁴³ However, it appears that these projected impacts are happening now, and
6 regrettably much farther ahead of some forecasts. Shortly after the Mendocino Complex Fire,
7 Governor Brown explained that “[t]he more serious predictions of warming and fires to occur
8 later in the century, 2040 or 2050, they’re now occurring in real time.”⁴⁴ California’s recently
9 released Fourth Climate Change Assessment—while acknowledging that projecting future
10 wildfires is complicated—nonetheless notes the potential for greater fire risk in the future and
11 particularly “mass fires” burning large areas simultaneously.⁴⁵

12 This sudden increase in the size and destruction of wildland urban interface fires, along
13 with the extremity of contributing weather conditions, marks a significant change in the state’s
14 firefighting posture, and an increased need for comprehensive, year-round mitigation and

⁴⁰ National Interagency Fire Center (“NIFC”), *National Year-to-Date Report on Fires and Acres Burned by State and Agency* (August 29, 2018), available at <https://gacc.nifc.gov/sacc/predictive/intelligence/NationalYTDbyStateandAgency.pdf> (Note that this website is updated daily, and the numbers may have increased since August 29, 2018)

⁴¹ NIFC, *National Large Incident Year-to-Date Report* (August 29, 2018), available at <https://gacc.nifc.gov/sacc/predictive/intelligence/NationalLargeIncidentYTDReport.pdf> (Note that this website is updated daily, and the numbers may have increased since August 29, 2018)

⁴² Sarah Ravani and Lauren Hernandez, *California Wildfires: Firefighter’s death the 6th of 2018; Yosemite Reopens*, S.F. CHRONICLE (August 14, 2018), available at <https://www.sfchronicle.com/california-wildfires/article/Mendocino-Complex-fires-claim-first-life-5-000-13154845.php#photo-15986939>

⁴³ Tania Schoennagel et al., *Adapt to More Wildfire in Western North American Forests as Climate Changes*, (May, 2017), available at <http://www.pnas.org/content/pnas/114/18/4582.full.pdf>.

⁴⁴ Jaelyn Cosgrove et al., *California fires rage, and Gov. Jerry Brown offers grim view of fiery future*, L.A. Times (Aug. 2018), available at <http://www.latimes.com/local/lanow/la-me-ln-california-fires-20180801-story.html>.

⁴⁵ Bedsworth, Louise, Dan Cayan, Guido Franco, Leah Fisher, Sonya Ziaja. (2018). Statewide Summary Report. *California’s Fourth Climate Change Assessment*. Publication number: SUMCCCA4-2018-013, available at <http://www.climateassessment.ca.gov/state/docs/20180827-StatewideSummary.pdf>.

1 preparedness efforts. Our state’s recent fires are proving that historical mitigation and
2 preparedness efforts are not enough for the current hazards and risks associated with wildfires in
3 California—it is therefore essential for all stakeholders to change the way we approach fire
4 mitigation efforts. SCE agrees with the Governor’s recent proclamation that in order to address
5 this threat “[w]e’re going to have to adapt. We’re going to have to change our technology.”⁴⁶


6 **SCE’s Existing Efforts to Mitigate Wildfire Risk in Its Service Area**

7 Fire mitigation has been an integral part of SCE’s operational practices for years, and it
8 has several programs in place that either directly manage this risk or help contribute toward
9 reducing it. Several of these programs were implemented, or substantially enhanced, following
10 the 2007 wildfires in SCE’s service area. For operations, SCE uses a map that is informed by
11 and recently updated to incorporate the Commission’s new fire threat maps to identify HFRA.⁴⁷
12 As shown below in Figure II-2 and Table II-3, approximately 35 percent of SCE’s service area is
13 considered by the utility to be high fire risk. This includes the areas identified as Tier 2 and Tier
14 3 on the Commission’s fire threat map adopted January 2018, plus areas that SCE previously
15 designated as high fire risk areas (referred to in the table below as “SCE HFRA not in CPUC
16 Tiers”).

⁴⁶ Jaclyn Cosgrove et al., *California fires rage, and Gov. Jerry Brown offers grim view of fiery future*, L.A. Times (Aug. 2018), available at <http://www.latimes.com/local/lanow/la-me-ln-california-fires-20180801-story.html>.

⁴⁷ Since the October 2007 wildfires in Southern California, the Commission, in collaboration with utilities and other agencies, has continued to update fire threat maps to identify HFRA throughout the state.

Figure II-2
SCE High Fire Risk Areas








- | | |
|---|--|
|  CPUC Tier 3 – Extreme Risk |  SCE Service Area |
|  CPUC Tier 2 – Elevated Risk |  California Counties |
|  SCE HFRA Not in CPUC Tiers | |

Table II-3
Breakdown of Areas Comprising SCE’s High Fire Risk Areas

| | Area (Sq. Miles) | Percent of Service Area |
|-----------------------------|------------------|-------------------------|
| CPUC Tier 3 – Extreme Risk | 4,708 | 9 percent |
| CPUC Tier 2 – Elevated Risk | 9,573 | 18 percent |
| SCE HFRA Not in CPUC Tiers | 4,212 | 8 percent |
| TOTAL | 18,493 | 35 percent |

SCE’s longstanding wildfire mitigation efforts are generally categorized into five areas:

- Planning
- Engineering and System Design
- Grid Improvements
- Vegetation Management and other Inspection and Maintenance Programs
- Standard Operating Practices, Emergency Planning and Response, and Stakeholder Outreach

These existing efforts are summarized below and are included in the 2018 GRC. These efforts will be enhanced by incremental GS&RP activities that are the subject of this Application and described in Chapter IV.

1. Existing Planning Activities

SCE has several plans in place to prepare for, and mitigate the impact of, potential wildfires and other emergency events like storms in its service area. Among these, SCE’s Fire Prevention Plan is the key planning document for wildfires. This plan consolidates practices and policies that SCE personnel follow to minimize the likelihood that utility lines and equipment could increase fire hazards (i.e., fire ignitions associated with electrical equipment or lines) in its service area, with special attention for designated HFRA. SCE reviews the plan at least annually, with the most recent update in October 2017. The plan includes operating restrictions on electrical lines during dry and windy weather conditions, such as Red Flag Warnings, preventive measures, system design and construction practices, and actions SCE’s crews and

1 support staff must follow during high wind events and other serious events such as snow, heat,
2 wind, and rain storms.

3 **2. Existing Engineering and System Design Activities**

4 SCE has traditionally designed its system to provide safe and reliable power to
5 customers, and these efforts provide wildfire mitigation benefits. Automation equipment such as
6 circuit breakers, remote-controlled automatic reclosers (RARs), and radio communications
7 systems along SCE's distribution lines are used to quickly detect faults, isolate circuits, and
8 restore electric service to customers. SCE has installed automated RARs and circuit breakers on
9 its distribution lines in HFRA to prevent reclosing should faults occur during high wind events,
10 which lessens the potential for fires from distribution line faults. SCE also follows several
11 principles when designing its system, including using wider easements and rights of way and
12 clearing buffers around substations to reduce the possibility of ignition due to debris contacting
13 substation equipment.

14 **3. Existing Grid Improvement Activities**

15 Over the years, SCE has implemented many infrastructure investment programs.
16 These programs help mitigate wildfire risk and include replacement programs designed to
17 mitigate in-service failures for transmission and distribution assets (e.g., wooden poles, overhead
18 conductors, relays, etc.). SCE reviews its multiyear plan for these infrastructure investment
19 programs during the annual operating plan process and, as necessary, reprioritizes and adjusts
20 program investments accordingly.

21 **4. Existing Vegetation Management and Other Inspection and Maintenance**
22 **Program Activities**

23 SCE has several vegetation management programs to maintain the approximately
24 900,000 trees in its inventory. These programs focus on identifying, and either pruning or
25 removing, trees in HFRA (and non-HFRA) based on proximity to transmission and distribution
26 lines, their health and expected growth (or decline), and environmental conditions such as
27 drought. SCE uses inspections and tracking processes to meet Commission and all applicable

1 regulations. It also has programs to perform additional detailed inspections and address trees
2 near circuits with the highest number of interruptions in HFRA and in canyons where high winds
3 and narrow roads increase fire risk. In addition, SCE staff meet and accompany local, county, or
4 state fire agency personnel to perform supplemental patrols of overhead lines to strengthen fire
5 readiness in HFRA.⁴⁸

6 SCE has other inspection and maintenance programs that, among other objectives,
7 help minimize sources of fire ignition and other wildfire risks, such as the Overhead Detailed
8 Inspection Program (ODIP)⁴⁹ and the Intrusive Pole Inspection Program (IPIP).⁵⁰ SCE also
9 conducts annual grid patrols and performs routine and detailed inspections and maintenance of
10 its transmission lines.

11 **5. Existing Standard Operating Practices, Emergency Planning and Response,**
12 **and Stakeholder Outreach Activities**

13 SCE has several policies and standard operating procedures for wildfire
14 mitigation in HFRA, and for managing its system during a fire event. These include specific
15 procedures for operating distribution lines traversing HFRA,⁵¹ and for standing up the Incident
16 Command System (ICS) during critical events (SCE's ICS is modeled after Federal Emergency

⁴⁸ Since 2001, SCE has been annually organizing Operation Santa Ana, which is a partnership with state and county fire authorities to perform joint patrols of overhead pole and powerline inspections to ensure appropriate tree-to-powerline clearances and brush removal around poles to strengthen fire readiness in HFRA.

⁴⁹ The ODIP involves visually evaluating SCE's overhead electrical distribution facilities to identify and document obvious discrepancies and validate accuracy of asset information and facility inventory mapping references for appropriate corrective action. Inspectors also identify and perform certain maintenance tasks during the course of a detailed inspection.

⁵⁰ The ODIP involves evaluating SCE's wood pole system using both visual and internal examinations to identify and document damage or decay on poles requiring remediation. Inspectors also apply a preservative to passing poles to reduce the likelihood of future decay.

⁵¹ SCE utilizes an operating policy called Standard Operating Bulletin 322 to standardize the operation of distribution voltage lines traversing fire hazard areas. This policy imposes operating restrictions on designated overhead distribution lines to reduce the risk of wildfires during a Red Flag Warning. This policy requires all circuit breakers and reclosers in fire hazard areas be made non-automatic until the Red Flag Warning expires. If protective relays on these circuit breakers operate to interrupt the flow of electricity, the line is not re-energized until it is patrolled and deemed safe.

1 Management Agency (FEMA) protocols). The ICS structure facilitates SCE’s own response and
2 coordinated multi-agency responses during fire events. SCE also conducts exercises and drills
3 with local emergency responders, fire agencies, regulatory agencies, and neighboring utilities
4 annually to test its ICS framework and enhance coordination efforts during emergency events
5 such as fires.

6 SCE has also recently instituted a formalized Public Safety Power Shutoff (PSPS)
7 protocol where it may de-energize power in HFRA to reduce the risk of fire ignition during the
8 most extreme and potentially dangerous fire conditions. A PSPS event is the preventive measure
9 of last resort in a robust line of defenses against fire risk deployed by SCE. This practice is
10 aimed at keeping the public, SCE customers, and SCE employees safe. SCE currently considers
11 many factors before deciding to de-energize, such as input from in-house meteorologists about
12 current and forecasted fire weather conditions, and fuel characteristics and moisture levels for
13 vegetation surrounding utility infrastructure.

14 SCE also participates in the California Utility Emergency Association, which
15 serves as a point of contact for critical infrastructure utilities, the California Office of Emergency
16 Services, and other governmental agencies before, during, and after an event to facilitate
17 communications and provide emergency response support. And it maintains a Fire Management
18 Team that serves as SCE’s primary interface with fire incident responders.⁵²

19 A critical component of SCE’s wildfire mitigation and recovery efforts is
20 effectively communicating with customers, community groups, and other stakeholders about
21 how to prepare for, prevent, and mitigate wildfires in its service area. It also uses
22 communication plans during a fire event to inform stakeholders and provide them with necessary
23 information. Core outreach initiatives related to wildfires also include collaboration and training
24 for local firefighting agencies.

⁵² These Fire Managers have experience as fire fighters and/or linemen. They have strong relationships with the communities and the fire incident commanders in SCE’s service area, and a detailed understanding of SCE’s electric infrastructure. They keep lines of communication open to involved agencies, provide training and training materials, and serve as onsite coordinators during fire events.

1 **C. SCE’s GS&RP: Further Hardening the Electric System and Enhancing Utility**
2 **Situational Awareness and Operational Capabilities**

3 **1. Creation of Program Management Office Focused on Addressing Increasing**
4 **Wildfire Risk**

5 SCE agrees with the Governor, the legislature, and other state officials that
6 additional investments to further enhance the safety and resiliency of the electric system are
7 warranted following the 2017 wildfires. Because addressing this issue is a top priority, in early
8 2018 SCE created a program management office (PMO) aggregating SCE’s fire mitigation
9 efforts and focused on bolstering public safety and system resiliency.

10 SCE charged the PMO with the following, overarching objectives: (1) executing
11 near-term actions to further mitigate increased wildfire risk; (2) developing enhancements to its
12 operational plans for long-term wildfire, public safety, and related resiliency strategies; and (3)
13 integrating SCE’s wildfire mitigation strategies with existing programs, such as long-term capital
14 planning, the Risk Assessment and Mitigation Phase (RAMP),⁵³ and the GRC. The first two
15 objectives are most relevant to this Application—for these, the PMO reviewed fire mitigation
16 strategies and researched potential enhancements focused on fire prevention (avoiding ignitions),
17 aiding suppression activities by others (speeding confirmation and assessment of fires), and
18 system resiliency (withstanding fires). The PMO also researched existing and emerging utility
19 fire mitigation strategies related to risk management and asset management for applicability to
20 SCE’s wildfire mitigation efforts.

21 Based on this assessment, SCE proposes further enhancing the safe operation of
22 its electric system and improving its resiliency by focusing on three primary areas: (1) further
23 grid hardening; (2) enhanced situational awareness; and (3) enhanced operational practices.
24 SCE’s portfolio of mitigation measures addresses all aspects of fire risk, but primarily focuses on

⁵³ RAMP filing requirements are guided by decisions in the Risk-Informed Decision Making for General Rate Cases Rulemaking (D.14-12-025) and in the subsequent Safety Model Assessment Proceeding (D.16-08-018). SCE will file its RAMP report on November 30, 2018.

1 preventing potential fire ignitions associated with utility equipment. This is an appropriate
2 focus: although utility equipment is only connected with up to ten percent of all of the state’s
3 historical fires, these fires can be large. For example, fires associated with electrical facilities
4 have been as large as 25 to 46 percent of total acreage burned in the state resulting from all fires
5 in prior years.⁵⁴ This is primarily due to greater wind speed, which means conditions more
6 favorable to the spread of wildfire, conditions where suppression is less effective, and conditions
7 in which firefighters are likely to be spread thin.⁵⁵

8 The increase of wildfire risk creates an even stronger need to find means to reduce
9 the cause of wildfires and enhance methods to detect and suppress them more quickly. This
10 approach is consistent with the legislature’s direction in SB 901, which, as noted earlier,
11 provides that electric utilities must “construct, maintain, and operate [their] electrical lines and
12 equipment in a manner that will minimize the risk of catastrophic wildfire posed by those
13 electrical lines and equipment.”⁵⁶

14 **2. Overview of Key GS&RP Wildfire Mitigation Activities**

15 a) Enhanced Grid Hardening

16 SCE is proposing to harden its infrastructure to significantly reduce
17 potential fire ignition sources. Figure II-3 below is a breakdown of fires associated with SCE’s
18 distribution system located in HFRA. As shown in Figure II-3, SCE’s historical data show that
19 over half of all fires associated with SCE’s distribution infrastructure in HFRA were caused by
20 foreign objects such as palm fronds, metallic balloons, debris, etc., contacting electric facilities.


⁵⁴ See Chapter III.A.1, *infra*.

⁵⁵ Kousky, C., Greig, K., Lingle, B., & Kunreuther, H. *Wildfire Costs in California: The Role of Electric Utilities*, Issue Brief (Aug. 2018), available at <https://riskcenter.wharton.upenn.edu/wp-content/uploads/2018/08/Wildfire-Cost-in-CA-Role-of-Utilities-1.pdf> This study was partially supported by an unrestricted gift by Edison International.

⁵⁶ Senate Bill 901, 2017-2018 Reg. Sess. (Cal. 2018). SB 901 has been submitted to the Governor for signature.

Figure II-3
Breakdown of SCE's Historical Fire Causes
(Distribution Voltage Infrastructure in HFRA from 2015 – 2017)

FIRE DATA



1 To address this, SCE’s grid hardening approach centers on replacing
 2 standard “bare” overhead conductor (i.e., exposed electric wires) with “covered” conductor,
 3 which is covered with special layers of insulation materials that protect electric lines against
 4 contacts from foreign objects and also against power lines coming into contact with each other
 5 during high winds. This is a more progressive approach compared to current utility practice,⁵⁷
 6 and is supported by research that determined it to be effective under severe wildfire conditions as
 7 it prevents faults from occurring and avoids ignitions at the site of the fault and potential failure
 8 of upstream conductor. Research also determined it to provide the best customer value
 9 compared to other potential mitigation measures, like undergrounding. SCE will prioritize

⁵⁷ Today, most utilities across the U.S. are able to accept the consequence of foreign objects contacting overhead lines by relying on protective relays and circuit reclosers that can detect these anomalies and quickly isolate line faults even though there is arcing with sparks that could cause ignitions. This is a standard utility practice that has been in place for many decades and is entirely reasonable—but SCE has determined this approach should now be adjusted to incorporate the use of covered conductor in selected situations given the heightened fire risk under the “new normal” environment in California.

1 deploying these conductors according to risk, focusing on portions of circuits in HFRA with the
2 greatest exposure to potential wildfire ignitions from line faults. Additionally, for covered
3 conductor projects in HFRA, SCE will use fire resistant composite cross-arms and poles with a
4 fire protective shield for pole replacements, when appropriate, to increase resiliency and reduce
5 potential outage impacts resulting from a fire event.

6 SCE's grid hardening efforts will also focus on limiting potential faults
7 from igniting wildfires. To accomplish this, SCE will add (and replace) certain devices on its
8 system to mitigate fault-related ignition risks. SCE will install additional fuses that activate
9 quickly to reduce the energy transmitted to faults and, accordingly, further reduce the risk of
10 ignitions from faults. Additionally, the existing remote-controlled automatic reclosers (RARs)
11 and selected substation Circuit Breakers (CBs) protecting circuits in HFRA will have their
12 remote "reclose blocking" capabilities expanded to include automated high-speed, "fast curve"
13 settings during Red Flag Warnings to further reduce the potential of ignitions from line faults.
14 SCE will also install additional RARs and upgrade selected substation CBs with these advanced
15 protection features, which may reduce the frequency and duration of some PSPS events.

16 b) Enhanced Situational Awareness

17 The second important feature of SCE's GS&RP is enhancing existing
18 situational awareness capabilities to more fully assess potential wildfire conditions and develop
19 appropriate operational plans, including preventive power shutoffs to mitigate wildfire risk. This
20 includes deploying additional weather stations along circuits in HFRA, and installing HD
21 cameras that will enable state and local fire agencies as well as SCE emergency management
22 staff to more quickly identify and respond to wildfires. SCE is also deploying advanced
23 computer hardware and state-of-the-art software that will run a sophisticated High Resolution
24 Weather model to support planning and operational decisions to reduce wildfire risk, and
25 increasing staffing of fire management personnel and meteorologists.

1 c) Enhanced Operational Practices

2 The third prong of the GS&RP is developing programs to further
3 strengthen operational practices regarding fire prevention and system resiliency. Among these,
4 enhancing SCE’s vegetation management program is a priority. SCE intends to focus on
5 proactively assessing and, as needed, mitigating trees that pose a blow-in / fall-in threat to
6 electrical facilities but are located outside existing regulatory-required clearances and are not
7 dead, sick, or dying.

8 Other operational practices SCE included in this filing include regular
9 infrared inspections of the distribution system. Use of infrared enables identification of “hot
10 spots” that could, if unaddressed, lead to potential wire and equipment failure. SCE began
11 evaluating this technology in 2016, and the results are promising in terms of identifying and
12 proactively addressing potential equipment failures not readily apparent during routine visual
13 inspections—this will also help address many of the equipment / facility failure issues described
14 previously. SCE is also proposing a mobile generator program that will provide electricity to
15 certain essential customers in the event it must initiate the PSPS protocol to address high-risk fire
16 conditions.

17 GS&RP activities will also improve system reliability over the long term,
18 as circuits in HFRA are hardened against fire risk and subject to more detailed inspections and
19 proactive maintenance. Some activities, like fusing, will have more near term reliability benefits
20 by reducing outage impacts from faults. Other activities, like deployment of mobile generators,
21 will limit reliability impacts associated with potential deployment of PSPS during extreme fire
22 conditions. It should also be noted that by hardening its system, SCE anticipates reducing the
23 need for PSPS deployment in the future.

24 **3. GS&RP Deployment Strategy and Prioritization Considerations**

25 SCE’s GS&RP is estimated to span several years, as noted in Chapter I.A. Given
26 the seriousness of this situation, SCE is already deploying some aspects of the GS&RP, such as

1 starting installation of covered conductor on the most critical risk circuits and deploying fuses,
2 weather stations, and HD cameras across HFRA.

3 In developing the GS&RP deployment timeline, SCE considered multiple factors,
4 including the deployment or cycle time for various mitigation measures, risk reduction, and
5 resource constraints. Each mitigation measure has a unique cycle time, which under targeted
6 conditions can be expedited. Some mitigation measures, such as covered conductor, have longer
7 cycle times due to the amount of design, planning, material procurement, and construction work
8 that is involved. Other measures, such as updating the settings of existing relays, have shorter
9 cycle times and can be completed in a matter of months. To best reduce wildfire risk over this
10 time period, SCE is deploying a mix of mitigation measures that can reduce likelihood of faults
11 that could result in fire ignitions.⁵⁸

12 **4. GS&RP 2018-2020 Incremental Costs**

13 Table II-4 below summarizes each program activity and associated incremental
14 forecast costs for 2018-2020. While the following discussion provides insights into the
15 reasoning behind SCE's proposed spending levels, additional details related to the choice of
16 timing of various mitigation measures and their associated benefits are provided in Chapter IV.

17 SCE's proposed spending levels for the 2018-2020 period are driven by the scope
18 of measures selected along with resource constraints that govern the speed at which each
19 measure can be deployed. The largest elements of SCE's proposed GS&RP are the Wildfire
20 Covered Conductor Program (WCCP), expanded vegetation management activities, and fusing.

21 For WCCP, the levels of spend for 2018 and 2019 were primarily limited by the
22 speed at which these new projects could be designed and planned. For 2020 projects, WCCP
23 projects will have greater lead time to enable normal design and planning processes to
24 accommodate larger volumes of work. The marked jump in WCCP spend from 2019 to 2020 is
25 due to SCE's planned accelerated installation of fuse installations in advance of the installation

⁵⁸ SCE's RAMP filing will provide additional analysis of the risk reduction benefits of proposed and alternative wildfire mitigation measures.

1 of covered conductor, to achieve near-term risk reduction across all HFRA. Since these fuse
2 installation projects utilize similar design and planning resources as WCCP projects, the
3 combined volume of work from these two program elements are also constrained by design and
4 planning resources and associated cycle times. Finally, SCE's expanded vegetation management
5 expenditures represent new activities being developed, which SCE anticipates launching in the
6 first quarter of 2019 and expanding through 2020.

Table II-4
2018-2020 Grid Safety & Resiliency Program Costs

| Capital (2018 Constant \$000) | | | | | |
|--------------------------------------|---|-----------------|------------------|------------------|------------------|
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | Grid Hardening | | | | |
| 2 | Wildfire Covered Conductor | 33,936 | 45,979 | 204,927 | \$284,842 |
| 3 | Remote-Control Automatic Reclosers | - | 8,789 | 18,076 | \$ 26,864 |
| 4 | Fusing Mitigation | 11,923 | 44,949 | 9,362 | \$ 66,235 |
| 5 | Total Grid Hardening | \$45,859 | \$ 99,716 | \$232,365 | \$377,941 |
| 6 | Enhanced Situational Awareness | | | | |
| 7 | HD Camera | 1,123 | 2,272 | 741 | \$ 4,136 |
| 8 | Weather Station | 1,066 | 5,922 | 6,345 | \$ 13,334 |
| 9 | Advanced Modeling Computer Hardware | 2,943 | 3,722 | 1,330 | \$ 7,995 |
| 10 | Asset Reliability and Risk Analytics | 3,380 | 505 | - | \$ 3,885 |
| 11 | Total Enhanced Situational Awareness | \$ 8,512 | \$ 12,421 | \$ 8,416 | \$ 29,349 |
| 12 | Capital Total | \$54,371 | \$112,137 | \$240,781 | \$407,290 |
| O&M (2018 Constant \$000) | | | | | |
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | Grid Hardening | | | | |
| 2 | Wildfire Covered Conductor Program | 747 | 951 | 4,201 | \$ 5,899 |
| 3 | Remote-Control Automatic Reclosers | 845 | 457 | 371 | \$ 1,673 |
| 4 | Fusing Mitigation | 271 | 2,640 | 21,138 | \$ 24,049 |
| 5 | Total Grid Hardening | \$ 1,862 | \$ 4,049 | \$ 25,710 | \$ 31,621 |
| 6 | Enhanced Situational Awareness | | | | |
| 7 | HD Camera | 618 | 2,572 | 3,197 | \$ 6,387 |
| 8 | Weather Station | 142 | 631 | 1,200 | \$ 1,973 |
| 9 | Advanced Weather Modeling Tool | 384 | 604 | 604 | \$ 1,592 |
| 10 | Advanced Modeling Computer Hardware | 50 | 120 | 120 | \$ 290 |
| 11 | Asset Reliability and Risk Analytics | 7 | 9 | - | \$ 16 |
| 12 | Additional Staffing Required | 115 | 480 | 480 | \$ 1,074 |
| 13 | Total Enhanced Situational Awareness | \$ 1,317 | \$ 4,416 | \$ 5,600 | \$ 11,333 |
| 14 | Enhanced Operational Practices | | | | |
| 15 | Vegetation Management | - | 40,148 | 77,921 | \$118,069 |
| 16 | Infrared Inspection Program | - | 459 | 459 | \$ 918 |
| 17 | PSPS Protocol Support Functions | 3,165 | 3,497 | 3,497 | \$ 10,159 |
| 18 | Mobile Generator Deployment | 137 | 137 | 137 | \$ 411 |
| 19 | Portable Community Power Trailers | 1,102 | 9 | 9 | \$ 1,120 |
| 20 | Total Enhanced Operational Practices | \$ 4,404 | \$ 44,249 | \$ 82,023 | \$130,676 |
| 21 | Wildfire Mitigation Program Study | \$ 512 | \$ 521 | \$ 380 | \$ 1,413 |
| 22 | O&M Total | \$ 8,095 | \$ 53,235 | \$113,712 | \$175,042 |

1 III.

2 **THE GS&RP WAS DEVELOPED USING A RISK-INFORMED DECISION-MAKING**
3 **PROCESS**

4 This Chapter provides an overview of SCE’s risk-informed decision-making process used
5 to develop the GS&RP.⁵⁹

6 **A. Overview of SCE’s Risk-Informed Decision-Making Process**

7 SCE’s risk-informed decision-making process began with developing an understanding
8 of the fundamental elements that enable fire to ignite, the statistical trends associated with fires
9 across California, particularly those caused by electrical power lines, the historical data
10 surrounding fires associated with SCE’s grid infrastructure, and the geographic locations within
11 SCE’s service area that represent the greatest wildfire risk (both likelihood and consequence of
12 ignition). From there, SCE identified various mitigation measures that can reduce the likelihood
13 of faults that could cause an ignition and potentially result in a wildfire, and estimated the risk
14 reduction (benefits) associated with each measure. SCE considered multiple factors including
15 each mitigation’s effectiveness, deployment timing, resource allocation, alternatives, and other
16 constraints to develop a comprehensive and complementary suite of solutions to reduce wildfire
17 risks.⁶⁰

⁵⁹ SCE’s approach has similarities to the policy framework for utility wildfire prevention recently presented by the CPUC’s Safety and Enforcement Division Director, Elizaveta Malashenko. Similarities include focus on ignition control, weather preparedness, fuel management (fire triangle), reliance on cause data to guide actions, and use of advanced means to gain situational awareness and analyze/model risk. See CPUC, Joint Agency Workshop on Climate Adaptation and Resiliency titled *Climate Adaptation and Utility Wildfire Prevention*, (August 2, 2018); California Legislature, *Conference Committee on SB 901 Informational Hearing: Ensuring a Safe and Reliable Electric Grid*, (August 7, 2018).

⁶⁰ SCE’s review of the wildfire risk landscape drove—and continues to drive—decisions regarding work undertaken outside the GS&RP, including some enhanced measures that SCE began to implement in advance of this Application. For example, as noted earlier, SCE has already begun proactively re-conductoring portions of selected high priority circuits in HFRA with covered conductor. This provided a means for SCE to meaningfully reduce wildfire risk on select circuits in the near-term and also allowed SCE to gain critical deployment capabilities and experience, in preparation for large-scale deployment as part of the GS&RP.

1 The specific approach used by the team to develop the GS&RP follows SCE’s risk-
2 informed decision-making framework. This framework is a logical six-step process and
3 examines both the likelihood and impact associated with potential risk events such as wildfires:

- 4 1. Risk Identification
- 5 2. Risk Evaluation
- 6 3. Risk Mitigation Identification
- 7 4. Risk Mitigation Evaluation
- 8 5. Decision-Making and Planning
- 9 6. Monitoring and Reporting

10 The following sections describe how these steps were used to develop SCE’s suite of
11 enhanced mitigation measures, its philosophy for selecting and deploying these measures, and
12 how each one addresses the broader wildfire risk landscape for the benefit of the state and the
13 communities in (and surrounding) SCE’s service area. As also discussed below, SCE’s risk
14 analysis supporting the GS&RP will inform its upcoming Risk Assessment Mitigation Phase
15 (RAMP) of its 2021 GRC, scheduled to be filed in November 2018. In its RAMP filing, SCE
16 will present additional analysis of wildfire risk among other top safety risks facing the utility.

17 **1. Steps 1 and 2: Risk Identification and Evaluation**

18 The first two steps of this analysis involve identifying and evaluating the wildfire
19 risk, the driver(s) and potential resulting negative outcomes. Chapter II discussed the increased
20 wildfire risks facing California and projections for future changes. Addressing these new risks
21 requires both an understanding of the basic drivers of wildfires and how these drivers may
22 change over time.

23 To understand the fundamental behavior of fire ignitions, SCE looked to the
24 elementary science behind fire ignitions and propagations. The fire triangle in Figure III-4
25 shows that a fire requires three necessary elements: (1) heat source that starts the ignition; (2)
26 fuel, or dry vegetation in the case of a wildfire; and (3) oxygen, or catalysts such as wind gusts to
27 propel the wildfire. Eliminating or reducing any one of these three elements in turn reduces the

1 risk of fire ignition and its propagation. This provided a framework for SCE to subsequently
2 identify and consider potential mitigation measures that target each element.

Figure III-4
The Fire Triangle



- Heat (ignition source & energy level)
- Fuel (material or dry vegetation)
- Oxygen (catalysts or wind gusts)

3 Within the context of ignitions associated with SCE’s electrical infrastructure, the
4 heat comes from the energy and flow of electricity within the grid. Conditions, such as arcing,
5 are the root ignition source. The fuel in SCE’s service area is principally associated with the
6 trees and other vegetation in proximity to electrical facilities, which is exacerbated by drought
7 and other climate changes that increase the quantity of flammable dry fuel. Increased flow of
8 oxygen from strong winds combined with low humidity heightens the risk associated with
9 ignitions that can quickly spread and become difficult to suppress or contain. In late 2017, the
10 state was subjected to “unprecedented” strong winds that have the potential to carry palm fronds
11 and other debris from even greater distances into utility lines.⁶¹

12 In addition to understanding the fundamental drivers behind fire ignitions and
13 propagation, SCE looked at historical data on the causes of fire ignitions, starting with all fires

⁶¹ In December 2017, the state for the first time experienced “purple” (i.e., extreme) winds capable of reaching 80 mph. See Associated Press, *California wind hits unprecedented high—and so does fire danger* L.A. Times (December 7, 2017), available at <http://www.latimes.com/local/lanow/la-me-ln-purple-wind-map-20171207-story.html>.

1 across California. CalFire maintains historical wildfire activity statistics, known as Redbooks.⁶²
2 In 2016, 2,816 fires were identified, of which 270 were associated with electrical power, and in
3 2015, 3,231 fires were identified, of which 251 were associated with electrical power. Overall,
4 the CalFire data indicate that electrical power is generally associated with up to ten percent of
5 statewide fires. But these fires have the potential to be sizable: for example, fires associated with
6 electrical power in 2007, 2013, and 2015 represented 46 percent, 39 percent, and 25 percent of
7 the total acres burned in California in those years, respectively. Additionally, external analysis
8 of California wildfires (1960-2009) indicates that the average size of fires attributed to power
9 lines is approximately ten times greater than the average size for all fires.⁶³ This is “because the
10 probability of ignition from a power line increases with wind speed. Greater wind speed means
11 conditions more favorable to the spread of wildfire, conditions where suppression is less
12 effective, and conditions in which firefighters are likely to be spread thin.”⁶⁴ Efforts to mitigate
13 wildfires associated with electrical power lines may reduce the incidence of major wildfires.

14 To further understand the cause of fires associated with its electrical system, SCE
15 analyzed fires that occurred in its HFRA from 2015 through 2017 that were of significant size
16 and reportable to the Commission.⁶⁵ The results indicated that approximately 90 percent of all of
17 the fires associated with electrical equipment in SCE’s service area are related to distribution
18 level voltages (33kV and below). As a result, SCE’s subsequent risk analyses targeted

⁶² CalFire Redbook, *Historical Wildfire Activity Statistics*, available at http://www.fire.ca.gov/fire_protection/fire_protection_fire_info_redbooks. Other top causes of fires include arson, campfires, debris burning, equipment use, vehicles, miscellaneous, and undetermined.

⁶³ J.W. Mitchell *Power Line Failures and Catastrophic Wildfires Under Extreme Weather Conditions. Engineering Failure Analysis*, Vol. (35), pp. 726-735 (December 15, 2013).

⁶⁴ Kousky, C., Greig, K., Lingle, B., & Kunreuther, H. *Wildfire Costs in California: The Role of Electric Utilities*, Issue Brief (Aug. 2018), available at <https://riskcenter.wharton.upenn.edu/wp-content/uploads/2018/08/Wildfire-Cost-in-CA-Role-of-Utilities-1.pdf> This study was partially supported by an unrestricted gift by Edison International.

⁶⁵ Per D.14-02-015, reportable fire events are any events where utility facilities are associated with the following conditions: (a) A self-propagating fire of material other than electrical and/or communication facilities, and (b) The resulting fire traveled greater than one linear meter from the ignition point, and (c) The utility has knowledge that the fire occurred.

1 distribution infrastructure.⁶⁶ Data related to the initiating events for fires associated with SCE's
 2 distribution infrastructure in HFRA are shown in Figure II-3 with a detailed breakdown shown in
 3 Table III-5. Similar data of the faults on SCE's distribution infrastructure over this same period
 4 are shown in Figure IV-7 and Table IV-8.

Table III-5
Breakdown of Contact from Object and Equipment/Facility Failure Related Fires
(Distribution Voltage Infrastructure in HFRAs from 2015-2017)⁶⁷

| Suspected Initiating Event | Count | Percentage |
|-----------------------------------|--------------|-------------------|
| Contact From Object | 70 | 53% |
| Equipment/Facility Failure | 40 | 30% |
| Other, Unknown, Wire-Wire Contact | 22 | 17% |
| Total | 132 | 100% |

| Contact From Object | Count | Percentage |
|----------------------------|--------------|-------------------|
| Animal | 15 | 11% |
| Balloons | 14 | 11% |
| Other | 10 | 8% |
| Vegetation | 22 | 17% |
| Vehicle | 9 | 7% |
| Total | 70 | 53% |

| Equipment/Facility Failure | Count | Percentage |
|-----------------------------------|--------------|-------------------|
| Capacitor Bank | 2 | 2% |
| Conductor | 12 | 9% |
| Crossarm | 1 | 1% |
| Fuse | 1 | 1% |
| Insulator | 5 | 4% |
| Other | 8 | 6% |
| Splice/Clamp/Connector | 8 | 6% |
| Transformer | 3 | 2% |
| Total | 40 | 30% |

⁶⁶ SCE's GS&RP prioritizes fire risk mitigation for its distribution facilities given their heightened exposure to potential fire conditions. However, while this analysis targeted distribution level voltages, some mitigation measures will reduce fire risk for transmission facilities. These include, for example, situational awareness mitigation measures including HD cameras, weather stations, and advanced weather models. In addition, distribution lines are occasionally located below transmission lines, and, consequently, measures applied to these distribution lines will provide some risk reduction benefit for the overhead transmission lines. SCE intends to further examine fire risk mitigation measures for transmission facilities.

⁶⁷ Note, Table III-5 presents data related to fires. See Table IV-8 for data associated with faults.

1 The two greatest ignition drivers are “contact from object” followed by
2 “equipment/facility failure.” These historical statistics are consistent with the suspected ignition
3 source data for California’s investor-owned electric public utilities by the CPUC’s Safety and
4 Enforcement Division. Accordingly, SCE analyzed these two ignition drivers to develop a
5 nuanced understanding of the precise causal chain that can lead to a wildfire outcome.
6 Specifically, faults on the distribution system primarily occur either due to contact from an
7 object or an equipment/facility failure. Although rare, these faults can result in high-energy and
8 high-temperature arcing between two conductors (phase-to-phase) or between one conductor and
9 the ground (phase-to-ground). Faults can also result in the failure of other electrical equipment.
10 In either case, if arcing contains sufficient energy—given local conditions such as temperature,
11 humidity, and adjacent dry vegetation—ignition could lead to a wildfire.⁶⁸

12 Next, SCE focused on the portions of its service area where the likelihood and
13 consequence of ignitions pose the greatest threat, i.e., its HFRA, to guide the prioritization of
14 mitigation strategies. Since ignitions in SCE’s HFRA represent the greatest wildfire threats and
15 most historical ignitions related to SCE’s facilities in these areas are principally associated with
16 overhead distribution infrastructure, SCE’s source of ignitions is largely concentrated in its bare
17 overhead distribution facilities within HFRA. This risk falls into two areas: (1) objects
18 contacting bare overhead distribution conductor, which is primarily caused by animals, balloons,
19 and vegetation (these total approximately 72 percent of all contact from object caused fires); and
20 (2) failure of equipment or facilities that is predominately induced by faults associated with
21 overhead conductor.

22 **2. Step 3: Risk Mitigation Identification**

23 SCE next identified potential mitigation measures that could reduce either the
24 likelihood or impact of wildfires. The fire triangle shown above in Figure III-4 helps frame

⁶⁸ The concept of fault energy can be described as the electric system’s natural reaction to fault conditions. Dominant factors for fault energy are the time duration and the magnitude of electrical current during a fault. In essence, reducing fault energy helps reduce the probability of ignition.

possible mitigation measures for wildfire ignitions by targeting specific sides of the triangle. SCE characterizes mitigation measures that reduce risk by addressing wildfire drivers as “prevention” measures, and those measures that reduce risk by addressing wildfire outcomes and consequences as “resiliency” measures. Table III-6 summarizes how the mitigation measures included in SCE’s GS&RP address wildfire prevention and/or resiliency. Additional details regarding the benefits of each measure are provided in Chapter IV.

Table III-6
Summary of Impacts of GS&RP Mitigation Measures on Wildfire Prevention and Enhanced Grid Resiliency

| Mitigation Measure | Prevention (Reduced Frequency) | Resiliency (Reduced Impacts) |
|--|---|--|
| Wildfire Covered Conductor Program | Mitigates contact from object faults and equipment failure ⁶⁹ | Fire resistant composite poles reduce outage impacts following wildfires |
| Remote-Controlled Automatic Reclosers (RARs) and Fast Curve Settings | Mitigates wires down and reduces energy at fault location (potential point of ignition) | Reduces outage impacts from PSPS and other events |
| Fusing | Mitigates wire downs and reduces energy at fault location | Reduces outage impacts caused by faults |
| Public Safety Power Shutoff (PSPS) | Eliminates energy source that can cause ignitions in extreme conditions | Primary mitigation focus is prevention |
| HD Cameras | Primary mitigation focus is resiliency | Speeds fire agency suppression response and aids real-time reactions by grid operators |
| Weather Station ⁷⁰ | Improves forecasting and enables more precise PSPS targeting | Reduces potential size of areas impacted by potential PSPS activations |
| Infrared Scanning and Repairs | Identifies and repairs equipment prior to failure | Primary mitigation focus is prevention |
| Vegetation Management | Reduces contact faults and trees falling into lines | Reduces fuel supply |
| Emergency/Mobile Generators | Primary focus is resiliency | Reduces outage impacts during wildfire events and PSPS activations |

⁶⁹ Covered conductor mitigates contact from object caused ignitions associated with animal, balloons, vegetation, and likely some in the “Other” category. In addition to replacing aged bare conductor, other WCCP program elements will replace other aged components such as conductor, crossarms, insulators, and splices/clamps/connectors, which will mitigate equipment/facility failures.

⁷⁰ Includes advanced weather modeling tool and the high performance computing platform.

1 **3. Step 4: Risk Mitigation Evaluation**

2 SCE evaluated a range of potential mitigation solutions warranting serious
3 consideration. SCE corroborated selected mitigation solutions by benchmarking international
4 practices in jurisdictions with comparable wildfire conditions, such as Australia. SCE also
5 reviewed certain international standards related to risk management and asset management to
6 leverage components that could be applied directly to wildfire mitigation.

7 SCE analyzed faults tracked in its Outage Database and Reliability Metrics
8 System (ODRM) over the 2015-2017 period to better understand how the different types and
9 frequencies of fault incidence relate to the actual occurrence of fire events discussed above. In
10 light of this analysis, SCE evaluated possible solutions based on a number of factors, including
11 both technical capability (i.e., demonstrated ability to reduce the likelihood of fire ignition by,
12 for example, reducing faults) and the operational feasibility of implementing the solution given
13 the current design and configuration of the system. To evaluate technical capability, SCE
14 performed internal testing, commissioned external testing, and consulted with electric/utility
15 industry experts. To assess operational feasibility SCE considered, for instance, how changing
16 protection philosophies might impact reliability, or how using covered conductor in high fire risk
17 areas would affect other components of the system (such as poles) and its long term performance
18 in all the inclement weather and environmental conditions.

19 Given the significance of contact from objects as a cause of fire ignitions, SCE
20 evaluated a number of potential risk mitigation measures focused on: (1) reducing the
21 population of potential objects (i.e., reducing tree branches, metallic balloons, animals, etc. near
22 overhead lines); and (2) designing the system to be able to withstand such contact without
23 leading to a fire ignition. Regarding the first approach, enhanced vegetation management
24 practices can further reduce the likelihood that vegetation will contact overhead distribution
25 system by increasing clearances and removing even more trees. But this approach has
26 limitations, including the utility's limited ability to increase clearances in certain areas, the fact
27 that wind can often blow debris into lines from significant distances despite appropriate

1 clearances to nearby trees, and that taller trees can fall onto lines even when located well outside
2 of the utility's right of way. Thus, SCE also evaluated mitigation measures focused on the
3 second approach (withstanding contact), concluding that covered conductor is the most feasible
4 mitigation solution for fault and ignition prevention.

5 And as new technologies emerge, SCE will continue to evaluate the effectiveness
6 of more advanced solutions and how they may complement its existing portfolio of mitigation
7 measures. If new measures prove to be better than existing ones, SCE will work to transition to
8 these improved measures as appropriate. The exploration of some of these new technologies is
9 described in Section IV.E.

10 **4. Step 5: Decision-Making and Planning**

11 In developing the GS&RP, SCE determined that a portfolio of mitigation
12 measures, as opposed to implementing just one or two specific ones, is necessary to
13 comprehensively address wildfire risk across all aspects of the fire triangle. SCE also considered
14 several factors in deciding how, when, and where to implement each selected mitigation
15 measure. These factors included the risk profile for HFRA in SCE's service area, the risk profile
16 of assets that have the potential to cause ignitions, how each activity impacts the frequency
17 and/or impact of wildfires, the potential speed of deployment, interactions between mitigation
18 measures and/or planned work outside of the GS&RP, cost, resource constraints, and material or
19 technology availability.

20 **5. Step 6: Monitoring and Reporting**

21 SCE's grid resiliency and wildfire mitigation efforts are both iterative and
22 dynamic. SCE will continue to evaluate the wildfire risk landscape in SCE's service area and
23 across California. SCE will also implement a variety of processes for monitoring and evaluating
24 the work undertaken as part of the GS&RP proposal. For example, tracking of faults and
25 wildfire ignition events continues to be a critical aspect of the evaluation of wildfire risk. All
26 else being equal, SCE would expect to see meaningful reductions in risk metrics over time as a
27 result of implementing the GS&RP proposal. SCE's monitoring and evaluation will also capture

1 valuable lessons from the initial GS&RP deployment period, which may help in the efficiency
2 and efficacy of the GS&RP initial deployment. These lessons will then inform future program
3 elements that would be the subject of the 2021 GRC.

4 **B. The GS&RP Aligns With, and Will Inform, SCE's Upcoming RAMP Filing**

5 The Commission modified the GRC process to include RAMP as the initial phase of each
6 utility's GRC, incorporating a risk-informed decision-making framework and providing an early
7 indication of the utility's top safety risks and mitigation plans. The Commission's intent was to
8 provide additional transparency and understanding of how top safety risks are identified and
9 prioritized, and accountability for how these risks are managed and mitigated.

10 SCE's RAMP Application is scheduled to be filed with the Commission by November
11 30, 2018. SCE's evaluation of risk mitigation effectiveness that informed development of the
12 GS&RP is a modeling input for the RAMP analysis. Over the past few years, wildfire risk has
13 been one of SCE's key enterprise risks, and SCE's RAMP filing will further analyze the
14 effectiveness of mitigation options addressing this risk in the context of other key safety risks
15 facing the utility. SCE's RAMP will also evaluate mitigation options for wildfire risks over a
16 wider timeframe (i.e., the 2021 GRC period) and present those risk analysis results to the
17 Commission.

1
2
3
4
5
6
7
8

IV.

GS&RP PROJECTS

In this Chapter, SCE reviews the portfolio of mitigation measures included in its GS&RP, discussing the need for each mitigation measure, what currently exists today, as of this filing (and why it should be enhanced), alternatives considered, the deployment timeline, and estimated costs. Each project fits into SCE’s broader wildfire mitigation strategy targeting both wildfire prevention and system resiliency. Table IV-7 below presents SCE’s forecast 2018-2020 revenue requirement for the GS&RP projects described in this Chapter.

*Table IV-7
Forecast 2018-2020 GS&RP Revenue Requirement*

| Revenue Requirement (Nominal \$000) | | | | |
|---|-----------------|-----------------|------------------|------------------|
| Description | 2018 | 2019 | 2020 | Total |
| Grid Hardening Projects | 3,021 | 12,769 | 52,977 | \$68,767 |
| Enhanced Situational Awareness | 2,392 | 7,995 | 11,344 | \$21,730 |
| Enhanced Operational Practices | 4,560 | 46,050 | 86,514 | \$137,124 |
| Wildfire Mitigation Program Study | 518 | 535 | 398 | \$1,451 |
| Total Grid Safety & Resiliency Program | \$10,490 | \$67,349 | \$151,233 | \$229,072 |

9
10
11
12
13
14
15
16
17
18
19
20
21

A. **Portfolio Overview**

At the center of SCE’s wildfire mitigation strategy is an approach and philosophy targeted at preventing ignitions. This approach heavily targets the heat element of the triangle. As described in Section III.A.1, SCE’s overhead distribution facilities represent the most likely source of ignitions and those portions of circuits that traverse HFRA present the highest risk, both from a likelihood of ignition and from the potential consequences of an ignition. SCE’s approach to minimizing ignitions combines several enhanced grid hardening and operational practices. For these circuits, SCE’s Wildfire Covered Conductor Program is designed to reduce the greatest historical source of ignitions, which are associated with faults resulting from contact from objects by covering those spans most prone to contact. This measure will help prevent the faults from occurring in the first place.

While this state-of-the-art covered conductor is very effective at preventing common causes of faults, it cannot prevent every type of fault in every circumstance, particularly if

1 external forces damage or break the conductor. Thus, SCE’s enhanced vegetation management
2 efforts aim to reduce trees that can fall into electrical lines and lead to ignitions. These enhanced
3 practices will benefit both the portions of circuits that have been covered and those that will
4 remain bare. SCE’s Wildfire Covered Conductor Program (WCCP) and enhanced vegetation
5 management practices are each independently necessary and complementary to one other:
6 covered conductor deployment will occur over several years on certain targeted spans and
7 circuits in HFRA while SCE’s enhanced vegetation management program will be implemented
8 in the near term, throughout HFRA.

9 In addition to measures that prevent faults, SCE will utilize hardening measures and
10 enhanced operational practices to reduce the likelihood of ignition if a fault were to occur by
11 reducing the amount of energy associated with faults. SCE’s use of remote-controlled automatic
12 reclosers (RARs) at the boundaries of HFRA will help reduce ignitions on portions of circuits
13 that traverse HFRA by utilizing “fast curve” relay settings that will activate more quickly and
14 reduce fault energy. Additionally, these devices will be programed to prevent automatic
15 reclosing during Red Flag Warning conditions when wildfire risk is elevated. SCE’s fusing
16 mitigation will install and replace fuses on smaller branch lines within HFRA. Like the RARs,
17 these fuses have the capability to reduce the amount of energy associated with faults and provide
18 greater protection deeper into the circuits downstream from RARs. Last, SCE is utilizing
19 infrared inspection of overhead equipment in an effort to detect equipment that may fail in the
20 near future and can be replaced prior to causing an ignition. This mitigation measure also
21 complements the WCCP by targeting types of equipment/facility failures not directly addressed
22 by WCCP and will include all of SCE’s overhead equipment in HFRA.⁷¹

23 While SCE cannot directly affect the oxygen element of the triangle, SCE is taking steps
24 to enhance its situational awareness capabilities to better understand weather conditions that
25 present elevated risks for fires that can grow into large events that are challenging to suppress.

⁷¹ See Chapter IV.D.2 for a details about SCE’s infrared inspection program.

1 The addition of weather stations and advanced weather modeling tools will enable SCE to better
2 anticipate and plan for severe weather events. In the event that conditions are extreme and can
3 result in an ignition that could cause a potentially catastrophic wildfire, SCE will utilize this real-
4 time information along with field monitors to exercise its measure of last resort, the PSPS
5 protocol.

6 For the fuel element of the triangle, SCE's enhanced vegetation management program
7 will seek to remove additional trees within HFRA that pose a potential risk to electric facilities.
8 This measure is primarily intended to prevent ignitions, but should provide some reduction in
9 overall fuel load. Additionally, advanced modeling and high performance computing, coupled
10 with advanced asset reliability and risk analytics, will aid SCE in performing vegetation and fuel
11 load modeling, and understanding with greater granularity which assets and locations within
12 HFRA present the greatest threat. This will enable SCE to better execute and deploy near-term
13 operational measures and refine and guide longer-term mitigation measures.

14 Last, in the event that an ignition does occur, new HD cameras can aid fire agencies in
15 responding more quickly to reduce the size and impacts of fires. Other mitigation measures
16 presented in this Chapter aim to reduce the potential impact to customers of outages associated
17 with PSPS, such as mobile generators, portable community power trailers, and exploration of
18 unmanned aerial systems.

19 **B. Grid Hardening Projects**

20 **1. Wildfire Covered Conductor Program**

21 a) Program Overview

22 The Wildfire Covered Conductor Program (WCCP) is the central grid
23 hardening fire mitigation solution for SCE's GR&SP. SCE expects the use of covered conductor
24 in HFRA to meaningfully reduce the wildfire ignition risks associated with overhead electrical
25 distribution system facilities.

26 SCE takes significant measures to design and maintain its systems to meet
27 all current safety code and compliance requirements. Nevertheless, some risks associated with

1 fire ignition remain. For instance, in HFRA, SCE's overhead distribution system can serve as a
2 potential fire ignition source when anomalies occur. Faults can occur when vegetation, metallic
3 balloons, animals, or other debris comes into contact with overhead conductor, causing short
4 circuit conditions. Fault conditions can sometimes cause intact conductor failures, resulting in
5 energized wire down events, which could involve electrical arcing in air or on the ground, each
6 of which can lead to fire ignition.

7 SCE has identified covered conductor as an important mitigation solution
8 to reduce the fire risks associated with contact-related faults on overhead conductor. The WCCP
9 seeks to reduce the risk of fire ignition through targeted replacement of existing bare overhead
10 conductor in HFRA with covered conductor. Covered conductor is aluminum or copper wire
11 insulated with a three-layer design, providing robust protection against contact-related faults and
12 the electrical arcing associated with a variety of fault conditions. Covered conductor, unlike bare
13 conductor wire, is specifically designed to withstand incidental contact with vegetation, other
14 debris, and even the ground in a wire down event. Thus, covered conductor achieves many of
15 the same fire mitigation benefits as converting overhead wire to underground cable, but at a
16 fraction of the cost. It also has similar public safety benefits, but does not suffer from the
17 troubleshooting and restoration delays associated with underground systems, meaning faster
18 repairs and shorter outage times for customers.⁷² SCE's WCCP will target the installation of
19 covered conductor on certain spans of the overhead distribution system in HFRA that are
20 estimated to pose the greatest risk of fire ignition.

⁷² Additional limitations of underground systems include that they cannot be visually inspected, they require service interruptions to perform maintenance, are difficult to upgrade and often require excavation, and are difficult to troubleshoot during emergencies, resulting in longer outages.

1 b) What Exists Today

2 (1) SCE's Historical Use of Bare Conductor Wire

3 SCE operates a large overhead electrical distribution system, and a
4 substantial portion of it is located in HFRA.⁷³ In constructing its overhead distribution system,
5 SCE has historically relied principally on bare conductor over other options, such as
6 undergrounding or legacy-designed covered conductor.⁷⁴ This was consistent with the standard
7 practice used by California's other investor-owned public utilities and utilities in many other
8 jurisdictions.

9 For many electric utilities, including SCE, bare conductor wire has
10 been the traditional design standard for overhead distribution systems throughout their service
11 areas. Indeed, bare conductor is consistent with the requirements of G.O. 95. SCE
12 commissioned an informal survey of utilities across the United States, to confirm that other
13 major utilities outside of California, such as Oncor Electric, Duke Energy, and Xcel Energy, also
14 use bare conductor for their overhead distribution systems. This widespread use of bare
15 conductor is due to a number of factors. It has demonstrated good reliability, supports a high
16 number of customers (due to its high temperature rating), and is cost effective. As part of the
17 WCCP, SCE will use covered conductor in HFRA, but bare conductor will remain the primary
18 design standard for new construction and re-construction work throughout SCE's service area
19 outside of HFRA.

⁷³ SCE has approximately 13,400 distribution circuit miles in HFRA. A large portion, around 73 percent or approximately 9,800 circuit miles, is overhead and around 27 percent, or approximately 3,600 circuit miles, is underground. The underground portion is primarily located in more densely populated urban areas and is generally understood to represent lower wildfire risk.

⁷⁴ Legacy-designed covered conductor accounts for only a minimal portion (estimated to be approximately 50 circuit miles) of SCE's existing overhead distribution system, which consists of approximately 28,000 circuit miles of primary overhead distribution conductor across SCE's entire service area.

1 (2) SCE's Use of Covered Conductor and Industry Advances in
2 Covered Conductor Design

3 Recently, SCE began considering greater use of covered conductor
4 for wildfire risk mitigation in HFRA in response to the unprecedented damage caused by the
5 2017 wildfires and the “new normal” of year-round increased wildfire risk. Over time, the
6 industry has continuously improved the design and application of covered conductor, moving
7 from a single layer of insulating material to a robust three-layer design that SCE will deploy in
8 its WCCP. Apart from adding layers, the industry improved the material used for the insulating
9 cover. The three-layer design and material advancements improved the performance and
10 extended the life of covered conductor. In connection with these advancements, the first industry
11 standards for covered conductor were adopted in 2016, specifying design and manufacturing
12 criteria as well as qualification testing and end user usage.⁷⁵


13 These improvements, together with other advances, solved many
14 of the problems associated with earlier generations of covered conductor such as degradation
15 with UV exposure, inability to withstand more than incidental contact, radio frequency
16 emissions, and burn downs due to vibration fatigue, tracking, and lightning.⁷⁶ The advanced
17 three-layer design, specifically the XL-HDPE outer layer, improved covered conductor's
18 tolerance to UV exposure without tracking, sensitivity to radio frequency emissions, and ability
19 to withstand prolonged contact. Additionally, the use of polymer insulators (as opposed to
20 porcelain insulators) and refinement of the system design criteria for covered conductor, namely,
21 appropriate sag and span length, further addressed the problems associated with radio frequency
22 emissions and vibration fatigue. Collectively, these improvements make the newer generation of
23 covered conductor a viable solution for electrical facilities in HFRA to enhance the safety and

⁷⁵ See Insulated Cable Engineers Association, Inc., *Standard for Tree Wire and Messenger Supported Spacer Cable*, ANSI/ICEA S-12-733 (2016).

⁷⁶ SCE's service area is considered to have low risk of lightning activities compared to other regions of the country. SCE also employs industry prudent practices to mitigate lightning strikes by installing lightning arrestors at strategic locations.

1 resiliency of SCE’s system. An overview of the evolution of covered conductor technology is
2 shown in Figure IV-5.

Figure IV-5
Comparison and Evolution of Covered Conductor Technology



3 Historically, neither SCE nor the other investor-owned public
4 utilities in California have relied on covered conductor for fire mitigation. SCE used legacy-
5 designed covered conductor, known as “tree wire” because it was used for mitigating incidental
6 contact with trees under special circumstances. SCE’s use of covered conductor was limited in
7 part due to its experience with early covered conductor designs and their associated problems.
8 These aforementioned problems made designing a covered conductor system in SCE’s service
9 area difficult and not cost effective.

10 SCE also used some aerial cable, which is an installation of
11 underground cable on poles for the overhead distribution system. The early version of aerial
12 cable was assembled or bundled in the field. In the 2000s, SCE began using manufacturer
13 assembled or bundled cable, known as Aerial Bundled Cable (ABC). Thus, deployment of

1 To gain critical deployment capabilities and experience and further
2 refine SCE's design and construction standards, SCE made the decision to proactively re-
3 conductor portions of ten at-risk circuits in HFRA beginning in 2018. SCE selected these
4 circuits based on a combination of their environmental footprint, asset characteristics, and
5 potential HFRA impact. SCE viewed this as an opportunity to proactively install covered
6 conductor to help reduce existing wildfire risks associated with its distribution system in HFRA.

7 Since SCE had used covered conductor rarely, and only on an
8 individual, case-by-case basis, this re-conductoring project also allowed SCE to gain greater
9 experience with broader deployment of covered conductor at the circuit level and to provide key
10 insights for the design of the WCCP. For instance, while similar in electrical and mechanical
11 properties to bare wire conductor, covered conductor necessitates greater care when handling for
12 installation to protect the outer covering from damage. The increased diameter associated to
13 covered conductor also increases wind loads resulting in additional pole replacements beyond
14 those of bare wire re-conductoring projects.⁷⁹

15 (3) The New WCCP and the Existing Overhead Conductor Program

16 The WCCP is related to the existing Overhead Conductor Program
17 (OCP) that SCE established to re-conductor small wire circuits with the greatest public safety
18 risks from a wire down event. As a long-term program, OCP covers all of SCE's service area,
19 ranking SCE's overhead circuits based on criteria such as specific increased likelihood of wire
20 down events to address safety and reliability risks.⁸⁰ Given its focus, OCP generally prioritizes
21 circuits that serve many customers and are located in densely populated areas, where reliability
22 and public safety risks from human contact with a downed wire are greatest. At this early stage
23 of the program, the circuits being addressed are generally located in urban areas, not the
24 wildland-urban interface that is typical of HFRA, as many of the circuits with the highest

⁷⁹ See Section IV.B.1.e)(2)(a) for details regarding impacts to pole replacements.

⁸⁰ The prioritization for OCP is based on circuit breaker operations, customer density, fault duty (short circuit duty) data, and recent history of wire-down events. (A.) 16-09-001 (2018 GRC), SCE-02, Vol. 8, at p. 51.

1 wildfire risks serve areas more sparsely populated. Even though OCP's primary focus is not
2 specifically wildfire risk mitigation, to the extent it addresses the root causes of wire down
3 events, including potential conductor damage associated with short circuit duty (SCD),⁸¹ OCP
4 also has important secondary wildfire risk mitigation benefits.

5 Most of the 2018-2020 projects under OCP have already begun,
6 even if only in the early design phases. Realigning current OCP projects to focus more on
7 wildfire mitigation would require unwinding projects that have already started. This would be
8 impractical, uneconomic, and detract from OCP's important safety priorities, including in
9 portions of SCE's service area not designated as HFRA. SCE continues to recognize the
10 importance of OCP's focus on public safety, but also understands the pressing need to address
11 wildfire risk mitigation, especially in HFRA, through re-conductoring. Thus, there is a vital role
12 for incremental re-conductoring that focuses on wildfire risk mitigation to complement the
13 existing work under OCP that is mainly outside of HFRA across SCE's entire service area.

14 Further, as part of SCE's change in conductor standards, future
15 OCP projects not yet initiated will begin using the newly developed covered conductor standards
16 for re-conductoring work in HFRA. And outside of HFRA, future OCP projects also may use
17 covered conductor for reliability and other benefits based on the recommendation of field
18 subject-matter experts in areas with heavy vegetation, known metallic balloon contact risk, a
19 high frequency of outages due to intermittent contact, or within one mile of the coast.⁸²

20 c) Effectiveness

21 SCE's WCCP is an important step forward in the mitigation of wildfire
22 risks, specifically the drivers of wildfire ignitions related to electrical equipment. Since covered
23 conductor has robust layered insulation, replacing bare conductor with covered conductor is an
24 effective way to prevent contact-related faults. Preventing the occurrence of faults in turn


⁸¹ Short circuit duty (SCD) generally indicates the relative ability of a system to supply load, typically measured by the fault current (in amps), at any location within the system.

⁸² Conductors situated in close proximity to the coast can be subject to corrosion and deterioration caused by salty fog.

1 reduces the likelihood of the anomalies that lead to fault-related fire ignitions. As secondary
2 benefits, the thick insulating layer of covered conductor also improves reliability and can reduce
3 the risk associated with human contact with energized conductor, such as during a wire down
4 event.

5 The detailed risk mitigation analysis to support the use of WCCP followed
6 three sequential steps: fault-to-fire mapping; mitigation-to-fault mapping; and the calculation of
7 mitigation effectiveness factors and cost-mitigation ratios.⁸³ Figure IV-6 illustrates the sequence
8 of the risk mitigation analysis:

Figure IV-6
Risk Mitigation Analysis




9 (1) Risk Analysis: Fault-to-Fire Mapping

10 As described above in Chapter III.A.1, SCE performed a detailed
11 analysis of the fires that occurred in SCE’s service area between 2015 and 2017 that were
12 reportable to the CPUC. These fires were categorized based on “suspected initiating event” such
13 as Contact from Object (CFO) and Equipment/Facility Failure. These data are shown in Figure
14 II-3 and Table III-5. Simultaneously, SCE analyzed the fault history during this time period as
15 tracked in its Outage Database and Reliability Metrics System (ODRM). This database includes
16 various cause codes so that each fault is associated with a particular cause (e.g., metallic balloon,
17 vegetation blown, or vehicle hit). These data are shown in Figure IV-7.

⁸³ Refer to Work Paper Vol. 1 (Mitigation Effectiveness Comparison).

Figure IV-7
Breakdown of Historical Fault Causes (Distribution Voltage Infrastructure in HFRA from 2015-2017)⁸⁴

FAULT DATA



Distribution Voltage Infrastructure in HFRA

LEGEND
Suspected Initiating Event,
Percent Total

1 Further breakdown of the categories of Contact from Object and
2 Equipment/Facility Failure is shown in Table IV-8.

⁸⁴ Note, this figure presents data related to faults. See Figure II-3 for data associated with fires.

Table IV-8
Breakdown of Contact from Object and Equipment/Facility Failure Related Faults
(Distribution Voltage Infrastructure in HFRA from 2015-2017)⁸⁵

| Suspected Initiating Event | Count | Percentage |
|-----------------------------------|--------------|-------------------|
| Contact From Object | 895 | 32% |
| Equipment/Facility Failure | 1,354 | 48% |
| Other | 571 | 20% |
| Total | 2,819 | 100% |

| Contact From Object | Count | Percentage |
|----------------------------|--------------|-------------------|
| Animal | 250 | 9% |
| Balloons | 152 | 5% |
| Other | 48 | 2% |
| Vegetation | 238 | 8% |
| Vehicle | 207 | 7% |
| Total | 895 | 32% |

| Equipment/Facility Failure | Count | Percentage |
|-----------------------------------|--------------|-------------------|
| Capacitor Bank | 8 | 0% |
| Conductor | 145 | 5% |
| Crossarm | 39 | 1% |
| Fuse | 98 | 3% |
| Insulator | 24 | 1% |
| Other | 111 | 4% |
| Splice/Clamp/Connector | 138 | 5% |
| Transformer | 791 | 28% |
| Total | 1,354 | 48% |

1 SCE then mapped the fire ignition data, including information
2 regarding the cause of each fire (where known), to the cause codes in ODRM. This process
3 allowed SCE to connect data regarding the frequency of faults of different types to data
4 regarding the frequency of fires associated with those fault types. From this analysis, SCE
5 extrapolated the likelihood that a given type of fault could be associated with a fire ignition
6 event.

⁸⁵ Note, this table presents data related to faults. See Table III-5 for data associated with fires.

1 The results showed that contact from object faults have a higher
2 probability of being associated with a fire event: this broad category accounted for less than one-
3 third of total faults in SCE's system (32 percent) but was associated with more than one-half (53
4 percent) of the suspected wildfire initiating event types. This pointed to a potential opportunity
5 for significantly reducing wildfire risk by focusing on measures that prevent contact-related
6 faults. Vegetation-related CFO faults provides a specific example. In the 2015-2017 period, the
7 ODRM fault analysis shows that there were 2,819 faults per year on the distribution system in
8 HFRA; 238 of these, or eight percent, were identified as vegetation-related CFO faults. In that
9 same period, fire data analysis shows that there were approximately 132 fires associated with the
10 distribution system in HFRA;⁸⁶ for 22 of these, or 16.7 percent, vegetation contact was identified
11 as the suspected initiating event. Note that these numbers do not include fires that are still being
12 investigated and for which the suspected origin and cause are still undetermined. Thus, all else
13 equal, there was a relatively greater likelihood that a vegetation-related fault was ultimately
14 associated with a fire event.

15 (2) Risk Analysis: Mitigation-to-Fault Mapping

16 The next step in the risk analysis performed by SCE was a
17 mapping of specific mitigation alternatives to the types of faults that can be avoided upon
18 deployment. This analysis relied on engineering subject matter expertise to identify how much
19 of each general fault type—contact from object, equipment/facility failure, and other—would be
20 mitigated by a specific mitigation measure. It focused on three key mitigation measures: (1) re-
21 conductor with bare conductor sized to meet current design standards; (2) re-conducting
22 with covered conductor sized to meet current design standards; and (3) relocating distribution
23 lines underground. For example, all three of these mitigation measures were identified as
24 effective at mitigating the splice/connector/tap subtype of equipment failure faults. Two of these
25 three mitigation measures (covered conductor and underground conversion) were identified as

⁸⁶ This figure is approximate since some fires during this period are still under investigation.

1 effective at mitigating the vegetation-related subtype of CFO faults. Only one mitigation
2 measure (underground conversion) was identified as effective at mitigating the overhead
3 transformer subtype of equipment failure faults.

4 (3) Mitigation Effectiveness Factors and Mitigation-Cost Ratios

5 Combining the fault-to-fire mapping and the mitigation-to-fault
6 mapping yields a model of mitigation effectiveness factors for each of the three mitigation
7 measures. Based on this methodology, and on a stand-alone basis, bare conductor was calculated
8 as having a 15 percent mitigation effectiveness factor; covered conductor was calculated as
9 having a 60 percent mitigation effectiveness factor; and underground conversion was used as the
10 reference baseline for mitigation effectiveness because it removes all exposures related to
11 overhead power lines. However, it is important to note that underground conversion introduces
12 other negative impacts that are not part of this evaluation, such as much longer troubleshooting
13 and restoration time in the case of system or equipment failures.⁸⁷

14 A mitigation effectiveness factor could be interpreted as an
15 estimate of the percentage of fires avoided with full deployment of the mitigation measure
16 throughout HFRA, all else equal. Thus, full deployment of covered conductor in HFRA is
17 estimated to mitigate approximately 60 percent of fires associated with SCE's electrical
18 distribution facilities in HFRA. This analysis of mitigation effectiveness does not account for
19 potential benefits with other mitigation measures, such as fuses and automatic reclosers, which
20 also reduce the likelihood of fire ignitions. Thus the mitigation effectiveness factors are
21 appropriately considered as relative—not absolute—measures, with underground conversion
22 providing the baseline for purposes of comparison. In other words, covered conductor could be

⁸⁷ Examples of these and other negative impacts were well articulated by President Picker. *See* Statement of President Picker, Conference Committee on SB 901 Informational Hearing: Ensuring a Safe and Reliable Electric Grid (August 7, 2018), at 51:06 to 1:06:15, *available at* <https://www.senate.ca.gov/media/conference-committee-s-b-901-20180807/video>.

1 viewed as achieving 60 percent of the fire mitigation benefits of underground conversion, and
2 bare conductor would achieve 15 percent.⁸⁸

3 In addition to mitigation effectiveness, SCE also considered the
4 cost associated with each mitigation option. For bare conductor, SCE relied on its costs
5 associated with OCP, approximately \$301,000 per circuit mile. For comparison, accounting for
6 the differences in material costs for covered conductor as well as the costs of associated upgrades
7 (such as the replacement rate of poles), covered conductor is approximately \$428,000 per circuit
8 mile.⁸⁹ For underground conversion, SCE relied on its experience with projects under Rule 20A,
9 which cost approximately \$3 million per circuit mile. These costs, combined with the relative
10 mitigation effectiveness factors, allows comparison of each measure's mitigation-cost ratio, i.e.,
11 the relative mitigation effectiveness (using underground conversion as the baseline) achieved per
12 dollar spent. These results are presented below in Table IV-9:

Table IV-9
Mitigation Effectiveness-to-Cost Ratios for Covered Conductor and Alternatives

| Mitigation Option | Relative Mitigation Effectiveness Factor | Cost per Mile (\$ million) | Mitigation-Cost Ratio |
|--------------------------|---|-----------------------------------|------------------------------|
| Re-conductor – Bare | 0.15 | 0.30 | 0.50 |
| Re-conductor – Covered | 0.60 | 0.43 | 1.40 |
| Underground Conversion | 1.00 | 3.00 | 0.33 |

13 (4) Risk Analysis Conclusions

14 SCE's risk analysis shows that application of covered conductor is
15 the most prudent of the three mitigation measures. Specifically, while re-conductoring with bare

⁸⁸ It should be noted that this analysis considers all ignition causes associated with overhead equipment only. It does not factor in the additional risks (e.g., cable/equipment failure, vault explosions, longer repair outages, etc.) that would be inherited by converting to an underground system, which would offset the risk benefits attributed to undergrounding.

⁸⁹ The material cost of covered conductor is significantly more than bare wire. While the overall unit cost is also more, this difference is relatively smaller than the difference in material costs alone would suggest given that material costs account for only a small portion of the overall unit cost per mile. Refer to Work Paper Vol. 2 (Unit Cost - Covered Conductor)

1 conductor would have lower cost, and underground conversion would have greater benefit, re-
2 conductor with covered conductor has the greatest overall value. A dollar spent re-
3 conductor with covered conductor provides nearly three times as much value in wildfire risk
4 mitigation as a dollar spent re-conducting with bare conductor, and over four times as much
5 value in wildfire risk mitigation as a dollar spent on underground conversion. Moreover, by
6 deploying covered conductor in connection with other mitigation measures included in the
7 GS&RP—including installing remote-controlled automatic reclosers and circuit breakers with
8 “fast curve” settings and fusing strategy—SCE can further bridge the benefit gap between
9 covered conductor and underground conversion.

10 From these results, SCE selected covered conductor—as
11 implemented in WCCP—as a key component of SCE’s GS&RP.

12 d) Forecast

Table IV-10
2018-2020 Wildfire Covered Conductor Program Costs
(\$000)⁹⁰

⁹⁰ Refer to Work Paper Vol. 2 (Scope - Covered Conductor; Unit Cost - Covered Conductor; Forecast - Covered Conductor; Unit Cost - Tree Attachments; Forecast - Tree Attachments; Scope - Fire Resistant Poles; Forecast - Fire Resistant Poles; Capital Related Expense - WCCP; Development and Delivery - Fire Resistant Poles; Development and Delivery - Covered Conductor)


| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|------------------|------------------|-------------------|-------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Covered Conductor | 30,258 | 41,001 | 182,355 | \$ 253,614 |
| Fire Resistant Poles | - | 4,978 | 22,139 | \$ 27,117 |
| Tree Attachment Remediation | 3,678 | - | 433 | \$ 4,110 |
| Grand Total | \$ 33,936 | \$ 45,979 | \$ 204,927 | \$ 284,842 |

| O&M (2018 Constant \$000) | | | | |
|---|---------------|---------------|-----------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Capital Related Expenses | 696 | 943 | 4,201 | \$ 5,839 |
| Fire Resistant Poles Development/Delivery | 9 | 9 | - | \$ 18 |
| Covered Conductor Development/Delivery | 42 | - | - | \$ 42 |
| Grand Total | \$ 747 | \$ 951 | \$ 4,201 | \$ 5,899 |

e) Detailed Program Description


WCCP will harden SCE's overhead distribution system in HFRA by replacing certain existing bare conductor with covered conductor to reduce the fire ignition risk from contact-related faults. In implementing WCCP, SCE will use two different construction methods depending on the individual circumstances of each span. The traditional cross-arm configuration is similar to existing overhead installations of bare conductor and will account for the vast majority of the covered conductor installed under WCCP. In selected situations, SCE plans to use a spacer cable system in which covered conductor is attached to spacer hardware that is suspended from a supporting messenger line (Figure IV-8). The messenger line has high tensile strength, is attached to the pole via side-arm hardware, and supports the weight of the covered conductor at the pole and along the span. The messenger line is specifically designed to withstand the weight of a falling tree branch. Anticipated use of the spacer cable system is primarily limited to heavily forested areas and certain circuit spans in areas of dense vegetation. In particular, the spacer cable system may be used for the replacement of SCE's existing tree attachments, discussed below.

Figure IV-8
Traditional Cross-Arm and Space Cable Configurations



1 The covered conductor that SCE will use for the WCCP is shown in
2 Figure IV-9.

Figure IV-9
Components of SCE's Covered Conductor




3 The conductor shield layer is approximately 15-mil thick.⁹¹ It is made of a
4 semiconducting thermoset polymer. Its purpose is to reduce stress concentrations caused by flux
5 lines from the individual conductor strands. By encircling the strands, it effectively transforms
6 the strands into a single uniform conducting "cylinder" as the images in Figure IV-10 illustrate.
7 The reduction of electrical stress, especially if the covered conductor makes contact with another
8 object, helps preserve the integrity of the insulation and lengthen the useful service life of the

⁹¹ 1 mil = 1/1000 inch.


1 covered conductor. Figure IV-10 shows the internal conductor wire with and without the
2 conductor shield layer.

Figure IV-10
Pattern of Electrical Stress (Flux) With and Without Covered Conductor Shield

Without conductor shield:



With conductor shield:



3 The dual insulation layers are each 75-mil thick and made of cross-linked
4 polyethylene. The inner layer is a crosslinked low density polyethylene (XL-LDPE), which is an
5 insulating material. The insulation contributes to the high impulse strength of the covering,
6 protecting from phase to phase and phase to ground contact. The outer layer is a track-resistant⁹²
7 crosslinked high density polyethylene (XL-HDPE). It has the same insulating function as the
8 inner layer. But the higher density makes it a tough outer layer that is resistant to abrasion and
9 impact. Its track resistance limits the charging current that flows on its surface. Since electrical
10 tracking erodes the insulation surface over time, the track resistant properties help maintain the
11 integrity of the insulation over time. Additionally, the outer layer is specified for UV stability,
12 making it less susceptible to UV degradation. In particular, as part of the manufacturer's tests,
13 the covering is subjected to UV radiation levels equivalent to the most extreme summer weather
14 in Florida, which is equivalent to, or more extreme than, the UV intensity in Southern California.
15 SCE's past operating experience with underground cable and other covered conductor suggests

⁹² Tracking is a path connecting electrons created from charging current on the covering surface. If the charged electrons connect and flow, it can erode the insulating cover over time. Covered conductor is designed to resist tracking, i.e., to stop electrons from connecting and flowing, and thereby prevent erosion and failure of the insulation layers.

1 that failure due to cover deterioration is minimal. And SCE believes that the covering on
2 covered conductor will continue to provide partial protection beyond its service life.

3 Together, the inner and outer insulation layers of covered conductor help
4 protect the internal conductor wire and conductor shield layer from phase-to-phase and phase-to-
5 ground contact, mitigating intermittent contact-related faults. As such, covered conductor is able
6 to withstand intermittent contact with vegetation, including tree limbs and palm fronds, metallic
7 balloons, animals, other conductor wire, and the ground without faulting. SCE's analysis shows
8 that if a tree branch falls on two covered conductors with 150 mil (0.15 inch) of insulation, a
9 0.18 milliampere (mA) current will be produced, resulting in an energy level of 0.00019 Watts.⁹³
10 This very low energy is insufficient to initiate an electrical arc, compared to bare conductor.⁹⁴
11 The insulation layers of covered conductor also reduce the charging current and reduce the
12 public safety risks associated with human contact. If energized conductor wire comes down,
13 human contact results in, at most, a slight shock. For instance, tests performed at the National
14 Electric Energy Testing, Research and Applications Center (NEETRAC), Georgia Institute of
15 Technology, demonstrate that human contact with a downed covered conductor would result in
16 current below 1 mA.⁹⁵ The effect of this current level is considered "generally not
17 perceptible."⁹⁶

⁹³ Refer to Work Paper Vol. 1 (An Engineering Analysis on Impacts of Contact from Objects (CFO) on Bare vs. Covered Conductor)

⁹⁴ The energy produced when a tree limb falls on bare conductors is on the order of magnitude of tens of kW, or more than 10 million times the energy produced when a limb falls on two covered conductors. This higher energy level can heat the tree limb and potentially create a carbon-ionization pathway as the limb starts to burn, to complete a phase-to-phase fault on air in the bare conductor situation.

⁹⁵ Refer to Work Paper Vol. 1 (NETRAC Study and Associated SCE Developed Study Summary)

⁹⁶ Dept. of Health & Human Services, Centers for Disease Control & Prevention, *Electrical Safety , Safety and Health for Electrical Trades Student Manual*, (Apr. 2009), at p. 7, available at <https://www.cdc.gov/niosh/docs/2009-113/pdfs/2009-113.pdf>.

1 (1) Program Scope

2 SCE has approximately 4,500 distribution circuits in its overall
3 service area and approximately 1,300 circuits traverse HFRA.⁹⁷ WCCP will focus on certain
4 spans located in HFRA that pose the greatest risk of fire ignition on these approximately 1,300
5 circuits. As discussed in Chapter III, SCE has taken a more expansive approach regarding
6 designating portions of its service area as HFRA beyond those identified in the Commission’s
7 fire threat map, including for purposes of WCCP.

8 In this Application, SCE proposes to begin a multi-year effort that
9 SCE will subsequently include in future GRCs. SCE has identified approximately 4,000 circuit
10 miles of bare overhead conductor in HFRA best suited for re-conductoring with covered
11 conductor between 2018 and 2025 to mitigate contact-related faults and the risk of wire down
12 events during fault conditions. In this Application SCE requests to begin replacement of
13 approximately 592 circuit miles throughout 2018-2020⁹⁸. The balance of the WCCP work
14 (2021-2025) will be addressed in a future rate case. SCE has focused WCCP on only the
15 primary overhead distribution system. This is because the current standard for secondary
16 voltages requires triplex covered conductor and the secondary overhead distribution system
17 accounts for a much smaller proportion of the overall risk of fire ignition. But SCE may

⁹⁷ SCE’s distribution circuits were not designed around the portions of SCE’s service area that are considered to be HFRA. As a result, significant variation exists in each circuit’s HFRA exposure. For instance, some circuits are located entirely in a HFRA while others have only a small portion that traverses a HFRA. The below table shows HFRA circuits, grouped by quartile, based on the percentage of each circuit’s length that resides within HFRA.

| Breakdown of Circuits with Varying HFRA Exposure | | |
|--|---------------------------|-------------------------|
| Percent of Circuit Length within HFRA by Quartile | Number of Circuits | Percent of Total |
| > 75 percent | 759 | 58 |
| 50 to 75 percent | 138 | 10 |
| 25 to 50 percent | 152 | 12 |
| < 25 percent | 267 | 20 |
| TOTAL | 1316 | 100 |

⁹⁸ Refer to Work Paper Vol. 2 (Scope - Covered Conductor)

1 consider proactively replacing existing bare overhead secondary conductor with covered
2 conductor as part of future GRC requests.

3 The circuit miles, referenced above, that SCE will target for re-
4 conductoring were derived from an analysis that accounted for the risk of fire ignition for various
5 portions of HFRA circuits. Specifically, this scope falls into two main categories: (1) spans with
6 vintage small conductor at risk of damage during fault conditions and (2) spans with elevated
7 risks of vegetation-related contact from object faults.

8 First, as discussed earlier regarding the OCP, certain vintage small
9 conductor is especially vulnerable to damage during fault conditions and at risk of causing a wire
10 down event. While these individual spans do not necessarily pose a higher risk of experiencing
11 contact-related faults as compared to other spans, replacing spans of vintage small conductor in
12 HFRA with covered conductor will significantly reduce ignition risks since these spans are the
13 most susceptible to damage and burn down during fault conditions due to short circuit duty. This
14 focus also aligns with the recent change in SCE's standard to require covered conductor for re-
15 conductoring work in HFRA.

16 In the second category, there are particular circuits that have a
17 history of vegetation-related faults. In some cases, these circuits are concentrated in areas where
18 SCE has limited ability to trim trees or where there is greater likelihood that vegetation will be
19 blown into overhead equipment from trees outside of SCE's right-of-way. Indeed, SCE's
20 enhanced vegetation management practices cannot eliminate all risk of vegetation-related contact
21 faults, especially during high wind conditions, so WCCP is needed to complement SCE's
22 enhanced vegetation management practices. As a result, SCE will target circuits that had two or
23 more vegetation-related faults in the 2015-2017 period. For these circuits, WCCP will install
24 covered conductor over the full length of the portions of these circuits that reside within HFRA.

25 In addition to defining the scope of WCCP (i.e., which spans and
26 circuits are subject to re-conductorng), SCE also developed a circuit prioritization methodology

1 to guide the order in which circuits would be hardened via WCCP.⁹⁹ This approach enables SCE
2 to maximize the risk reduction benefits over time and is designed to prioritize circuits with
3 greater wildfire risk, which includes both ignition frequency as well as ignition consequence, and
4 the greatest estimated mitigation effectiveness when covered conductor is installed.

5 The risk analysis to support WCCP was a system-level analysis, in
6 other words an articulation of the overall risk benefit that could be attained by covered conductor
7 application. As discussed, to implement WCCP, SCE defined the program's scope and
8 implementation prioritization. The combination of segment targeting and circuit prioritization is
9 intended to allow SCE to approach the calculated system-level benefits as rapidly as practicable
10 via covered conductor deployment over the 2018 to 2020 period. However, the work undertaken
11 during this initial time period will not be enough to re-conductor all existing bare conductor in
12 HFRA that require replacement, only a portion the total circuit spans. Nevertheless, by re-
13 conductoring 592 circuit miles, or around six percent of the total overhead primary circuit miles
14 in HFRA, SCE will be able to reduce wildfire risk over this initial period on the highest priority
15 circuits—which is why it is critical to start this incremental work in the immediate future as
16 opposed to waiting several years until the next GRC to roll out this necessary program.

17 SCE's decisions regarding the scope of WCCP and the
18 methodology for prioritizing the HFRA circuits accurately account for both the relative risk of
19 wildfire ignition and the relative effectiveness of installing covered conductor as a wildfire risk
20 mitigation, so the most impactful projects are undertaken first and resources are effectively
21 deployed. By using a circuit prioritization methodology, SCE expects to maximize the
22 operational efficiencies of concentrating work on a circuit-by-circuit basis. SCE considered
23 other options to guide installation of covered conductor. For instance, another option would be
24 to prioritize HFRA separately and work through the list by beginning only with spans in Tier 3,
25 then moving to spans in Tier 2, and then moving to any remaining spans that SCE considers to

⁹⁹ Refer to Work Paper Vol. 1 (Circuit Deployment Prioritization).

1 be in HFRA. SCE found this alternative inferior for several reasons. First, operational
2 efficiencies would be negatively impacted by addressing only the Tier 3 spans on a given circuit
3 first and then returning to the same circuit to address Tier 2 portion of the same circuit after the
4 Tier 3 spans of other HFRA circuits.¹⁰⁰ Second, there would also be permitting inefficiencies
5 since in SCE's experience it is sometimes easier and faster to permit, for instance, ten miles on a
6 single circuit as opposed to eight miles on one and two miles on another circuit. Third, it would
7 increase the inconvenience and disturbance for individual municipalities and customers since
8 SCE would need to return to an individual circuit within a relatively short period of time to re-
9 conductor the remaining high risk Tier 2 or other HFRA spans after Tier 3 spans have been
10 addressed.

11 (2) Program Components

12 WCCP will involve more than simply replacing existing bare
13 conductor with covered conductor. Rather, SCE will simultaneously complete a number of
14 related grid hardening improvements on the relevant portions of the distribution system that go
15 hand-in-hand with re-conductoring using covered conductor. For instance, re-conductoring work
16 will include the installation of composite cross arms and wildlife protection, such as covers,
17 tubing, and covered jumper wire. Covers protect a variety of overhead equipment (transformer
18 bushings, recloser bushings, fuses, cable terminations, insulator, fuses, arrestors, etc.). When
19 appropriately applied, wildlife protection covers mitigate animal-related contact faults, as well as
20 other contact-related faults associated with vegetation and metallic balloons. In addition, for
21 dead-end poles where covered conductor is open for termination onto the cross arm, wildlife
22 protection covers will also help protect these areas of exposed conductor.

23 Two specific upgrades associated with WCCP are discussed in
24 more detail below: poles and tree attachments.

¹⁰⁰ For example, given a hypothetical circuit of ten miles in length, a portion of the circuit, say eight miles, is in the Tier 3 area, with the remaining two miles in the Tier 2 area.

1 (a) Poles

2 WCCP will require pole upgrades in certain circumstances.

3 Since there are material weight and wind load differences between bare conductor and covered
4 conductor, implementing WCCP will require SCE to determine that existing poles are able to
5 support this extra weight and wind loading. As part of this re-conductoring work, SCE will
6 conduct a pole loading assessment on existing poles where covered conductor is to be installed to
7 determine if pole replacement is required. If the pole loading analysis shows that minimum
8 safety factors would not be met by installing covered conductor, SCE will also install new poles
9 able to support covered conductor. The primary driver for pole replacement rates is attributed to
10 larger conductor diameters that increase the wind forces that are transmitted from the conductor
11 to the pole. Additionally, when appropriate, pole replacements as part of WCCP will use fire
12 resistant composite poles with a fire protective shield.

13 SCE's Pole Loading Program (PLP) was adopted in the
14 2015 GRC as a comprehensive way to address pole overloading issues. The objective of the PLP
15 is to assess SCE's poles to identify and repair or replace those poles that do not meet G.O. 95
16 minimum safety factors. In combination with SCE's other infrastructure replacement programs,
17 SCE has replaced approximately 54,000 poles in HFRA since the inception of PLP.

18 As a result of PLP, SCE anticipates that a majority of the
19 recently replaced poles in HFRA will pass a pole loading assessment and will not require
20 replacement as part of WCCP. However, SCE will need to replace some poles. SCE anticipates
21 that there will be two primary categories of poles needing replacement: (1) poles that were not
22 designed for 1/0 ACSR (Aluminum Conductor Steel Reinforced) (i.e., primarily pre-2014 poles)
23 and (2) poles designed for 1/0 ACSR that nevertheless require replacement (i.e., primarily poles
24 subject to particularly high winds).

25 SCE analyzed a statistically valid random sample of
26 existing poles in HFRA to estimate the percentage of poles of each type that will need replacing

1 as part of WCCP.¹⁰¹ This analysis found that approximately 24 percent of the population of
2 existing poles in HFRA are not capable of carrying increased load associated with 1/0 ACSR
3 covered conductor wire and will require replacement. The specific poles that require
4 replacement will disproportionately be those with higher wind loading conditions. This
5 replacement rate is higher than the expected 13 percent replacement rate for these poles if SCE
6 were to install 1/0 ACSR bare conductor wire to meet SCE's current standard, such as for work
7 under OCP.


8 SCE's analysis also showed that the anticipated
9 replacement rate for poles in HFRA designed for 1/0 ACSR will be significantly lower. These
10 poles were designed for SCE's current standard for bare wire conductor (1/0 ACSR) and have
11 already accounted for new installation safety factors. As a result, for the approximately 54,000
12 recently-replaced (i.e., since 2014) poles in HFRA, SCE anticipates replacement rate of less than
13 3 percent for the subset of those poles that are subject to the re-conductoring work under WCCP.

14 At locations where SCE is installing covered conductor in
15 HFRA and pole replacements are required, SCE will use fire-resistant composite poles, where
16 appropriate, instead of traditional wood poles. These poles are specifically designed to withstand
17 wildfires, which will harden the distribution system and reduce the risk of a wire down event.
18 SCE plans to use fire-resistant composite poles with a fire shield, as shown in Figure IV-11.
19 SCE has experience with similar composite poles, including the sectional composite pole without
20 a fire shield.¹⁰² Compared to steel poles, composite poles are non-conductive and resistant to
21 corrosion. And compared to wood poles, composite poles are less susceptible to wildlife damage
22 (e.g., woodpeckers), rotting, and fires, and are also lighter in weight and have the capacity to
23 carry more load (when compared to wood poles of the same class and size). In general,

¹⁰¹ Refer to Work Paper Vol. 1 (Pole Replacement Rate).

¹⁰² For instance, SCE currently has over 5,000 composite poles in service as part of its distribution system. These composite poles are primarily used in areas where wood poles are prone to damage from woodpeckers, areas of environmental or other archeological conditions, and in rear property lines without truck access.

Figure IV-11
Diagram of Composite Pole with Fire Shield



(b) Tree Attachments

As part of WCCP, SCE also will install new poles in order to eliminate instances where existing electrical equipment, including overhead conductor, is attached to trees. Approximately 114 tree attachments will be replaced as part of WCCP in the

1 terms of wildfire mitigation effectiveness and cost. But insulating retrofit conductor wrap was
2 rejected due to its limited application, cost, and potential for failure.¹⁰⁷

3 Additionally, as an alternative option for covered conductor
4 deployment, SCE also considered the possibility of installing covered conductor on only one or
5 two of the three phases on SCE's overhead distribution system. This partial installation of
6 covered conductor was rejected because it is less effective at mitigating faults, can lead to
7 potential issues associated with using bare and covered conductor on a single span, and is
8 inconsistent with the prudent practices of utilities in other jurisdictions.

9 f) Deployment Time

10 SCE has already begun to install covered conductor on portions of ten
11 circuits in HFRAs. SCE's GS&RP plans to move forward with the re-conductoring work under
12 WCCP that is part of this Application at an accelerated pace through the rest of 2018, 2019 and
13 2020. As shown in Table IV-11, the work will cover 71 circuit miles in 2018, 96 circuit miles in
14 2019, and 426 circuit miles in 2020. At this rate, SCE anticipates installing 592 circuit miles of
15 covered conductor under WCCP by the end of 2020.

Table IV-11
WCCP Deployment 2018-2020

| Category (Circuit Miles) | 2018 | 2019 | 2020 | Total |
|---|------|------|------|-------|
| Short Circuit Duty: Vintage Small Conductor | - | 44 | 157 | 201 |
| Contact From Object | 71 | 52 | 269 | 391 |
| Total | 71 | 96 | 426 | 592 |

16 While this timeline is ambitious and accelerated, it is operationally
17 feasible for SCE to ramp up and complete this target in addition to its other related activities.
18 Indeed, one purpose of creating the PMO was to consolidate SCE's grid hardening projects to

¹⁰⁷ The manufacturer of the silicone rubber conductor wrap recommends application where protection of less than 20 feet is required, making it unsuitable for most applications. In field tests, it also proved difficult to install and presented the possibility of failure if the wrap were to come off over time or during high wind conditions. The high-density polyethylene/co-poly conductor cover is significantly more expensive than covered conductor (approximately \$5.75 per foot as compared to \$0.80 per foot) and requires the same ancillary upgrades to the other components of the distribution system, such as poles, due to added weight.

1 enable more streamlined and expeditious deployment. As part of this effort, SCE carefully
2 considered how quickly it could move forward with WCCP, and this timeline represents a
3 prudent approach given the importance of grid hardening activities, specifically covered
4 conductor.

5 g) Benefits

6 In general, WCCP is intended to mitigate wildfire risk by addressing the
7 drivers of wildfire ignitions associated with the electric power lines. Therefore, the most
8 effective way to measure the benefits of the program is to directly measure frequency of wildfire
9 drivers and frequency of wildfire triggering events within HFRA. Faults (tracked in ODRM) and
10 wildfire ignition events (tracked in SCE’s annual report to the CPUC) can be directly measured
11 after covered conductor deployment to measure effectiveness. As a result of WCCP, the number
12 of faults leading to ignition events—and, by extension, the risks associated with wildfires—
13 would be expected to decrease in a meaningful and measurable way over time.

14 **2. Remote-Controlled Automatic Reclosers (RARs) And Fast Curve Settings**

15 a) Program Overview

16 SCE intends to install 98 additional RARs¹⁰⁸ on its HFRA circuits for
17 increased circuit protection and reliability. The RARs will be used to provide faster or more
18 selective “fault clearing” to further reduce fire ignition risks and lessen service interruptions for
19 SCE customers. These assets will assist SCE in four important ways:

- 20 **1. Fault Interruptions** - the RARs will be applied to automatically
21 interrupt faults on HFRA circuits, limiting the amount of customers
22 affected by faults and sectionalizing faulted circuits to smaller
23 portions;
- 24 **2. Fast Curve Operating Settings** - during Red Flag Warnings, the
25 RARs will be remotely configured to operate with “Fast Curve

¹⁰⁸ Refer to Work Paper Vol. 2 (Scope - New RARs)

Settings,”¹⁰⁹ thereby isolating many faults faster, limiting total energy delivered to these faults, and reducing ignition risks;

3. **Reclose Relay Blocking** - RARs will permit SCE to remotely block reclosing to SCE’s HFRA during Red Flag Warnings while permitting reclosing to non-HFRA, thus enable a lesser degree of outage and public impact in the event of a fault; and

4. **Public Safety Power Shutoff (PSPS)** - as a mitigation of last resort, if SCE must proactively de-energize circuitry due to extreme fire conditions, SCE will be able to utilizing these additional RARs in order to further limit the number of customers impacted.

Having additional RARs will also provide the much needed operational flexibility to reconfigure circuits quickly during extreme fire conditions.

In addition to the installation of the new RARs, SCE will be updating the relay and/or settings on approximately 300 existing RARs and 764 Circuit Breakers (CBs) with Fast Curve operating settings.

b) What Exists Today

SCE currently has approximately 930 RARs installed on 520 circuits in HFRA. These RARs provide the traditional benefits of fault interruption and sectionalizing circuits to smaller portions. However, there are locations in HFRA that do not presently have RARs installed, but where additional RARs could provide more benefits in alignment with the four key benefits outlined above.

SCE has also been reconfiguring relay settings on existing RARs and CBs with Fast Curve configurations to allow for increased fault clearing speeds and fault energy reduction during Red Flag Warning events. Approximately 630 of the 930 existing RARs in

¹⁰⁹ Fast Curve Setting modifies the relay fault detection curve providing faster fault detection and interruption. Once the updated settings are installed, the Fast Curve can be remotely activated or de-activated through SCE’s monitoring and control radio network. This is described in the Detailed Program Description section below.


1 HFRA have already been upgraded with Fast Curve configurations, with 300 remaining to be
2 updated. Approximately 400 existing relay settings on CBs have already been updated with Fast
3 Curve operating capabilities thus far this year, with 764 remaining to be updated.

4 c) Effectiveness

5 These additional RARs will provide additional isolation points with fault
6 interrupting capabilities, reclose relay blocking practices during Red Flag Warnings, and assist in
7 implementation of PSPS and Fast Curve settings. In particular, SCE's PSPS protocols will
8 benefit from additional RARs in that less customers will be impacted if SCE is able to de-
9 energize only a smaller portion of a circuit utilizing RARs. Additionally, SCE has revised its
10 policies and procedures to require Fast Curve settings during Red Flag Warnings to isolate most
11 faults faster, thus limiting total energy delivered to these faults and reducing ignition risk. The
12 new RARs will have such settings already configured.

13 In many cases, the RAR installation aligns with the HFRA boundary;
14 however, SCE has also identified circuit sections beyond HFRA boundaries which would benefit
15 from an additional RAR. The simplified circuit diagram in Figure IV-13 illustrates RAR
16 installations both aligned with the HFRA boundary and beyond the HFRA boundary. RARs
17 provide the ability to remotely de-energize portions of circuits for a PSPS event.

Figure IV-13
Illustration of RARs Relative to HFRA Boundaries



d) Forecast

As noted above, SCE has been reconfiguring existing relay settings on RARs and CBs with Fast Curve configurations. In this Application, SCE is only seeking to recover future costs incurred. SCE’s goal is to have all new and existing relay settings for RARs and CBs configured with these settings by 2020 to help mitigate fire ignition risks during Red Flag Warnings and enhance its PSPS protocol.

Table IV-12 below summarizes the forecast incremental costs in SCE’s request. For capital items, the “New RARs” line item pertains to the 98 additional RARs that SCE intends to install.¹¹⁰ The CB Relay Hardware for Fast Curve line item refers to additional hardware upgrades for 378 CBs, which will include Fast Curve settings for these devices. For O&M items, the RAR and CB Relay Fast Curve Settings line item consist of updating settings for 300 RARs and 386 CB relays. The line items pertaining to development/delivery relate to training activities to support both the new hardware installation and changes to device settings.

¹¹⁰ SCE performed an engineering study to determine the need for 73 additional RARs. Additionally, SCE anticipates the need for an additional 25 RARs to lessen the impact of potential PSPS outages, especially taking into consideration input from fire agencies, offices of emergency management, and other emergency response entities (See Section IV.D.2).

Table IV-12
2018-2020 Remote-Controlled Automatic Reclosers (RARs) and Fast Curve Setting
Costs¹¹¹

| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|-------------|-----------------|------------------|------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| New RARs | - | - | 9,287 | \$ 9,287 |
| CB Relay Hardware for Fast Curve | - | 8,789 | 8,789 | \$ 17,577 |
| Grand Total | \$ - | \$ 8,789 | \$ 18,076 | \$ 26,864 |

| O&M (2018 Constant \$000) | | | | |
|--|---------------|---------------|---------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| RAR and CB Relay Fast Curve Settings | 777 | 277 | - | \$ 1,054 |
| Capital Related Expenses | - | 180 | 371 | \$ 551 |
| New RARs Development/Delivery | 19 | - | - | \$ 19 |
| RAR/Relay Fast Curve Settings Development/Delivery | 49 | - | - | \$ 49 |
| Grand Total | \$ 845 | \$ 457 | \$ 371 | \$ 1,673 |

e) Detailed Program Description


(1) RAR Configurations and Installations

The installation of RARs include switches to provide the capability to bypass and electrically isolate the recloser (see Figure IV-14). A three-phase gang operated switch provides the means for bypassing the RAR during maintenance. The bypass switch can also be operated closed to maintain the power flow in the event the RAR is faulted and/or needs to be bypassed. Line side and load side single phase disconnect switches are installed to provide means to disconnect and isolate the RAR during maintenance. The disconnect switches also provide means for isolating an RAR due to a failure or for replacement. When working on a distribution line beyond an RAR where the line is required to be de-energized, the disconnect switch is used to keep the line section de-energized as part of clearance requirements for safe-working practices.

¹¹¹ Refer to Work Paper Vol. 2 (Scope - New RARs; Forecast - New RARs; Unit Cost - CB Relay Hardware for Fast Curve; Forecast - CB Relay Hardware for Fast Curve; Forecast - Fast Curve Settings for RARs and Circuit Breakers; Capital Related Expense - Remote-Control Automatic Reclosers; Development and Delivery - Fast Curve Settings for RARs and Circuit Breakers; Development and Delivery - New RARs)

1 this figure, faults at branch line “Location 1” and faults at mainline “Location 2” would be
2 cleared by the substation CB, the closest upstream protective device to these locations. Faults at
3 mainline “Location 3” would be cleared by the AR, and faults at branch line “Location 4” would
4 be cleared by the BLF.

Figure IV-15
Illustration of Protection Coordination



5 As part of device coordination during normal operating conditions,
6 SCE believes that RARs will provide faster fault isolation than source CBs which will provide
7 improvements in service reliability by reducing the number of customers experiencing outages.
8 Compared to CBs, the anticipated faster fault isolation and improved sensitivity of RARs offer a
9 benefit for reducing fault energy for faults on their downstream circuitry. The related energy
10 reduction during a fault also provides a benefit by decreasing fire risks. Reliability is further
11 improved by the reclosing capabilities of RARs which can remotely and automatically restore
12 electric service following temporary faulted conditions.

13 Because SCE intends to change operating settings for CBs and
14 RARs during red flag events as discussed below, it is important to distinguish the normal fault
15 interrupting operating conditions and automatic reclosing during most of the year, with the
16 operating performance expectations for fault interruption and automatic reclosing during red flag
17 conditions. The following two sections describe the expected benefits and drawbacks when

1 modifying the operating strategies during Red Flag Warning conditions and explain the
2 additional installation placement criteria related to such operating practices.

3 (3) Fast Curve Operating Settings

4 During Red Flag Warning conditions, the Fast Curve settings will
5 be remotely enabled by SCE's Distribution Control Center operators, resulting in typical faults
6 being cleared more quickly.¹¹² These settings can be toggled remotely when Red Flag Warnings
7 occur. Fast Curve settings reduce fault energy by increasing the speed with which a relay reacts
8 to most fault currents. Compared to conventional settings, reduced fault durations anticipated
9 with Fast Curve operating settings are expected to reduce heating, arcing, and sparking for many
10 faults. The Fast Curve reduction in fault energy is dependent on the fault magnitude and existing
11 settings; as a general estimate, the configuration is expected to result in a 50 percent reduction in
12 fault energy.

13 Though SCE has not found published articles directly correlating
14 the reduction in fire ignitions to reduction in fault energy, SCE believes such reduction will
15 occur given the science involved. The explanation of the expected benefits of operating with
16 Fast Curve settings is simplistic; however, there are a variety of electric service impacts of
17 applying these operating settings to CBs and RARs due to changes in the way SCE must operate
18 the electric system. Coordination of downstream overcurrent devices and either the CB or RAR
19 with Fast Curve setting is impacted.

20 Device coordination in response to faults is the primary operational
21 impact of Fast Curve settings. Faster operation of CBs and RARs may not allow time for fuses
22 to operate. Coordination between CBs and RARs with Fast Curve is also impacted, though SCE
23 expects some selective coordination between these devices. With the faster interruption of faults
24 and associated impacts to coordination of devices, SCE expects an increase to the System

¹¹² SCE is currently exploring the application of Fast Curve settings for sub-transmission lines within HFRA. Incremental costs associated with line patrols following device operations when Fast Curve settings are enabled may be recorded to the GS&RPMA.

1 Average Interruption Duration Index (SAIDI) of 1.45-1.95 minutes annually, depending on
2 whether or not the RAR will coordinate with the CB Fast Curve during red flag conditions. The
3 fusing mitigation detailed in the below section, and specifically the use of current limiting fuses
4 helps to minimize impacts to customer electric service reliability from Fast Curve operating
5 settings.

6 The additional RAR installations will assist in reducing the impact
7 of the mentioned device coordination and associated electric service interruptions which are
8 created by implementation of the Fast Curve at the CB. The RAR installations further improve
9 the sensitivity of fault detection by allowing lower magnitude fault current thresholds to be
10 detected, significantly reducing these fault energy levels.

11 (4) Public Safety Power Shutoff

12 When facing dangerous fire conditions, CBs at the substation and
13 RARs are expected to be the primary switching devices should SCE initiate proactive de-
14 energizing of circuitry under the PSPS protocol. As the Commission recognized in approving
15 Resolution ESRB-8, “de-energizing electric facilities during dangerous conditions can save lives
16 and property and can prevent wildfires.” By placing RARs at the boundaries of SCE’s HFRA,
17 and also within critical HFRA regions, when SCE de-energizes for public safety, it will only de-
18 energize a portion of the circuit that is located within the HFRA as opposed to de-energizing the
19 entire circuit. As a result, there will be less impact to customers due to the reduced amount of
20 customers de-energized.

21 The functionality of a CB and RAR on the distribution system are
22 similar in that they interrupt faults, are used to sectionalize circuits, and can be remotely
23 operated. RARs are typically mounted on poles; however, SCE also has standard pad-mounted
24 designs and substation rack mounting provisions for RARs. CBs are typically in the confines of
25 the substation fence and installed on a concrete pad with a supportive metal frame that maintains
26 safe electrical clearances of the energized parts. CBs in general have higher ratings and different
27 operating parameters given their application at the substation. For example, typical CB

1 minimum trip levels are expected to be higher than those of an RAR for proper coordination.

2 The substation is generally referred to as the source location of a circuit; thus, the CB is applied
3 at the source.

4 SCE intends to utilize PSPS for particularly high risk segments of
5 circuits. The use of CBs to de-energize will impact all the customers on a circuit because the CB
6 is located at the source of the circuit. RAR additions for PSPS may aid in confining the outage
7 impacts related to a PSPS event as opposed to the CB.

8 (5) Recloser Relay Blocking

9 During Red Flag Warnings, SCE will utilize the RARs to remotely
10 block relay reclosing to HFRA. This is critical for SCE to be able to target its mitigation efforts
11 specific to HFRA. Under normal circumstances, SCE automatically recloses its circuits after
12 they are de-energized from a fault interruption, commonly referred to as a trip operation or relay
13 event. Automatic reclosing is used to allow electric service to be restored quickly following a
14 fault which is momentary or temporary. Many electric distribution system faults are temporary,
15 such as from wind blowing a branch into a line or an animal-caused short circuit. Analyzing the
16 past three years of outage events associated with RARs, SCE shows the applications of RARs
17 average an approximate 50/50 split between faults that produced momentary versus sustained
18 outages.

19 Momentary faults are commonly cleared by CBs or RARs and
20 then, following a brief de-energized period (15-30 seconds), the reclosing relay requests a test of
21 the line (closing CBs or RARs attempting to energize the circuit) to see if the fault has cleared.
22 During Red Flag Warning conditions, SCEs Distribution Control Center remotely blocks the
23 automatic reclosing relay for CBs and RARs within its HFRA. For these circuits, the reclosing
24 relay is disabled and following a fault, the circuit remains de-energized until a patrol is
25 performed to inspect for sources of the fault. Following a patrol, the circuit may then be
26 energized, restoring electric service.

1 Without the use of RARs, SCE would have to block relay reclosing
2 at the CB located at the substation. Thus, when a fault occurs, the entire circuit (even portions of
3 the circuit not located in the HFRA) would be de-energized.

4 Also, the RAR's capability to automatically sectionalize only a
5 portion of the circuit (as opposed to the entire circuit such as with a CB) indicates that a fault
6 originated beyond the RAR and improves the troubleshooting process to search for the fault
7 location(s) and cause(s).

8 f) Alternatives

9 (1) Use Remote Controlled Switches (RCS) instead of RARs

10 Remote Controlled Switches permit circuit sectionalizing with
11 remote and local operation capabilities. However, these switches are not equipped with fault
12 interrupting capabilities; therefore, RCSs cannot be configured with Fast Curve operating modes
13 to aid in fault energy reduction. Overhead RCS devices (pole switches fitted with motor
14 operators) produce hot gasses and sparks when operated while energized. In contrast, an RAR
15 does not produce external sparks or hot gasses. Thus, SCE recommends installing RARs as
16 opposed to switches to minimize fire ignition risks. The fault interrupting capability of RARs
17 further aids in electric service restoration by providing information on the fault location which is
18 not available from an RCS.

19 (2) Install RARs widely across HFRA circuits maximizing reliability
20 and fault energy reduction

21 Currently, an average of 1.79 RARs per circuit exist on
22 approximately 47 percent of circuits identified in HFRA. Application of 1-2 RARs on a circuit
23 can likely still be coordinated with existing relay settings for CBs. A higher quantity of RARs
24 can be applied to further improve reliability, allowing greater circuit sectionalizing. The
25 additional benefit of energy reduction is expected as described above, in that a given fault will
26 generally be isolated faster by an RAR than a CB. Using the average quantity of RARs on a
27 circuit today, the remaining 53 percent of HFRA circuits which do not contain RARs

1 (approximately 583) would result in an increase of 1,040 installations at a cost of \$104,000,000.
2 This approach would essentially double the SCE installations of RARs in HFRA, help improve
3 electric service reliability, and may result in a reduction of fire ignitions related to electrical
4 facilities. But the additional expense may yield limited overall reliability gains as HFRA circuits
5 are generally less densely populated compared with circuits in non-HFRA. Thus, SCE believes
6 the proposed targeted approach of deploying only a limited number of new RAR installations,
7 along with other program proposals such as the Branch Line Fusing program used to maximize
8 benefits of the four critical areas (PSPS, Fault Interruptions, Fast Curve Operating Settings, and
9 Recloser Relay Blocking) is the most prudent approach for public safety and electric service
10 reliability.

11 **3. Fusing Mitigation**

12 a) Program Overview

13 SCE proposes to install fusing at 8,855 new Branch Line Fuse¹¹³ (BLF)
14 locations and replace fuses at up to 6,758 existing BLF locations on circuits which traverse the
15 HFRA.¹¹⁴ This accounts for all 15,613 radial branches located within SCEs HFRA. In addition,
16 SCE proposes to install 21 Substation-Class Electronically Controlled Fuses on these same
17 circuits.¹¹⁵

18 This fusing program is intended to reduce the risk of fire ignitions
19 associated with SCE's distribution lines and equipment by reducing fault energy. SCE has
20 traditionally used conventional expulsion type fuses (conventional fuses) for BLF applications.
21 For this program, SCE intends to utilize Current Limiting Fuses (CLFs) for most applications in
22 the HFRA. In rare instances, fault current levels and device coordination may require the

¹¹³ SCE uses the term "Branch Line Fuse" to refer to a set of fuses applied between main line circuitry and a lateral and can consist of two or three fuses, depending on the application.

¹¹⁴ Refer to Work Paper Vol. 2 (Scope - Current Limiting Fuses)

¹¹⁵ Refer to Work Paper Vol. 2 (Forecast - Substation Class Electronically Controlled Fuses)

1 application of conventional fuses or Branch Line Reclosers (BLRs)¹¹⁶ as opposed to CLFs.
2 CLFs are selected for this application because they can provide faster fault clearing for most
3 faults and a reduction in fault energy,¹¹⁷ compared to a conventional fuse.¹¹⁸ In addition to the
4 fault energy reduction, the placement of BLFs is expected to improve electric circuit reliability
5 by segmenting faulted circuits to smaller line sections.

6 Historically, SCE has not utilized Substation-Class Electronically
7 Controlled Fuses, but now intends to use these advanced fuses in the HFRA as a program study.
8 Substation-Class Electronically Controlled Fuses offer similar fault energy reduction benefits as
9 CLFs but allow for significantly more loading.¹¹⁹ This enables these devices to be used on the
10 mainline portions of SCE's circuits as opposed to the branch lines with conventional distribution
11 class CLFs. Again, the goal is to reduce fault energy on SCE circuits and thus, lower the risk of
12 possible ignition when a fault occurs.

13 b) What Exists Today

14 SCE has traditionally applied BLFs to improve electric service reliability
15 by limiting the number of customers affected by a fault as opposed to upstream RARs. This
16 practice has resulted in BLF applications on approximately 43 percent of the HFRA-related
17 branch circuits. The simplified circuit diagram in Figure IV-16 below illustrates branch circuitry
18 both with and without installed BLFs within the HFRA boundary.


¹¹⁶ SCE uses the term "Branch Line Recloser" to refer to a set of single phase reclosers applied between main line circuitry and a lateral and can consist of two or three reclosers, depending on the application.

¹¹⁷ Various vendor and industry documentation suggest the CLF energy reduction is typically up to twenty-five (25) times compared to a conventional fuse for high magnitude fault currents.

¹¹⁸ Refer to Work Paper Vol. 1 (IEEE Fusing Support).

¹¹⁹ SCE is investing the use of Substation-Class Electronically Controlled Fuses and CLFs cannot be applied to main line circuits and RARs cannot provide current limiting capabilities due to rating limitations.

Figure IV-16
Illustration of Fused and Unfused Branch Lines



c) Effectiveness

De-energizing branch lines that experience faults due to vegetation contact, animal contact, or contact with other objects, is critical to mitigating fire ignition risk. In addition, the ability to limit the amount of energy associated with a fault is expected to further minimize the ignition potential. Given that SCE’s HFRA circuits have 8,855 un-fused branch lines, a substantial reduction in high fault energy events can be realized with CLF applications for these locations. Furthermore, replacement of conventional BLFs with CLFs can further aid in reducing fault energy on branch circuits.

SCE has evaluated various fusing technology and interrupting devices that had the potential to further reduce the risk of ignitions in HFRA. In evaluating the various options, SCE took into consideration energy reduction capabilities, maintenance requirements, and cost. SCE’s proposed fusing approach allows for rapid deployment across all of SCE’s HFRA distribution circuits with relatively minimal costs to alternate strategies. Specifically, the BLFs work in conjunction with other SCE mitigation programs such as Fast Curve operating settings, recloser relay blocking, and covered conductor.

SCE intends to use CLFs as opposed to conventional fuses for BLF applications in HRFAs, as CLFs not only provide higher reduction in fault energy for high current faults compared to conventional fusing, but the CLF design minimizes the release of materials and gases during operation. SCE may use conventional fuses as an alternative application when CLFs offer no advantages in terms of energy reduction and where the conventional fuse can provide comparable coordination benefits.

d) Forecast

Table IV-13 below summarizes the forecast incremental costs in SCE's request for Fusing Mitigation.

Table IV-13
2018-2020 Fusing Mitigation Costs¹²⁰

| Capital (2018 Constant \$000) | | | | |
|--|------------------|------------------|-----------------|------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Current Limiting Fuses | 11,923 | 44,779 | 5,962 | \$ 62,664 |
| Substation Class Electronically Controlled Fuses | - | 170 | 3,401 | \$ 3,571 |
| Grand Total | \$ 11,923 | \$ 44,949 | \$ 9,362 | \$ 66,235 |

| O&M (2018 Constant \$000) | | | | |
|--|---------------|-----------------|------------------|------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Current Limiting Fuses | - | 1,710 | 20,946 | \$ 22,656 |
| Capital Related Expenses | 244 | 921 | 192 | \$ 1,358 |
| Substation Class Fuse Development/Delivery | 26 | 9 | - | \$ 35 |
| Grand Total | \$ 271 | \$ 2,640 | \$ 21,138 | \$ 24,049 |

e) Detailed Program Description

CLFs will be added to distribution circuit branch lines in HFRA which are not presently fused, or that may benefit from further segmentation via additional fuse installations. In addition, SCE will replace certain conventional fuses with CLFs to further minimize ignition risk. Two general groups of fuse replacements are expected to be part of the

¹²⁰ Refer to Work Paper Vol. 2 (Scope - Current Limiting Fuses; Unit Cost - Current Limiting Fuses; Forecast - Current Limiting Fuses (O&M); Unit Cost - Substation Class Electronically Controlled Fuses; Forecast - Substation Class Electronically Controlled Fuses; Capital Related Expense - Current Limiting Fuses; Development and Delivery - Substation Class Electronically Controlled Fuses; Forecast - Current Limiting Fuses (Capital))

1 program. The first group of existing fuses for replacement includes expulsion fuses which
2 require brush clearing at the base of the pole to remove potentially flammable vegetation per the
3 CalFire Power Line Fire Prevention Field Guide. The second group of fuse replacements include
4 locations that would benefit from the current limiting technology for energy reduction, but would
5 otherwise be exempt from brush clearing per CalFire Power Line Fire Prevention Field Guide.
6 SCE does not intend to replace existing conventional fuses with CLFs where the fault energy is
7 not reduced by the replacement or where there is no risk of materials released during fuse
8 operation.¹²¹


9 Conventional industry practice as well as SCE historical use for branch
10 line protection devices have primarily focused on coordinating protective devices to maximize
11 electric service reliability. To address the new heightened wildfire risk, SCE's GS&RP proposal
12 for branch line protection specific to HFRA circuits place an additional emphasis on limiting
13 fault energy, while maintaining protective device coordination as a secondary measure.¹²² This
14 approach is expected to also result in improvements to electric service reliability by further
15 segmenting the circuit by isolating only the smallest section of the circuit impacted by the fault.
16 The 8,855 BLF locations are expected to provide approximately a two-minute reduction to
17 SCE's SAIDI reliability metrics.¹²³ Figure IV-17 represents the energy reduction (i.e., peak
18 current and fault duration) comparison between current limiting fuses vs. conventional fuses.

¹²¹ SCE may install a limited number of conventional fuses where loading levels require use of conventional devices or where CLFs offer no advantages in terms of energy reduction and the conventional fuse can provide a coordination benefit. BLR devices may be selected instead of CLFs for longer heavily loaded branch circuits.

¹²² "Coordination" in this context refers to the application of the fuse-blowing strategy whereby operational sequence of multiple protective devices on the same circuit in such a way to always isolate the smallest portion of the circuit with minimum number of customers to clear the fault first, yet preserve the backup protective function of devices further upstream of the circuit should the initial protective device failure to operate. See also Section IV.B.2.e)(2).

¹²³ While SCE believes that replacing existing conventional fuses with CLFs will improve overall SAIDI, it acknowledges that outages caused by a transformer failure may have slightly greater customer impacts due to possible fuse mis-coordination.

Figure IV-17
Energy Let Through Comparison of Current Limiting Fuse vs. Conventional Fuse



1 The majority of SCE’s branch lines within the HFRA do not currently
2 have fuses installed. The reduction in fault energy and increased sectionalizing provided with
3 the installation of fuses is expected to reduce the risk of fire ignitions caused by the following
4 events:

- 5 1. Arcing/sparking at a fault location (e.g., equipment failure) in which
- 6 hot-sparking material can fall to the ground;
- 7 2. Conductor and conductor supporting components (e.g., dead end,
- 8 insulator, splice) melting at a fault location or another location; and
- 9 3. Upstream CBs or RARs reclosing into faulted circuits.

10 Branch lines equipped with CLFs also help to avoid potential fire ignitions
11 at the base of the pole related to the release of materials and gases during the operation of a
12 conventional fuse. During operation, the conventional fuse visibly releases materials and gases
13 while the CLF does not.

14 SCE also seeks to apply Substation-Class Electronically Controlled Fuses
15 to provide mainline circuitry with fault energy reduction similar to SCE’s approach on smaller
16 branch circuits. These devices are significantly more complex than conventional fuses or CLFs

1 and require adjoining electronics to operate the fuse for a fault event; however, these electronics
2 allow SCE to selectively activate the increased energy reduction capability during high risk
3 situations, such as during Red Flag Warnings. Further product development is needed to analyze
4 and allow execution of this equipment throughout SCE's HFRA. A single trial installation is
5 planned for 2019 so that SCE can evaluate its use, as SCE intends on installing Substation-Class
6 Electronically Controlled Fuses at an additional twenty locations in 2020.

7 f) Alternatives

8 Branch Line Reclosers: Branch line reclosers are available in single and
9 three phase configurations. The latest designs utilize vacuum interrupter technology for
10 improved fault interruption performance. They offer similar fault energy reduction as
11 conventional fuses and, similar to CLFs, do not release materials or gases during interruption.
12 Due to their automatic reclosing feature, SCE requires remote control capability to block
13 reclosing during red flag conditions for HFRA; however this capability is not currently available
14 from all equipment suppliers. The application of BLRs is further limited compared to fusing by
15 their reduced interrupting ratings. Additionally, the unit cost for BLR installations is
16 significantly greater material costs for BLR installations. Most important, BLRs do not provide
17 the same level of fault energy reduction as CLFs for high current faults. Therefore, due to higher
18 cost and lessened fault energy reduction benefits, this device is not recommended for mass scale
19 deployment. Instead, SCE will apply this technology in specific situations when appropriate.

20 Conventional Fusing: Conventional fusing was considered as an
21 alternative to CLFs. Installation costs are similar for conventional fuses though CLF materials
22 are twice the cost. Conventional fuses offer the ability for increased branch loading for a given
23 fuse size and slightly faster operation at the lower fault current levels which helps with device
24 coordination as discussed earlier in the fuses section. CLFs, on the other hand, offer substantial
25 energy reductions for the expected higher fault currents. CLFs further mitigate concerns with
26 potential fire ignitions related to materials and gasses released during the operation of a
27 conventional fuse. Given the reduction in fault energy and the lower risk of potential fire

1 ignitions, SCE intends to deploy the vast majority of fusing utilizing CLFs. However,
2 conventional fuses may be used where circuit loading or other factors may preclude the use of
3 CLFs.

4 SCE's selected approach allows for rapid deployment across HFRA with
5 relatively minimal expense and works in conjunction with other programs such as covered
6 conductor, recloser relay blocking, and RAR Fast Curve operating settings. The other
7 alternatives discussed above do not have these advantages. Given the uncertainty of future fault
8 locations on the distribution system, 8,855 additional BLF installations along with the 6,758
9 BLFs help to mitigate the consequence of fault events. SCE is prioritizing the installation of the
10 BLFs at unfused branches followed by replacement of existing BLF locations.

11 **C. Enhanced Situational Awareness**

12 Below, SCE discusses enhancements to its situational awareness capabilities. Situational
13 awareness is an integral part of emergency management, as it is imperative SCE has a granular
14 understanding of what is happening across its service area prior to, and during, emergency
15 events. SCE has already made significant enhancements in this area over the last few years.
16 Today, SCE has a Watch Office that monitors activities on a 24/7 basis, notifying response teams
17 when action is needed, and updating SCE's management on evolving events. The Watch Office
18 is co-located within the Emergency Operations Center (EOC), which was recently upgraded in
19 2016¹²⁴ and also serves as the training center for Incident Management Teams. SCE also has
20 meteorologists on staff, and uses various measures to monitor evolving weather, fuel, and other
21 conditions that might lead to fire events and other hazardous conditions.

22 As explained below, SCE is further enhancing its situational awareness capabilities to
23 address increasing fire risks throughout its service area. SCE is focused on accessing more
24 detailed information about wildfire risk at the individual circuit level, to better understand how

¹²⁴ 2016 EOC upgrades included re-configuring the facility to better support incident management teams, new space for the Watch Office, installation of video walls, and new PC hardware at each workstation.

1 weather conditions might impact utility infrastructure and public safety in high fire risk areas.
2 This plan includes contracting with IBM to access a high resolution weather model, and
3 strategically installing weather stations to enhance the IBM high resolution model with real time
4 data near circuits in high fire risk areas. SCE is also installing HD cameras in high fire risk areas
5 to help both fire responders and staff maintain visual awareness of potential fire events in real
6 time.¹²⁵ This data will be sent into a newly-established Situational Awareness Center co-located
7 in SCE's EOC with the SCE Watch Office. This is where meteorologists and Geographic
8 Information System (mapping) specialists will aggregate the data into useful programs. SCE will
9 also purchase a high-performance computer platform that will enable aggregation of complex
10 data to generate geographically based fire potential indices to approximate wildfire risk across its
11 service area.

12 These new capabilities will better inform operational decisions, help SCE's emergency
13 management staff determine how best to reduce potential wildfire risks, and make the utility
14 even more effective in responding to fire events when they occur. Because technology is critical
15 to this effort, and always evolving, SCE is exploring the use of alternate technologies in parallel
16 to the proven technology being used today. This includes a program study in support of a high-
17 resolution weather forecast tool, as well as additional technologies described in Section IV.E.

¹²⁵ To immediately enhance its situational awareness capabilities, SCE has begun installing weather stations and HD cameras, prioritizing CPUC Tier 2 and Tier 3 areas first. SCE will continue to install this equipment throughout 2019 and 2020, as explained in additional detail below.

1

1. HD Cameras

*Figure IV-18
HD Cameras Deployed at Santiago Peak*



2

a) Program Overview

3

4

5

6

7

8

SCE is installing pan-tilt-zoom (PTZ) HD cameras throughout its HFRA to enable fire agencies and SCE personnel to more quickly address emerging wildfires, helping mitigate potential safety risks to the public and prevent damage to electric infrastructure. HD camera views will transmit into SCE’s Situational Awareness Center, and will be used by its IMTs to decide how to deploy crews and in make other operational decisions, such as PSPS activation. Without HD camera capability, SCE and local fire agencies would not have real-time

1 access to guide fire related decisions and risk losing critical time during potential fire events.¹²⁶
2 Between 2018 and 2020, SCE is targeting installation of up to 160 PTZ HD cameras¹²⁷ on
3 approximately 80 towers within HFRA to achieve up to 90 percent coverage of SCE's HFRA.

4 b) What Exists Today

5 Today, SCE primarily relies on fire agency and news media reporting¹²⁸
6 and on-scene observations by SCE's crews to address wildfire activity in its service area.
7 However, SCE has installed a test HD camera pilot at Santiago Peak, located in its service area.
8 The test cameras have operated successfully, and were used by fire agencies for recent fires.¹²⁹

9 c) Effectiveness

10 Deploying HD cameras throughout its HFRA will enhance SCE's
11 situational awareness capabilities and enable emergency management personnel, including fire
12 agencies, to more quickly respond to emerging wildfires. In particular, HD camera images save
13 additional time in verifying and assessing a fire's severity as compared to sending fire crews to
14 perform this assessment.

15 SCE in reviewing HD Camera deployment reviewed statements received
16 from the United States Forest Service, Fire Protection Districts, Bureau of Land Management,
17 and San Diego Fire Rescue, and these agencies all agreed this approach is beneficial. SDG&E
18 also has experience deploying HD cameras, and confirmed the benefits of this approach.¹³⁰
19 Thus, the HD cameras not only provide benefit to the utility in helping provide real-time

¹²⁶ As noted earlier, SCE's HD cameras deployed at Santiago Peak help fire agencies respond to wildfires, and were able to capture what are believed to be the first images of the Holy Fire. See Kevin Sablan, *Holy fire time-lapse GIF captures smoke exploding into blaze*, O.C. Register (August 13, 2018), available at <https://www.ocregister.com/2018/08/13/these-holy-fire-gifs-show-how-quickly-the-blaze-grew-and-how-winds-pushed-it-forward/>

¹²⁷ Refer to Work Paper Vol. 2 (Forecast - HD Cameras)

¹²⁸ Fire agencies rely on 911 dispatch calls and land/aerial surveillance.

¹²⁹ Santiago Fire reported June 11, 2018 and Holy Fire reported August 6, 2018.

¹³⁰ SDG&E has partnered with CalFire agencies to deploy a network of HD cameras throughout high fire risk areas within its service area. SDG&E indicated that HD cameras have been successfully used by first responder agencies to quickly assess and respond to active wildfire ignitions, mitigating the potential for these incidents to grow into larger wildfires.

1 information regarding whether utility equipment is in jeopardy during fire events, but they also
 2 provide important information to state agencies that may help in the speed and efficacy in
 3 responding to fire events.

4 d) Forecast

5 Table IV-14 below summarizes the forecast incremental costs in SCE’s
 6 request for HD Cameras.

Table IV-14
2018-2020 HD Camera Costs¹³¹

| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|-----------------|---------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| HD Cameras | 1,123 | 2,272 | 741 | \$ 4,136 |
| Grand Total | \$ 1,123 | \$ 2,272 | \$ 741 | \$ 4,136 |

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|---------------|-----------------|-----------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| HD Camera Leases | 618 | 2,572 | 3,197 | \$ 6,387 |
| Grand Total | \$ 618 | \$ 2,572 | \$ 3,197 | \$ 6,387 |

7 e) Detailed Program Description

8 SCE is partnering with the University of California San Diego and the
 9 University of Nevada Reno to deploy HD cameras throughout HFRA. Specifically, SCE will
 10 deploy two PTZ cameras: one will perform 360° sweeps approximately every minute, with
 11 twelve high definition frames per sweep; the other will be web-controlled for early fire detection
 12 and situational awareness. SCE’s Fire Management Organization will control the second camera
 13 and will set it to “Home” in an appropriate location to minimize any blind spots.

14 SCE’s Fire Management Organization and approved public agencies can
 15 access the cameras via an electronic platform and can pan, tilt, and zoom for early fire detection,
 16 confirmation, and situational awareness. The public will be able to view live images of the
 17 cameras via the AlertWildfire.org website and view time lapse videos, but will not be able to
 18 control the cameras. All data will be deleted from the cloud buffer after 12 hours.

¹³¹ Refer to Work Paper Vol. 2 (Forecast - HD Cameras)

1 For 2018, SCE targets installing up to 70 PTZ cameras on approximately
2 35 towers, covering up to 50 percent of Tier 2 and 3 areas. These cameras will be installed on
3 third-party towers and strategically placed in areas providing maximum visibility of HFRA. In
4 2019, SCE plans to install up to 70 additional PTZ cameras on another 35 tower locations,
5 covering up to 80 percent of Tier 2 and 3 areas.

6 In 2020, SCE targets installing up to 20 cameras on 10 additional towers
7 to bring coverage up to 90 percent of Tier 2 and 3 areas, and to increase resiliency by creating
8 multiple backhaul pathways using the microwave network.

9 f) Alternatives Considered

10 SCE can obtain fire progression images by other public means (e.g.,
11 monitoring news channels and 911 calls). Fire crews can also be dispatched to determine fire
12 severity and report back. SCE prefers deploying HD cameras over these other options because
13 those other options take longer to obtain information regarding fire progression. Moreover, SCE
14 understands from SDG&E's experience that the fire agencies also find the HD cameras
15 beneficial because no other agency or public entity has installed such devices.

1 2. Weather Stations

*Figure IV-19
SCE Weather Station on Distribution Pole*



2 a) Program Overview

3 SCE intends to enhance its existing weather models by installing weather
4 stations on circuits within HFRA. SCE intends to install up to 850 weather stations in the HFRA
5 between 2018-2020. ¹³² These additional weather stations will enhance the resolution of existing
6 weather models and provide real-time information to assist with making key operational
7 decisions during potential fire conditions, including PSPS deployment.

8 b) What Exists Today

9 SCE has approximately 24 legacy weather stations installed at various
10 substations. These stations are less precise and have less functionality than current weather
11 station models. SCE can also use publicly-available weather station data to monitor conditions;
12 however, these data do not cover many rural areas within its HFRA, limiting its situational
13 awareness capabilities in those areas.

¹³² Refer to Work Paper Vol. 2 (Scope - Weather Stations)

1 c) Effectiveness

2 The deployment of additional weather stations will significantly enhance
3 SCE's existing weather forecast models to provide more expansive, accurate weather data
4 throughout SCE's HFRA. In today's higher risk fire environment, this information is crucial to
5 informing operational decisions during severe fire conditions. This includes potential
6 deployment of PSPS. The Commission recognized in Resolution ESRB-8 that de-energizing
7 electric facilities for public safety is complex, and depends on many factors including "local
8 meteorological conditions of humidity and winds."¹³³ SDG&E utilizes a similar program, with
9 at least 170 weather stations within its service area, and SCE's understanding is that fire agencies
10 in SDG&E's service area support this program.¹³⁴

11 d) Forecast

12 Table IV-15 below summarizes the forecast incremental costs in SCE's
13 request for Weather Stations.

¹³³ See Resolution ESRB-8, p. 8, available at <http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M218/K186/218186823.PDF>.

¹³⁴ See Weather Awareness System, #10 Weeks of Summer: Behind the Forecast, SDG&E's Weather Team dated July 11, 2017, available at <http://weather.sdgeweather.com/> (accessed August 21, 2018).

Table IV-15
2018-2020 Weather Station Costs ¹³⁵

| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|-----------------|-----------------|------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Weather Stations | 1,066 | 5,922 | 6,345 | \$ 13,334 |
| Grand Total | \$ 1,066 | \$ 5,922 | \$ 6,345 | \$ 13,334 |

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|---------------|---------------|-----------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Weather Station Maintenance | 94 | 631 | 1,200 | \$ 1,925 |
| Weather Station Development/Delivery | 48 | - | - | \$ 48 |
| Grand Total | \$ 142 | \$ 631 | \$ 1,200 | \$ 1,973 |

e) Detailed Program Description

SCE intends to install up to 850 weather stations within HFRA between 2018-2020. To date in 2018, SCE has installed approximately 60 new stations and SCE’s fire meteorologists will continue identifying potential locations for up to 790 additional weather stations, for a total of up to 850 weather stations. SCE is prioritizing circuits where these stations will be installed within HFRA by targeting locations in the downslope area of mountain ranges that would capture north-to-northeast winds.

SCE partnered with Western Weather Group (WWG) to identify the best weather station solution for improving fire weather prediction and real-time observation capabilities. WWG has extensive experience helping utility companies to implement solutions to monitor weather. WWG focused on preventing disasters such as downed power lines caused by high winds. WWG worked with Campbell Scientific¹³⁶ to build out a customized weather station kit for SCE, focused on timely and site-specific weather information for predicting and observing fire weather. The kit was designed with advanced sensors to measure wind, temperature, humidity, and other key variables that provide meteorologists and incident management teams


¹³⁵ Refer to Work Paper Vol. 2 (Forecast - Weather Stations; Forecast - Weather Stations Maintenance; Scope - Weather Stations; Development and Delivery - Weather Stations)

¹³⁶ Campbell Scientific is a worldwide provider of rugged, reliable dataloggers and data acquisition systems for long-term, unattended monitoring and is experienced in building automated weather stations specifically for fire weather.

1 with information to make accurate and timely decisions to address heightened wildfire risk
2 conditions.

3 When installed, weather stations use various sensors and communications
4 to provide meteorologists with real-time weather data including temperature, relative humidity,
5 dew point, wind speed, wind direction, wind gust behavior, wind gust direction, and other
6 variables. The weather station equipment includes the components depicted below in Figure IV-
7 20. This includes a datalogger (the central component of the weather station, which measures
8 signals coming from the weather station sensors); sensors to measure wind speed and direction,
9 and temperature and relative humidity; and a solar panel and back up battery for power.

Figure IV-20
Weather Station Anatomy



Anatomy of a
Weather Station

- 1. Solar Sensor
- 2. Temperature/RH Sensor
- 3. Wind Monitor
- 4. Directional Cellular Antenna
- 5. Solar Panel
- 6. Data Logger
Charge Controller
Battery
Cellular Modem

10 f) Alternatives Considered

11 Forecasting information is available from weather models or through
12 public information such as the Remote Automatic Weather Stations, National Weather Service,

1 and Federal Aviation Administration airports. But these alternatives are less accurate and will
2 limit SCE's ability to make more fully-informed operational decisions in today's higher-risk fire
3 environment.

4 **3. Advanced Weather Modeling Tool (IBM Forecast on Demand System)**

5 a) Program Overview

6 SCE is procuring IBM's Forecast on Demand System, a comprehensive,
7 advanced weather monitoring platform with faster weather data incorporation and higher
8 resolution compared to other available systems.¹³⁷ The IBM system provides several benefits,
9 including enhanced resolution and more accurate forecast data to better inform deployment of
10 SCE's PSPS protocol and provide overall support to SCE's IMT in developing HFRA forecasts
11 and fire response plans. SCE tested a "proof of concept" for this system and anticipates fully
12 deploying it in production environment in 2018-2019.

13 b) What Exists Today

14 SCE currently uses lower-resolution modeling systems, specifically
15 publicly-available weather models and vendor models that provide information for weather
16 monitoring. These models are mainly run on six- or twelve-hour cycles and at resolutions of
17 3km or greater. To further enhance our existing capabilities, SCE is obtaining more advanced
18 technologies that enable forecasting capabilities with higher granularity and precision to identify
19 more localized weather conditions.

20 c) Effectiveness

21 The Forecast on Demand System provides several benefits, but the
22 primary one is the ability to better inform operational decisions during potential fire conditions,
23 including PSPS deployment. As Resolution ESRB-8 recognized, de-energizing electric facilities
24 for public safety is complex, and depends on many factors including local meteorological

¹³⁷ SCE contracted with IBM because it is a leader in weather forecasting modeling and observational weather information. As opposed to other weather modeling companies, IBM also can create a tool to house the Forecast on Demand data.

1 conditions of humidity and winds.¹³⁸ The proposed modeling tool addresses this issue by
2 providing more frequent, higher-resolution forecast data on one comprehensive platform.

3 d) Forecast

4 Table IV-16 below summarizes the forecast incremental costs in SCE's
5 request for Advanced Weather Modeling.

Table IV-16
2018-2020 Advanced Weather Modeling Tool Costs ¹³⁹

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|---------------|---------------|---------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Advanced Weather Modeling Tool | 384 | 604 | 604 | \$ 1,592 |
| Grand Total | \$ 384 | \$ 604 | \$ 604 | \$ 1,592 |

6 e) Detailed Program Description

7 In May 2018, SCE contracted with IBM, an international leader in weather
8 modeling, to develop an advanced modeling tool to provide more frequent, higher-resolution
9 forecast data on one comprehensive platform, including information gained from SCE's Weather
10 Stations. This tool will provide higher resolution forecast information down to 500m, and short-
11 term forecast updates as frequently as every 15 minutes. This is faster than SCE's current
12 models, which are mainly run on six- or twelve-hour cycles and at resolutions of 3km or greater.
13 The model will forecast weather parameters such as temperature, wind speed and gusts,
14 humidity, and precipitation. This system will provide these benefits:

- Enhanced resolution and more accurate forecast data to better inform
15 deploying SCE's PSPS protocol;
- Severe weather forecasting including wind, thunderstorms, heavy rain
16 events along with extreme temperatures;
- Visualization of weather conditions and forecasts around SCE
17 infrastructure; and
18
19
20

¹³⁸ See Resolution ESRB-8, p.8, available at
<http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M218/K186/218186823.PDF>.

¹³⁹ Refer to Work Paper Vol. 2 (Forecast - Advanced Weather Modeling Tool)

- Overall support to SCE's IMT in developing HFRA forecasts and fire response plans.

IBM has delivered an initial functional forecasting model and visualization tool. IBM is currently working on developing enhancements to the initial release of the software, and will add additional capabilities and features in future phased releases in the coming months. Key features will include improved GIS capabilities, incorporation of additional variables into forecasts (e.g. fuel moisture levels), development of forecasting capabilities to assess the risk of fire ignition and other end user improvements. The next release of the software is scheduled for October, 2018.

f) Alternatives Considered

Other weather models provide similar data (e.g., American GFS Model and European ECMWF Model), but with lower resolution and/or less frequent time increments compared to the IBM system. For example, typical operational weather models can be run at a 2km resolution at their lowest and at a time step of one hour. For these reasons, SCE chose not to pursue these models because the degree of enhanced functionality above the existing systems was not as great. SCE also evaluated whether it could continue using its current systems without modification, but determined that the new heightened risks call for more sophisticated technologies to better predict such weather conditions under the "new normal" conditions of year-round fire risk and more extreme climate extremes.

4. Advanced Modeling Computer Hardware

a) Program Overview

SCE intends to deploy a high-performance computing platform to improve its ability to scientifically quantify the risk of wildfire ignitions in different geographic regions throughout its service area. SCE will procure advanced computer hardware and deploy state-of-the-art software that will run a sophisticated Fire Potential Index model that will account for various factors including weather, live fuel moisture, and dead fuel moisture to assess the level of risk of wildfire ignitions. This platform will also enable software to analyze decades of data

1 for fuel and weather characteristics from past wildfire ignitions, and compare and contrast those
2 variables against current conditions to forecast the Fire Potential Index. The output from this
3 model will be used to inform operational decisions, implement work restrictions, and optimize
4 resource allocation for emergency situations.

5 SCE is obtaining the hardware and software for its high performance
6 computing platform and intends on using it starting in 2019.

7 b) What Exists Today

8 SCE relies on a manual process and its staff's professional judgment to
9 estimate fire potential risk, taking into account a number of variables such as wind, temperature,
10 humidity, and vegetation properties. SCE's staff includes a team of meteorologists who are
11 members of the American Meteorological Society and who hold specialized education in
12 Atmospheric Sciences.

13 c) Effectiveness

14 Commission Resolution ESRB-8 recognized that proactively de-
15 energizing electrical facilities is a complex decision, depending on many factors including fuel
16 moisture and local metrological conditions of humidity and winds.¹⁴⁰ The high-performance
17 computer platform helps address this complexity, by providing the ability to consider and
18 analyze large amounts of data, consisting of many factors to provide for objective forecasting of
19 wildfire indices.

20 d) Forecast

21 Table IV-17 below summarizes the forecast incremental costs in SCE's
22 request for Advanced Modeling Computer Hardware.

¹⁴⁰ Resolution ESRB-8, p. 8, *available at*
<http://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M218/K186/218186823.PDF>.

Table IV-17
2018-2020 Advanced Modeling Computer Hardware Costs¹⁴¹

| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|-----------------|-----------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Advanced Modeling Computer Hardware | 2,943 | 3,722 | 1,330 | \$ 7,995 |
| Grand Total | \$ 2,943 | \$ 3,722 | \$ 1,330 | \$ 7,995 |

| O&M (2018 Constant \$000) | | | | |
|---|--------------|---------------|---------------|---------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Advanced Modeling Computer Hardware Maintenance | 50 | 120 | 120 | \$ 290 |
| Grand Total | \$ 50 | \$ 120 | \$ 120 | \$ 290 |

e) Detailed Program Description

In considering whether to de-energize power lines, SCE considers a wide variety of factors which may include, but are not limited to, the following:

- The National Weather Service issuing Red Flag Warnings for counties that contain SCE circuits in HFRA
- Ongoing assessments from SCE meteorologists regarding local conditions related to wind speed, humidity, and temperature
- Real-time situational awareness information from personnel positioned in HFRA identifying extreme weather conditions
- Input from its Fire Management experts regarding any ongoing firefighting efforts
- Specific concerns from local and state fire authorities regarding the potential consequences of wildfires in select locations
- Awareness of mandatory or voluntary evacuation orders in place
- Expected impact of de-energizing circuits on essential services such as public safety agencies, water pumps, traffic controls, etc.
- Other operational considerations to minimize potential wildfire ignitions

¹⁴¹ Refer to Work Paper Vol. 2 (Forecast - Advanced Modeling Computer Hardware; Forecast - Advanced Modeling Computer Hardware Maintenance)

1 SCE plans to further refine its fire risk mitigation decision-making by
2 utilizing risk-modeling to create a Fire Potential Index. To do so, SCE must purchase hardware
3 and software capable of statistically-analyzing mass quantities of information real time, such as
4 historic weather information and fuel moisture. This technology will do the following:

- 5 • Compute high-quality granular weather forecast data that allows for
6 enhanced weather prediction capabilities supporting PSPS planning
7 and implementation
- 8 • Compute wind speed forecasts, fuel moisture statistics and humidity
9 levels to create a wildfire threat index which rates the potential for
10 wildfires fueled by strong seasonal winds to assist with development
11 of understanding of fire threats in areas where observations of fuel
12 moisture are not readily available. Development of a wildfire index
13 can assist with SCE crew deployment based on the rating scale
- 14 • Improve Load modeling with the additional granular temperature,
15 humidity, wind and solar related data inputs

16 SCE is engaging qualified vendors to assess cost and scope for this
17 technology and plans to designate an appropriate data center and sufficient circuit and network
18 capabilities to properly house and support the equipment.

19 SCE expects that the final configuration and project scope will likely
20 include the following elements:

- 21 • Order hardware, coordinate with SCE data center personnel to prepare
22 data center with appropriate circuit and network connection
- 23 • Install and optimize the Weather Research and Forecasting (WRF)
24 Model¹⁴² on both computer systems

¹⁴² The Weather Research and Forecasting (WRF) Model is a next-generation mesoscale numerical weather prediction system designed for both atmospheric research and operational forecasting applications. It features two dynamical cores, a data assimilation system, and a software architecture supporting parallel computation and system extensibility.

- Use SCE observation network to validate optimal WRF configuration.
- Operationalize WRF configuration(s)
- Run WRF over historical period (30 years) on backup computer systems. Implement nudging scheme and initialize soil moisture/temperature properly. Provide analytics including fire potential index, fuels, high-impact weather variables
- Gather and parse load data from SCE. Match to historical weather data to train load model (aggregate spatially)
- Implement fuel moisture model on the WRF grid. Spin-up dead fuel moisture
- Implement live fuel moisture model on the WRF grid;
- Implement fire potential index on WRF grid. Create analytics and data feeds to appropriate users
- Install existing SCE models (Damage Model, etc.) and build web-based interface for on demand model initialization.

f) Alternatives Considered

SCE is not aware of equivalent alternatives. The ability to timely process countless weather-related data points to create forecast models that allow for creation of wildfire threat index ratings and supporting PSPS initiation is not available by manual means.

5. Asset Reliability and Risk Analytics

a) Program Overview

As part of the Asset Reliability and Risk Analytics program, SCE seeks to: (1) develop capabilities in predicting an asset's overall wildfire-related risk; and (2) given an asset's risk, prioritize work, repairs, and/or replacement(s) to minimize potential wildfire ignitions. SCE will utilize its existing analytics platform to develop composite risk models that can be leveraged to predict risk as it relates to distribution assets, vegetation health, and extreme

1 weather events that could impact public safety, including wildfire ignitions. These risk models
2 will be used to enhance existing processes, including the following:

- 3 • Identifying which assets should be prioritized for replacement or
4 upgrade based on the environment they operate in and their asset
5 characteristics (i.e., number of splices, conductor type; fusing, etc.);
- 6 • Analyzing forecasted and historical weather conditions;
- 7 • Conducting and prioritizing maintenance;
- 8 • Analyzing asset types; and
- 9 • Analyzing operational data (such as load, duty cycle, etc.).

10 Using these analytics to prioritize mitigation efforts on the highest risk
11 assets in the high fire risk areas will help optimize SCE's actions to help overall ignition risk.

12 This program also proposes advanced analytic capabilities for streaming
13 grid data (smart meter, supervisory control and acquisition data (SCADA), etc.) to improve
14 advanced fault detection. This capability will allow SCE to use artificial intelligence, machine
15 learning, and predictive modeling on streaming data to identify early warning signs of potential
16 faults and to immediately identify a fault that has occurred, to more quickly respond to remediate
17 a public safety risk. Quickly detecting downed energized conductors and predicting faults that
18 could cause increase ignition risk would reduce fire risk and maintenance costs, making the
19 system safer and more cost effective.

20 b) What Exists Today

21 SCE collects a large amount of data on asset operations, maintenance, and
22 other asset characteristics, using manual analysis and human judgment for asset classes
23 individually and relying primarily on scheduled maintenance or the Commission's prescribed
24 issue remediation timeframes to address and prioritize asset reliability risk.

25 c) Effectiveness

26 SCE is pursuing this initiative to help support risk-informed decision
27 making to address increasing fire risk, including potential PSPS deployment. This program also

1 focuses on upgrading and replacing SCE's infrastructure to mitigate potential ignition risks. By
2 developing models that predict which assets are more likely to experience faults that could
3 increase ignition risks, SCE can prioritize where, and what, assets need remediation to optimize
4 system investments as efficiently as possible.

5 While focusing on asset health to meet system reliability goals has
6 historically been a primary driver of SCE's asset management approach, SCE needs additional
7 tools and data to inform prioritization of asset and circuit upgrades to mitigate ignition risk in
8 HFRA. In order to understand the ignition risk of particular assets and their circuits, and
9 prioritize remediation across SCE's system accordingly, SCE needs to gather relevant data
10 together in a central analytics platform to develop models that allow SCE to make risk-informed
11 investment and operational decisions that reduce wildfire risks.

12 SCE also plans to accelerate and improve its current manual asset analysis
13 approach to rapidly adapt to new information and methods to continuously improve how SCE
14 manages asset reliability and public safety risks across SCE's system. This platform is designed
15 to assimilate more data in the future as it becomes available (such as supercomputer fire
16 simulation data, new weather station data, etc.) and train composite risk models using analytics
17 and machine learning to improve the accuracy and usefulness of the models in mitigating
18 wildfire risk over time.

19 This initiative will also use advanced analytics to improve operations by
20 using streaming data from the electric grid to augment analysis for PSPS decision-making by
21 using real-time fire simulation data from the advanced computer models and predictive fault
22 analytics together to get a full picture of the state of SCE's assets in HFRA.¹⁴³ For example,
23 today, SCE's first indication of an energized downed conductor may be from a phone call from a
24 first responder or customer. In the future, using outage event data from SCE's smart meter
25 system, SCADA data, and fire simulation data, SCE will be able to locate downed conductors

¹⁴³ See Chapter IV, Section C.5, *supra*, for a discussion of SCE's advanced computer program.

1 faster and with greater location specificity and, using the advanced computing platform, quickly
 2 understand the impact of a potential ignition event. This will significantly decrease the risks
 3 associated with downed conductors, including wildfire ignitions and help SCE work more
 4 effectively with first responders when wildfire events do occur.

5 d) Forecast

6 Table IV-18 below summarizes the forecast incremental costs in SCE’s
 7 request for Asset Reliability and Risk Analytics.

Table IV-18
2018-2020 Asset Reliability and Risk Analysis Tool Costs¹⁴⁴

| Capital (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|---------------|-------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Asset Risk Modeling | 2,141 | 505 | - | \$ 2,646 |
| Operational Analytics | 1,239 | - | - | \$ 1,239 |
| Grand Total | \$ 3,380 | \$ 505 | \$ - | \$ 3,885 |

| O&M (2018 Constant \$000) | | | | |
|--|-------------|-------------|-------------|--------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Operational Analytics Development/Delivery | 7 | 9 | - | \$ 16 |
| Grand Total | \$ 7 | \$ 9 | \$ - | \$ 16 |

8 e) Detailed Program Description

9 The Asset Reliability and Risk Analytics program is composed of two
 10 major work tracks.

11 (1) Asset Risk Modelling

12 The first work track is focused on developing risk models that
 13 create composite risk scores based on asset, environmental and operational data. This will
 14 provide guidance on ignition risks so that SCE can prioritize asset maintenance, upgrades and
 15 replacement work to decrease the risk of wildfires. As such, the key objectives and elements of
 16 Asset Risk Modelling are as follows:

¹⁴⁴ Refer to Work Paper Vol. 2 (Forecast - Asset Risk Modeling; Forecast - Operational Analytics; Development and Delivery - Operational Analytics)

- Enhance public safety by identifying and prioritizing assets for ignition risk mitigation in HFRA by creating composite risk indexes for those assets based on their characteristics (splices, fusing, conductor type, fault risk, maintenance and operational data, and fire simulation data from the “super computer” platform)
- Integrate relevant SCE and public domain data to enable risk modelling
- Develop and implement risk models associated with SCE Assets, surrounding vegetation, weather and operational data that then result in a consolidated Risk Score
- Integrate risk model events, data and scores for ingestion into the machine learning and analytics environment to operationalize the asset risk modelling capability
- Display geospatial visualization of the risk model events and scores along with appropriate notifications and alerts to the situational awareness center, distribution planning, engineering, and SCE work and asset management teams
- Conduct exploratory analysis using machine learning techniques to gain greater insights into the data and improve model accuracy by searching for anomalies or extremes and improving spatial and temporal fidelity of major data sources as new sensors and simulation data becomes available

(2) Operational Analytics

The second work track is focused on using analytics to develop advanced fault detection. Specifically, the program is designed to develop and improve energized wire down detection algorithms using streaming data from meters, SCADA, remote

1 fault indicators and other sensors to shorten the duration of Energized Downed Conductor (EDC)
2 events and reduce ignition risks. Key elements and objectives of operational analytics for
3 energized downed conductor detection are as follows:

- 4 • Identify many EDC events within approximately fifteen
5 minutes and to be able to mitigate public danger as fast as
6 possible;
- 7 • Determine the confidence, location, and risk factor of an EDC
8 and respond appropriately;
- 9 • Provide first responder notification of an EDC in faulted
10 conditions that pose a public safety risk;
- 11 • Use the information from events to tune continue to fast curve
12 settings on RARs (where available) to further diminish risks to
13 public safety from EDCs; and
- 14 • Use data analytics tools to create a platform capable of
15 improving existing operational analytics and algorithms to
16 detect infrastructure in faulted conditions and predict assets
17 more prone to faults.

18 SCE intends on developing its Asset Reliability and Risk Analytics
19 program in several phases with initial capabilities in November of 2018 and program completion
20 in 2019.

21 f) Alternatives Considered

22 SCE considered using generic reliability-centered maintenance software
23 and algorithms. SCE rejected this alternative because the level of integration work,
24 customization of commercial off-the-shelf software to do risk analytics, and the individual asset
25 lifecycle focus would be more costly, take longer, and be less flexible to accommodate future
26 requirements than using SCE's existing platform.

1 **6. Additional Required Staffing**

2 As discussed in this testimony, the state’s substantially increasing fire risk means
3 that SCE must respond to more frequent and prolonged fire threats throughout its service area.
4 SCE is planning to enhance its staffing expertise in early fourth quarter 2018 to be more fully
5 prepared to address any fire conditions emerging later this year. SCE anticipates filling four new
6 full-time positions in the fourth quarter of 2018:

7 **One Fire Management Officer** – SCE currently has two Fire Management
8 Officers, responsible for coordinating with first responders and enhancing first responder safety,
9 and reporting and informing operational decisions. Increasing fire risk is placing a significant
10 strain on SCE’s Fire Management Officers, who also support system planning efforts related to
11 grid resiliency. This additional resource will help SCE continue to timely respond to fire
12 incidents and coordinate with first responders.¹⁴⁵

13 **Two Additional Meteorologists** – SCE currently staffs three meteorologists who
14 have historically been responsible for forecasting related to energy procurement. These
15 meteorologists now also support SCE’s Business Resiliency department, performing several
16 additional tasks including: coordinating the installation of weather stations; contracting with
17 vendors to deploy high resolution weather models; developing new tools and products to support
18 the situational awareness center; exploring new models to predict fire potential; and supporting
19 incidents and pre-incidents by providing meteorological expertise (including on a twenty-four-
20 hour, seven-day-a-week schedule at SCE’s Situational Awareness Center during activated
21 incident management conditions). The proposed two additional positions will support these
22 added functions, along with staffing the situational awareness center staffing twenty-hour
23 staffing during activation events.

¹⁴⁵ In support of the Fire Management Officer responsibilities, SCE has included within the forecast staffing one vehicle that is furnished with additional radios for SCE communication (Edison 900mH, Fire Radios along with scanner function).

1 **One Fire Scientist** – This new position will build and mature complex fire
 2 models designed to predict wildfire ignition and propagation by considering multiple variables
 3 such as weather, fuel, and asset conditions. Once developed, these models will inform SCE’s
 4 IMT of severe fire conditions which may require deployment of PSPS in HFRA.

5 The proposed four full time positions are expected to remain on staff within SCE's
 6 Business Resiliency department to support projects, programs, and work streams focused on
 7 preparing and responding to potential fire conditions.

8 a) Forecast

9 Table IV-19 below summarizes the forecast incremental costs in SCE’s
 10 request for Additional Required Staffing.

Table IV-19
2018-2020 Staffing Costs ¹⁴⁶

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|---------------|---------------|---------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Additional Required Staffing | 115 | 460 | 460 | \$ 1,035 |
| Vehicle for Fire Manager | - | 20 | 20 | \$ 39 |
| Grand Total | \$ 115 | \$ 480 | \$ 480 | \$ 1,074 |

11 **D. Enhanced Operational Practices**

12 **1. Vegetation Management**

13 a) Overview of Expanded Vegetation Management Activities

14 Vegetation management is a longstanding component of SCE’s efforts to
 15 minimize ignitions associated with electrical facilities. SCE has an inventory of approximately
 16 900,000 trees near its electrical facilities (system wide) inspected annually and pruned¹⁴⁷ as
 17 needed to maintain mandated clearances. Due to the longstanding drought and bark beetle
 18 infestation, SCE also removes approximately 40,000 trees per year that are dead, dying, or
 19 diseased and could fall into its electrical facilities. SCE is also inspecting and pruning trees in

¹⁴⁶ Refer to Work Paper Vol. 2 (Forecast - Additional Required Staffing; Forecast - Vehicle for Fire Manager)

¹⁴⁷ SCE uses “pruning” and “trimming” interchangeably.

1 areas recently added to the Commission’s designated Tier 2 and Tier 3 High Fire Threat Areas to
2 meet new mandated clearances¹⁴⁸ and expanding time-of-trim clearances throughout these areas
3 to factor in the new recommended distances.¹⁴⁹

4 As part of its GS&RP, SCE plans to expand its vegetation management
5 activities to assess the structural condition of trees in HFRA that are not dead or dying, but could
6 fall into or otherwise impact electrical facilities and potentially lead to ignitions and outages.
7 These trees may be as far as 200 feet away from SCE’s electrical facilities. Trees posing a
8 potential risk to electrical facilities due to their structural or site condition will be removed or
9 otherwise mitigated.¹⁵⁰ For example, a 75-foot tall palm tree, 50 feet from electrical facilities not
10 only has the potential to fall into these facilities, but its palm fronds can dislodge and blow into
11 electrical facilities igniting a fire. While this palm tree meets all mandated compliance
12 clearances and is not dead or dying, under this new effort, SCE may still identify it as a potential
13 risk to be mitigated by either removing dead fronds or removing the tree altogether. SCE views
14 this as an important effort in light of increasing winds that have the potential to blow palm fronds
15 and other debris into utility lines from even greater distances.

16 Another example is a tree near electrical facilities that has heavy woody
17 stems that are exempt from mandatory clearances. While this tree meets all the mandatory
18 clearance requirements, through the threat assessment, SCE may conclude that it is expected to
19 pose a risk and remove the tree.

¹⁴⁸ In those areas that were recently added, the required clearances went from 18 inches to 48 inches.

¹⁴⁹ In the Commission’s designated Tier 2 and Tier 3 High Fire Threat Areas the recommended time-of-trim clearances went from 6.5 feet to 12 feet for lines operating between 2,400 volts and 72,000 volts. Recommended time-of-trim clearances for lines operating at higher voltages were also increased. (See D.17-12-024, pp. 100-102.)

¹⁵⁰ Many trees that may pose an expected risk to SCE’s electrical facilities are on private or public property and SCE may not have rights to access the property to conduct assessments and perform mitigation tasks. Thus, SCE may be prevented from reducing potential tree risks by property owner opposition and/or restricted access to private property.

1 b) What Exists Today: SCE’s Vegetation Management-Related Activities
2 and Associated Rate Recovery Mechanisms

3 As noted above, SCE currently has a number of vegetation management
4 programs in place to comply with current state and federal regulations. As shown in Table IV-
5 20, SCE recovers existing vegetation management program costs through one of three CPUC
6 ratemaking mechanisms: (1) the GRC; (2) the Drought Catastrophic Event Memorandum
7 Account (Drought CEMA); or (3) the Fire Hazard Prevention Memorandum Account
8 (FHPMA).¹⁵¹ As also shown in the below table, in this Application SCE proposes recording
9 costs for its expanded vegetation management activities in the GS&RPMA. Alternatively, SCE
10 believes the Commission could confirm these costs are now eligible for recording in the Drought
11 CEMA under the “new normal” environment of year-round fire risk.¹⁵²

¹⁵¹ In addition, SCE recovers through its FERC Formula Rate, FERC jurisdictional vegetation management related costs.

¹⁵² Ordering Paragraph (OP) 2 of Resolution ESRB-4 states “Investor Owned Electric Utilities must take practicable measures necessary to reduce the likelihood of fires associated with their facilities. These measures include: increasing vegetation inspections and removing hazardous, dead and sick trees and *other vegetation* near the IOUs’ electric power lines and poles; ...” (Emphasis added). SCE is proposing to remove trees that, based upon tree-specific assessments, create a potential threat to its facilities and could, under the “new normal” environment, be appropriately considered as “other vegetation” within the scope of the Resolution.

Table IV-20
Vegetation Management CPUC Cost Recovery Summary

| Vegetation Management Activity | GRC | Drought CEMA | FHPMA | GS&RP BA |
|--|-----|-----------------|-------|-------------|
| Vegetation management compliance inspections, pruning & opportunity removals and non-drought-related dead, dying and diseased tree removal | ✓ | | | |
| Transmission ROW and road maintenance | ✓ | | | |
| Removal of dead, dying & diseased trees in bark beetle infestation zones | | ✓ | | |
| Resolution ESRB-4 related activities including removal of hazardous, dead and sick trees in HFRA | | ✓ | | |
| D.17-12-024 changes: <ul style="list-style-type: none"> • New compliance clearance in expanded Tier 2 and Tier 3 areas (change from 18 inches to 48 inches) • Incorporation of new recommended time-of-trim clearance in Tier 2 and Tier 3 areas | | | ✓ | |
| Planned expanded vegetation management activities (removal/partial removal of trees that pose a risk to electrical facilities) | | | | ✓ |

(1) 2018 GRC

SCE included in its 2018 GRC revenue requirement forecast \$63.8 million and \$10.4 million (2015 constant \$) for distribution-related and transmission-related vegetation management expenses, respectively.¹⁵³ This includes “all of the expenses associated with tree trimming and tree removal in proximity to transmission and distribution high voltage lines and weed abatement around overhead structures in high fire designated areas. It also includes costs to plant different species of trees as replacements and in handling preventative soil treatment” for adherence to the regulations in place at the time of filing.

SCE’s vegetation management activities included in its 2018 GRC filing are designed to maintain compliance clearances for the approximately 900,000 trees that exist in proximity to electrical facilities throughout SCE’s service area. SCE must comply with

¹⁵³ See A.16-09-001, Exhibit SCE-02, Vol. 4, pp.16 – 18 and Exhibit SCE-02, Vol. 7, pp. 24-25.

1 many vegetation regulations, including GO 95 Rule 35, Public Resources Code Sections 4292
2 and 4293, and FERC FAC-003.

3 SCE's rights-of-way are inspected annually for compliance with
4 state requirements. During these inspections, trees or vegetation that require pruning to maintain
5 required clearances (both vertical and horizontal) from high voltage lines are scheduled for
6 pruning or removal. The pruning takes into consideration a tree's anticipated growth over
7 twelve-months.¹⁵⁴ Fast-growing species, or trees in areas designated as high risk for wildfire,
8 may need more frequent pruning to maintain required compliance clearances. SCE engages
9 contractor resources to prune and remove trees and weeds, and other activities, to comply with
10 these requirements.

11 During these annual line clearance inspections, inspectors also may
12 identify trees that must be removed per existing regulations (e.g., dead, dying and diseased
13 trees,¹⁵⁵ overhangs in HFRA, and opportunity removals (e.g., healthy trees requiring pruning
14 multiple times a year due to their growth rate). Because opportunity removals require owner
15 consent, SCE attempts to contact owners for approval to remove the tree, and leaves contact
16 information if the owner is unavailable.¹⁵⁶ In addition to the approximately 40,000 trees
17 removed due to drought and bark beetle infestation, SCE removes on average approximately
18 12,500 trees per year under its normal vegetation management program.

19 SCE also included in its 2018 GRC revenue requirement \$3.6
20 million (2015 constant \$) for transmission-related road and rights-of-way maintenance activities

¹⁵⁴ For example, if the required clearance is 48 inches in CPUC Tier 2 and Tier 3 Areas and the anticipated annual growth for that species of tree is 24 inches, the tree would be pruned to a distance of at least 72 inches. Based on the recommended time-of-trim clearances in D.17-12-024, SCE has started to expand the trimming distances in CPUC Tier 2 and Tier 3 Areas to reflect at a minimum the new recommended time-of-trim distances.

¹⁵⁵ As discussed below, the costs of removing dead, dying, and diseased trees in HFRA and bark beetle infested zones are recorded in SCE's Drought CEMA. Dead, dying and diseased trees removed under SCE's normal vegetation management program are in non-HFRA and non-bark beetle infested zones.

¹⁵⁶ SCE continues to maintain compliance clearances by pruning when property owner approval to remove the tree is not obtained.

1 including annual grading, repairs of damaged storm drains, repairs of access roads, annual brush
2 clearing along access roads and weed abatement on parcels of property owned by SCE along
3 transmission rights-of-ways, as required by city or county fire codes.¹⁵⁷

4 (2) Drought CEMA

5 Because of unprecedented levels of tree mortality caused by the
6 multi-year drought and bark beetle infestation, SCE records in its Drought CEMA costs
7 associated with removing dead, dying, or diseased trees that can fall into SCE's facilities in
8 HFRA and bark beetle infestation zones. Unlike trees near power lines that must be trimmed to
9 prevent encroachment into the mandated clearances, large dead or dying trees can be located
10 outside of SCE's rights-of-way and fall into electrical facilities. Given that tree mortality is
11 ongoing, SCE inspects for newly dead, dying, and diseased trees every 90 – 120 days in HFRA.
12 Because these inspections are limited in scope, they can be performed fairly quickly via ground
13 and aerial inspections. SCE is removing approximately 3,000 – 4,000 trees per year because of
14 bark beetles and approximately 35,000 trees per year because of the drought.

15 (3) Fire Hazard Prevention Memorandum Account

16 Decision 17-12-024 adopted new regulations to enhance the fire
17 safety of overhead electric power lines and communication lines in high fire-threat areas. The
18 Decision allowed SCE and other electric IOUs to track and record their costs to implement these
19 new regulations in the FHPMAs established pursuant Commission decisions issued in R.08-11-
20 005. As stated previously, SCE is inspecting and pruning trees to meet the Commission's new
21 48-inch clearance requirement in the expanded Tier 2 and Tier 3 areas, and increasing the
22 trimming distance to reflect the Commission's new recommended time-of-trim clearances. The
23 incremental costs of both activities are being recorded in its FHPMA.

24 Recovery of the costs recorded in the FHPMA may be through one
25 or more applications where the Commission will verify and assess the reasonableness of

¹⁵⁷ See A.16-09-001, Exhibit SCE-02, Vol. 7, pp. 23-24.

1 recorded costs. Only those costs not already being recovered in rates (e.g., costs previously
2 booked to the FHPMA and subsequently recovered in rates in a previous GRC proceeding) may
3 be recorded in the FHPMA. Because SCE submitted its 2018 GRC prior to the issuance of D.17-
4 12-024, it will record incremental costs associated with that Decision in its FHPMA until its
5 2021 GRC.

6 c) Forecast

7 Table IV-21 provides SCE's forecasted costs SCE for this effort. These
8 costs are above and beyond what SCE incurs today and have not been included in SCE's 2018
9 GRC and are not recorded in its FHPMA or Drought CEMA. While this expanded effort may
10 include inspections of FERC jurisdictional assets, only those costs associated with CPUC
11 jurisdictional assets will be recorded in the GS&RPMA. As operational details are further
12 developed, the types of, and forecast of, incremental costs may change. As explained later in this
13 section, SCE's forecast is based on its aspirational targets for 2019 and 2020, or mitigating up to
14 15,000 and 30,000 trees in those years, respectively.¹⁵⁸

¹⁵⁸ Refer to Work Paper Vol. 2 (Unit Cost and Scope - Removal)

Table IV-21
2018-2020 Vegetation Management Costs¹⁵⁹

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|-------------|------------------|------------------|-------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Tree Inspection | - | 1,226 | 1,226 | \$ 2,452 |
| Program Management | - | 4,692 | 8,235 | \$ 12,927 |
| Removal | - | 30,218 | 60,435 | \$ 90,653 |
| Mitigation | - | 3,608 | 7,217 | \$ 10,825 |
| Property Owner Incentives | - | 404 | 808 | \$ 1,211 |
| Grand Total | \$ - | \$ 40,148 | \$ 77,921 | \$ 118,069 |

d) Detailed Program Description: Expanded Vegetation Management Activity

As part of the GS&RP, SCE intends to go beyond its existing vegetation management and tree removal activities by focusing on trees in HFRA that are not dead or dying but potentially pose a risk to electrical facilities.¹⁶⁰ More specifically, SCE intends to focus on trees in its HFRA far enough away from electrical facilities that are not covered by existing mandated clearance requirements,¹⁶¹ but close enough to potentially fall into or otherwise impact these facilities. SCE will use a risk-based approach to identify, assess, and mitigate the expected threat level posed by these trees. The key components of this expanded activity covering trees outside of existing clearance requirements include:

- A dedicated tree inspection process;
- A tree-specific threat assessment;
- Risk-based tree removal or mitigation; and
- Enhanced efforts to obtain property owner approval to remove trees.

¹⁵⁹ Refer to Work Paper Vol. 2 (Forecast - Tree Inspection; Forecast - Program Management; Forecast - Removal; Forecast – Mitigation; Forecast - Property Owner Incentives; Unit Cost and Scope – Mitigation; Unit Cost - Program Management; Scope - Program Management; Unit Cost and Scope - Removal)

¹⁶⁰ These expanded efforts will look at SCE’s transmission, distribution, and generating facilities, including secondary distribution, substations, and communication facilities.

¹⁶¹ This also includes exemptions from the clearance requirements for woody stems.

1 Below is an overview of program operations. SCE anticipates finalizing
2 and implementing the operational details of this effort during the first quarter of 2019, and
3 refining its operational approach on an ongoing basis, as the program matures.

4 (1) Dedicated Tree Inspection Process

5 SCE is developing a detailed inspection process to identify subject
6 trees that could potentially fall into or otherwise impact electrical facilities in HFRA, separate
7 from its existing inspection processes.¹⁶² These inspections will look at areas on either side of
8 SCE's electrical facilities called the "utility strike zone" from which a tree or a portion of a tree
9 could directly strike or impact electric facilities. The areas inspected on either side of SCE's
10 electrical facilities can vary significantly (up to 200 feet) based on the height of the trees. SCE
11 anticipates that most inspections will be performed by inspectors on the ground.

12 SCE is developing an inspection prioritization methodology that
13 will include factors such as, fire threat area tier, fuel loading surrounding SCE's facilities, permit
14 and environmental considerations, tree density, and population density. This prioritization
15 methodology will help SCE focus on areas posing the highest risk to public safety and property
16 damage. For example, removing a tree in a sparsely populated area with minimal fuel around
17 SCE's facilities does not mitigate as much risk as removing a tree in a densely populated area
18 where there is fuel near the facilities that can ignite if an energized line was to provide the
19 ignition source. In addition, there are areas in HFRA where obtaining permits to remove trees
20 may take up to a year or more, thus these areas may be prioritized differently from areas where
21 permits are not required or are typically granted. Finally, this program will focus on trees that
22 are outside of SCE's ROW and for which SCE may not have easement rights to disturb, so trees
23 where SCE can obtain owners' permission for removal will be prioritized over trees where
24 owners refuse.

¹⁶² If during these inspections, a dead, dying, or diseased tree in HFRA is identified, it will be inventoried and removed with the associated removal costs recorded in the Drought CEMA.

1 (2) Tree-specific Threat Assessment and Inventory

2 Once a subject tree is identified, an assessment will be performed
3 using a Level 1 assessment approach.¹⁶³ When specific tree characteristics are identified during
4 the Level 1 assessment, a Level 2 assessment¹⁶⁴ of the tree will be conducted. These assessments
5 will be conducted by certified arborists trained to conduct such assessments. The assessment
6 will evaluate the condition of the tree and the expected threat it poses to electrical facilities. For
7 example, if the tree is leaning away from SCE’s facilities and does not pose other risks, a Level 1
8 assessment may determine the tree poses no significant risk. The assessment will include tree
9 characteristics such as those shown in Table IV-22 and site conditions such as those shown in
10 Table IV-23. Moreover, although this program seeks to make strides in removing trees that pose
11 such threat, the limitations of SCE’s access rights, permissions and sheer volume of non-SCE
12 trees located near SCE’s facilities make it impossible to entirely eliminate all risk from such
13 trees.

¹⁶³ These are industry standard assessments typically conducted by arborists for many purposes. A Level 1 assessment is a limited visual assessment that is generally performed from one side of the tree while the inspector is located within or adjacent to the utility easement. This inspection can be ground-based, vehicle-based, or aerial-based (i.e., fixed-wing, helicopter, drone, LiDAR) as appropriate for the site conditions, type of facilities, and tree population being considered. A Level 1 assessment focuses on identifying obvious tree defects (e.g., dead branches, leaning) observable from the side of the tree nearest electrical facilities.

¹⁶⁴ A Level 2 assessment is a more detailed, ground-based visual assessment of an individual tree and its surrounding site. A Level 2 assessment may include walking around the tree – looking at the site, buttress roots, trunk, and branches. Access restrictions, severe terrain or other obstacles may prevent access or otherwise limit ingress to do a 360-degree assessment of an individual tree.

Table IV-24
Sample Risk Based Mitigation Approach

| Recommended Mitigation | Recommended Mitigation Activities |
|---|---|
| Total Tree Removal | <p>Criteria: Tree is expected to pose a risk to electrical facilities and shows characteristics that make the tree or parts thereof, unstable</p> <p>Additional Activities:</p> <ul style="list-style-type: none"> • Add to inventory • Enhanced efforts to identify property owner (e.g., research public records) • Enhanced efforts to contact and negotiate with property owner, including, but not limited to, providing replacement tree and/or engaging local fire agencies, as needed |
| Partial Tree Removal or Trimming | <p>Criteria: Partial removal or trimming can mitigate the expected risk and does not remove more than 30 percent of the crown. In addition, the condition is not caused by or exacerbated by site conditions.</p> <p>Additional Activities:</p> <ul style="list-style-type: none"> • Add to inventory • Enhanced effort to identify property owner • Enhanced effort to contact property owner • Remove tree if property owner willingly approves • Monitor if not removed. Re-inspect/assess based on frequency proposed by inspector |
| Monitor Only | <p>Criteria: Tree considered stable and not expected to pose a risk in the foreseeable future, but shows signs of an emerging threat characteristic or changing site condition (e.g., erosion)</p> <p>Additional Activities:</p> <ul style="list-style-type: none"> • Add to inventory • Re-inspect/assess based on frequency proposed by inspector • No need to contact property owner |
| No Mitigation Required | <p>Criteria: Tree considered stable and not expected to pose a risk in foreseeable future</p> <p>Additional Activities:</p> <ul style="list-style-type: none"> • Do not add to inventory • Re-assess during next annual inspection |

(3) Enhanced Efforts to Obtain Property Owner Approval

Since most trees to be mitigated through this effort reside on private or public property, property owner approval is required to remove the trees. SCE plans to take additional measures to contact property owners when tree removal is recommended. At

1 times, the property owner differs from the occupants of the property, meaning that SCE may
2 need to research public property records to identify property owners and obtain contact
3 information; make multiple efforts to contact the property owner; and negotiate with the property
4 owner to overcome their opposition to removing the tree. Depending upon location, additional
5 approvals may be required from homeowner associations or governmental agencies.

6 SCE anticipates that some property owners will oppose removing
7 trees that are not dead or dying, for reasons such as perceived value, visual appearance,
8 sentimental value (e.g., grandfather planted the tree), shade, and environmental value. SCE will
9 try to negotiate with property owners and may need to provide replacement trees or other
10 inducements on a case-by-case basis. In certain situations, SCE may engage local fire agencies
11 to help persuade property owners of the criticality of removing the tree. Until SCE gains
12 experience in the field, it is difficult to determine the level of property owner opposition and how
13 best to overcome it.

14 (4) Risk-Based Tree Mitigation

15 While many of the trees that pose an expected threat to electrical
16 facilities may be mitigated through removal, other mitigation options include partial tree removal
17 where major branches are removed; palm frond removal; and monitoring where the tree does not
18 need removal or partial removal yet, but may in the future. It is anticipated that the mitigation
19 will be conducted by third-party contractors. Tree removal will be performed using a
20 combination of industry-standard methods such as: (1) directional felling, (2) climb and
21 sectionalize, (3) crane, and (4) high hazard.¹⁶⁵ Once the trees are felled, they are bucked and
22 slashed, and the logs and debris are removed from the site.

¹⁶⁵ The directional felling method is used when a tree can be brought safely to the ground by an experienced feller, typically without rigging, climbing, or vehicles (e.g., cranes, tractors). This is typically the least expensive method. The climb, sectionalize method is used for trees that, due to their size, condition and/or location, cannot be free-felled or worked with a crane. Under this method, an experienced feller climbs the tree and sections of the tree are brought to the ground by placing rigging in the tree. The crane method is used for trees that, due to their size, condition and/or location, require the use of overhead crane(s) and/or heavy equipment to safely bring the tree to the

1 As needed, SCE will also retain biological and archaeological
2 consulting firms to assess possible impacts to sensitive biological and cultural resources, as
3 required, in areas where SCE will be removing trees. These consultants will monitor and guide
4 work in potentially sensitive environmental areas; conduct field surveys; develop special training
5 for tree removal crews; and prepare documentation and reports.

6 In addition, there will be a Quality Assurance function independent
7 from the program management function that will confirm that contractors perform the required
8 work in accordance with their contract and SCE internal standards; verify that the inspectors
9 correctly identified subject trees and performed threat assessments; and verify the accuracy of
10 the inventory of mitigated trees.

11 e) Deployment Schedule

12 SCE is developing its operating plans for this effort with an anticipated
13 deployment in the first quarter of 2019. SCE estimates that it will target removing
14 approximately 7,500 trees in 2019, and 15,000 trees in 2020, with aspirational targets of up to
15 15,000 trees in 2019 and 30,000 trees in 2020.¹⁶⁶ Additional trees will be mitigated through
16 partial removal.

17 **2. Infrared Inspection Program**

18 a) Program Overview

19 SCE is developing a bi-annual Infrared (IR) Inspection Program for
20 overhead distribution lines within HFRA. Inspection findings will be prioritized per SCE's
21 Distribution Inspection Maintenance Program (DIMP) manual and given appropriate system
22 remediation timeframes. IR inspections will help increase safety by enhancing critical circuit
23 inspections and reducing fire safety hazards caused by potential equipment failures. These IR
24 inspections will also improve reliability.

¹⁶⁶ SCE's cost forecast assumes the high end, or aspirational, targets for 2019 and 2020.

1 b) What Exists Today

2 SCE visually inspects overhead facilities under General Orders 95 and
3 165. Visual inspections, while valuable, only detect issues visible to the naked eye, and cannot
4 reveal potential issues inside of sealed components or covered objects that may lead to
5 component failures posing a fire risk.

6 c) Effectiveness

7 SCE has evaluated the need for IR inspections on its distribution circuit.
8 The engineering review concluded these inspections offer a substantial benefit above standard
9 visual inspections by adding a layer of visibility into potential failures.

10 In 2017, SCE conducted an IR inspection program study involving a
11 statistically random sample of its overhead distribution system. This program study identified
12 “Hot Spots,” i.e., areas where there is a temperature difference between either two phases, or two
13 pieces of metal on one phase. These Hot Spots are not visible to the naked eye and can only be
14 detected by a trained thermographer using an IR camera. SCE removed and analyzed these Hot
15 Spots and determined they are reliable predictors of future component failures that, if
16 unaddressed, could potentially result in faults and customer outages.

17 Later, in 2018, SCE conducted an IR inspection of all remaining high fire
18 circuits and identified another 192 findings on these circuits. These 192 findings are potential
19 failures that were not visible during a visual inspection or other testing.


20 Figure IV-21 shows a connector in its normal state, which an inspector
21 would see during a General Order 165 inspection. Figure IV-22 shows the same connector as
22 seen during an infrared inspection and identified as a potential Hot Spot.

Figure IV-21
Visual Inspection View



1 Figure IV-22 below shows that the connector identified as Ar1, when
2 compared to the connector identified as Ar2, exhibits a temperature difference (Dt1) over 180
3 degrees Fahrenheit.

Figure IV-22
Infrared Inspection¹⁶⁷



4 d) Forecast

¹⁶⁷ DIMP utilizes a three priority rating system, designed to identify issues, and set appropriate timeframes for repair. Priority “1” conditions require immediate action, Priority “2” conditions are assigned a due date between zero to 12 months, based on the risk when located within High Fire Areas, and Priority “3” conditions are General Order 95/128 issues that are not an imminent safety and/or reliability risk.

Table IV-25
2018-2020 Infrared Inspection Program Costs ¹⁶⁸

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|-------------|---------------|---------------|---------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Infrared Inspection Program | - | 459 | 459 | \$ 918 |
| Grand Total | \$ - | \$ 459 | \$ 459 | \$ 918 |

1 e) Detailed Program Description

2 SCE is proposing a bi-annual IR inspection program, conducted at the
3 distribution circuit level and including circuits entirely, or partially, located in SCE’s HFRA.
4 SCE would conduct the majority of inspections by truck; however, a small percentage of the
5 system requires hiking or scanning from a helicopter. Truck inspections would use a two-person
6 crew, with the passenger aiming an infrared camera at overhead facilities as the driver drove the
7 area.¹⁶⁹ When the crew discovers a potential issue, they will stop and determine if it is a Hot
8 Spot. If confirmed, SCE will record relevant data (location, equipment, temperature reading, and
9 pictures (infrared and optical)) and schedule the equipment for remediation. Inspection findings
10 would be prioritized per SCE’s DIMP and given appropriate remediation timeframes.

11 SCE proposes to deploy IR Program inspections starting in 2019, with half
12 of the system circuits in HFRA inspected in 2019 and the remaining portions inspected in 2020.
13 SCE will use the results of the 2017 effort, and 2018-2020 data to determine the appropriate
14 inspection cycles for IR inspections going forward after 2020.

15 f) Alternatives Considered

16 IR inspections offer a substantial benefit above standard visual inspections
17 by adding a layer of visibility into potential equipment failures. As information gained from the
18 IR inspections is not available to the human eye, SCE at this time is not proposing a formal
19 alternative but expects to continue for review of IR cycles based upon additional data gained
20 through 2020.

¹⁶⁸ Refer to Work Paper Vol. 2 (Forecast - Infrared Inspection Program)

¹⁶⁹ Hiked inspections would use a two-person crew for safety and other reasons. Helicopter inspections would be done using a mounted camera with at least a two-person crew.

1 **3. PSPS Protocol Support Functions: Customer Communications and Line**
2 **Patrols**

3 a) Overview

4 As discussed in Section II.B.5, SCE’s PSPS protocol involves proactively
5 de-energizing portions of SCE’s system under extreme fire conditions. Per Resolution ESRB-8,
6 SCE is developing a customer awareness and communication strategy to inform stakeholders
7 about the program, obtain feedback, and provide notice of de-energization events. This includes
8 the town hall meetings SCE is conducting within areas potentially impacted by PSPS events and
9 direct customer mailings providing information about SCE’s PSPS protocol. To date, SCE has
10 already conducted town hall meetings in Santa Barbara, Camarillo, and elsewhere, with more
11 planned for the near future. SCE also is meeting with large business customers,
12 telecommunication providers, and water companies.

13 In addition, operationally, SCE will deploy line patrol crews to assess
14 circuit conditions prior to de-energization and also before restoring service to confirm it is safe to
15 re-energize.¹⁷⁰

16 b) What Exists Today

17 SCE has a communication framework in place to support emergency
18 outages. SCE’s existing notification capabilities must be enhanced to support the PSPS protocol
19 due to their lack of functionality and bandwidth. SCE requires a notification system that will
20 permit SCE to send out mass notifications in a timely manner. Moreover, SCE’s current
21 notification capabilities do not permit customized messages, including language preferences.

22 c) Effectiveness

23 (1) Customer Outreach Activities

24 SCE agrees with Resolution ESRB-8 that public outreach is an
25 important component of a utility’s pre-emptive power shutoff protocol. The Resolution requires

¹⁷⁰ Subject to fire or other public agency approval it is safe to enter impacted area.

1 SCE and other utilities to complete outreach efforts with state agencies, tribal governments, local
2 agencies, and representative from local communities within 90 days of the Resolution's effective
3 date, July 12, 2018. SCE is also required to submit a report to the Commission outlining its
4 public outreach efforts, and notification and mitigation plan. The plan must include
5 communication methods for informational workshops along with notification plans for when
6 protocols are engaged.

7 To meet this expectation, SCE is planning and conducting
8 customer outreach activities to increase stakeholders' awareness and understanding of SCE's
9 PSPS protocol. SCE's messaging emphasizes that this is a measure of "last resort" for the utility
10 but is nonetheless very important to have as an option in order to address and mitigate potential
11 fire threats and protect the overall safety of the communities in and around SCE's service area.

12 Just prior to, during, and following PSPS events, SCE expects
13 customers to contact SCE when they receive emergency outage notifications or otherwise
14 experience impacts associated with PSPS events.

15 The proposed customer notifications, dedicated customer website,
16 and town hall meetings, along with the Emergency Outage Notification System (EONS) system,
17 all support SCE's public outreach efforts on its PSPS protocol.

18 (2) Line Patrols

19 In addition to the customer outreach efforts discussed above, a
20 critical component of SCE's PSPS protocols is to assess potential extreme fire risk conditions
21 with the help of line patrols and monitoring functions (including troublemen and supporting
22 crews) in the field prior to making the decision to de-energize. In addition, SCE will utilize line
23 patrols to assess the condition of each circuit prior to re-energizing after the extreme conditions
24 have subsided as well in order to assist with assessing ignition risks and ensuring public safety
25 prior to re-energizing.

26 The line patrol activities described above in support of PSPS
27 protocols was not accounted for in SCE's GRC as budgeting was based upon line patrols focused

upon a specific circuit with a detected system issue (for example, circuit fault) as compared to a circuit group based upon the PSPS protocols.

d) Forecast

Table IV-26 below summarizes the forecast incremental costs in SCE’s request for PSPS Protocol Support Costs.

Table IV-26
2018-2020 PSPS Protocol Support Costs¹⁷¹

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|-----------------|-----------------|------------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Direct Customer Mailings | 978 | 990 | 990 | \$ 2,958 |
| Town Hall Community Meetings | 40 | 15 | 15 | \$ 71 |
| Emergency Outage Notification System | 660 | 1,004 | 1,004 | \$ 2,667 |
| Customer Contact Center Support | 440 | 440 | 440 | \$ 1,319 |
| Line Patrols | 1,048 | 1,048 | 1,048 | \$ 3,144 |
| Grand Total | \$ 3,165 | \$ 3,497 | \$ 3,497 | \$ 10,159 |

e) Detailed Program Description

(1) Customer Outreach Activities

Direct Customer Mailings: SCE, as part of its communication strategy supporting PSPS and promoting general wildfire threat awareness, has developed and is sending mailings to customers located within the HFRA. These mailings provide information on SCE’s PSPS protocol and invite customers to in-person community meetings for further discussion. SCE expects to continue the yearly mailings for at least the next three years to increase customer knowledge regarding PSPS and provide additional information regarding wildfire mitigation and general outage preparedness.

Town Hall Community Meetings: In further support of SCE’s customer engagement efforts, SCE is proactively sponsoring community “Town Hall” meetings that commenced in May 2018 and will continue through October 2018. These sessions are

¹⁷¹ Refer to Work Paper Vol. 2 (Forecast - Direct Customer Mailings; Forecast – Town Hall Community Meetings; Forecast - Emergency Outage Notification System; Forecast - Customer Contact Center Support; Forecast - Line Patrols)

1 intended to inform and assist in potential outage preparation and to offer a venue to answer
2 customer questions regarding PSPS. Beyond 2018, SCE primarily expects to hold community
3 meetings based on need or customer request throughout the service area.

4 **Emergency Outage Notification System (EONS):** In response to
5 urgent customer information needs during PSPS events and related outages, SCE has procured a
6 software solution provided by Message Broadcast that provides numerous benefits including:

- 7 • Ability to quickly and easily create and deliver customized
8 outage communications in the customers' digital channel(s) of
9 preference (Smartphone, SMS text, Email, TTY and Social
10 Media);
- 11 • Bandwidth to deliver up to 1.5 million digital outage
12 communications within one hour; and
- 13 • Ability to provide near real-time and historic reporting on
14 notifications sent to customers including the ability to see
15 actual customer messages for each communication.

16 In selecting Message Broadcast, SCE considered various criteria
17 including the ability to distribute high volumes of personalized communications in a short period
18 of time. EONS is expected to be fully deployed as of December 2018 and utilized going forward
19 in support of PSPS outage events. SCE selected Message Broadcast in support of the expected
20 need to send up to 1.5 million customer communications within 60 minutes that is not available
21 through SCE's existing systems. SCE's Automated Outage Communications (AOC) system was
22 originally built as a digital communications platform for contacting Medical Baseline and
23 Critical Care customers regarding Maintenance and Repair Outages. It has since been expanded
24 to include all SCE customer types and is at the peak of its potential capabilities. It does not have
25 the bandwidth to process and distribute Emergency Outage Notifications to customers in a short
26 period of time.

1 **Customer Contact Center Support:** In conjunction with the
2 increased PSPS patrols, SCE intends to provide support for customers during PSPS events via its
3 Customer Contact Center, but anticipates additional resources to support the incremental increase
4 call volumes associated with PSPS events.

5 (2) Line Patrols

6 SCE intends to deploy crews upon alert of a potential PSPS event
7 to assess extreme fire conditions as part of factors to be considered in making the decision to de-
8 energize. In addition, these additional crews will be needed to visually inspect primary
9 conductors and associated assets to determine that circuits have not sustained damage and are
10 safe to re-energize.

11 **4. Mobile Generator Deployment**

12 a) Program Overview

13 Because PSPS may disrupt electric services to critical electrical loads and
14 essential customers, SCE plans to contract the deployment of temporary mobile generators for
15 Essential Use¹⁷² customers to assist maintaining electric service for essential life, safety, and
16 public services on a case-by-case basis. These case-by-case decisions will be made by SCE's
17 IMT, based on the unique circumstances associated with each event. SCE's supply chain
18 organization performed a competitive solicitation for generator regional vendors who could
19 support mobile generator deployment, and will keep a list of generator vendors assigned to
20 different regions.

21 b) What Exists Today

22 Today, SCE does not have a specific program to provide mobile
23 generators for PSPS events. In support of Essential Use customers, SCE may elect to provide
24 temporary mobile generators to preserve critical public functions.

¹⁷² Essential Use customers are defined by the Commission as those that provide essential public health, safety, and security services. See General Order 166. Examples include agencies providing essential fire or police services, hospitals and skilled nursing facilities, communications utilities, facilities supporting fuel and transportation services, water and sewage treatment utilities, and others.

1 c) Effectiveness

2 In situations where SCE is preparing to initiate PSPS, the deployment of
3 mobile generators will support maintaining service to Essential Customer needs.

4 d) Forecast

5 Table IV-27 below summarizes the forecast incremental costs in SCE's
6 request for Mobile Generator Deployment.

Table IV-27
2018-2020 Mobile Generator Deployment Costs¹⁷³

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|---------------|---------------|---------------|---------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Mobile Generator Deployment | 137 | 137 | 137 | \$ 411 |
| Grand Total | \$ 137 | \$ 137 | \$ 137 | \$ 411 |

7 e) Detailed Program Description

8 Under the plan, SCE would begin to assess emergency generator
9 deployment once SCE's Business Resiliency weather staff forecasts or identifies extreme fire
10 conditions. Once these conditions become a credible threat, the Business Resiliency
11 organization will hold a situational awareness call with internal stakeholders (SCE Organizations
12 including: Transmission and Distribution, Customer Service, Public Affairs, etc.) to determine if
13 PSPS monitoring activities (in-field weather measurements coupled with microclimatic and
14 environmental assessments at the circuit level) should move forward. This decision will be
15 primarily based on a combination of weather forecasts (National Weather Service, SCE weather
16 stations, external weather data, etc.) and various environmental factors (fuel volume, fuel
17 moisture content, vegetation health/density, etc.) that are predicted or exist near the affected
18 circuits.

19 If the decision is made to move forward with PSPS monitoring, the
20 Electrical Services Incident Management Team (ESIMT) will be activated (if not already
21 deployed). The Operations Section Chief will work with the IMT Logistics Section to determine

¹⁷³ Refer to Work Paper Vol. 2 (Forecast - Mobile Generation Deployment)

1 availability and begin sourcing of generators for areas that may be affected by a PSPS event,
2 while the PSPS Task Force (special team tasked with assessing the impacts of executing a PSPS
3 event) begins to coordinate the need and sizing of generators to be deployed.

4 SCE's Supply Chain Organization performed a competitive solicitation for
5 generator regional vendors who could support mobile generator deployment to which a mobile
6 generator selection vendor list was created. SCE's Logistics Section will have a list of generator
7 vendors assigned to different regions. The Logistics Section is in charge of identifying generator
8 source(s) and provide preliminary estimates of when the generators will become available. For
9 generators 500 kW and below, the expected turnaround time is between two to three hours from
10 initial call until the generator is delivered on-site. Generators greater than 500 kW typically can
11 be delivered within 24 hours.

12 f) Alternatives Considered

13 SCE considered two other mobile generator alternatives, listed below in
14 Table IV-28. The first alternative involves providing mobile generation solely to Critical Care
15 customers (138 customers assumed for purposes of alternative deployment). This results in a
16 projected increase of \$939,315 annually. However, this alternative would require a significant
17 amount of Qualified Electrical Workers to install and disconnect the generators, thus precluding
18 them from providing their critical functions and support to SCE's service area during a PSPS
19 event (monitoring, patrolling, troubleshooting, repairs, etc.).

20 The second alternative includes providing mobile generation for all
21 Medical Baseline and Essential Use customers (853 customers assumed for purposes of
22 alternative development). This results in a projected increase of \$6,820,515 annually and would
23 also stretch existing resources similar to alternative one. SCE is, however, proactively
24 addressing these segments of Medical Baseline customers through education/outreach materials
25 and workshops, urging these customers to plan ahead for outages—regardless of cause—and to
26 have adequate backup generation or uninterruptible power supplies to power critically important
27 medical devices.

Table IV-28
Mobile Generator Deployment Alternatives

| Alternatives | Estimated Number of Circuits Proactively De-energized Annually | Essential Customers Proactively De-energized Annually | Critical Care Customers Proactively De-energized Annually | Medical Baseline Customers Proactively De-energized Annually | Total Mobile Generators Needed | Total Annual Cost | Difference from Proposal |
|--------------|--|---|---|--|--------------------------------|-------------------|--------------------------|
| Alt 1 | 60 | n/a | 138 | n/a | 138 | \$ 1,076,400 | \$ 939,315 |
| Alt 2 | 60 | 39 | 138 | 715 | 892 | \$ 6,957,600 | \$ 6,820,515 |

5. Portable Community Power Trailers

a) Program Overview

SCE’s customers may be without power for extended periods due to wildfire mitigation efforts, including PSPS activation and/or more planned outages associated with hardening the grid and installing technologies that reduce wildfire risk. Although SCE has developed a public outreach plan in support of PSPS, including overall wildfire awareness and preparation, SCE expects that some customers will need some assistance in receiving critical messages from SCE, public agencies, first responders, news agencies, social media, etc. SCE’s proposed Portable Community Power Trailers (PCPTs)—towable trailers equipped with a clean, hybrid renewable generation system and energy storage—can be deployed within three to four hours to any HFRA community to provide outreach and support to affected customers.

b) What Exists Today

SCE’s current customer outreach efforts consist mainly of sending a team of SCE employees to incident centers to interact with customers, answer questions, share helpful information, and, at times, pass out LED flashlights, water, etc. This typically involves setting up portable, temporary shade structures, tables, and chairs and staffing the event with various employees from across the utility.

However, while this solution may be acceptable when responding to incidents after they have occurred or after inclement weather has passed, it is not suitable to have temporary shade structures, tables, chairs, and other miscellaneous items staged outside during

high fire conditions, (e.g., when there are 50+ mile an hour winds). A robust, stable, and strong platform solution provides a safe and resilient platform to connect with the communities SCE serves in order to provide needed amenities during PSPS events and extended repair or maintenance outages.

c) Effectiveness

As referenced in Resolution ESRB-8: “Increased coordination, communication and public education can be effective measures to increase public safety and minimize adverse impact from de-energization.” SCE agrees, and considers in-situ outreach an important component of event coordination, communication, and outreach. Moreover, these Portable Community Power Trailers will have a reliable and clean source of back-up power so that customers can plug in and charge their personal devices (mobile phones, tablets, laptops, etc.) so that they can continue to receive information/updates from SCE about their outage, listen for relevant public safety broadcasts, and/or connect with friends and family concerned with their well-being.

d) Forecast

Table IV-29 below summarizes the forecast incremental costs in SCE’s request for PCPTs.

***Table IV-29
2018-2020 Portable Community Power Trailer Unit Costs ¹⁷⁴***

| O&M (2018 Constant \$000) | | | | |
|--------------------------------------|-----------------|-------------|-------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Portable Community Power Trailers | 1,102 | 9 | 9 | \$ 1,120 |
| Grand Total | \$ 1,102 | \$ 9 | \$ 9 | \$ 1,120 |

e) Detailed Program Description

SCE forecasts the need for eight PCPTs to enable rapid response (approximately three to four hours) to community needs across its service area. The PCPTs

¹⁷⁴ Refer to Work Paper Vol. 2 (Forecast - Portable Community Power Trailers)


1 would be located at strategic locations throughout SCE’s 50,000 square mile service area, with a
2 particular focus on deployment in HFRA.

3 The two-axle, 10-foot industrial trailers would be equipped with a clean
4 hybrid generation and energy storage system, consisting of a deployable 2.25 kW photovoltaic
5 (PV) array, 6.5 kW liquid propane generator, 130 lbs. of propane fuel, 6 kW 120/240 VAC
6 utility interactive inverter/charger, and 10.7 kWh AGM battery storage system. With the PV
7 array deployed and outriggers extended, the PCPT can be deployed in winds in excess of 100
8 mph. Moreover, depending on electrical demand, the unit can easily run on battery energy
9 storage alone, reducing the need to run the fossil fueled backup generators for much of the day
10 while in service.

11 The primary goal of the PCPTs is to provide charging stations for mobile
12 phones, laptops, and tablets—personal devices that customers rely upon for important
13 notifications and updates from SCE about their outage, relevant public safety broadcasts, and to
14 stay in contact with family and friends. A mobile hot spot may be provided for those without
15 mobile broadband connections, and a large TV screen will stream local news channels via local
16 online TV streaming. The PCPTs will also be outfitted with a fire extinguisher, first aid kit, and
17 informational brochures and resources. Depending on the type of event supported and weather
18 conditions, water and/or snacks may be provided on a case-by-case basis.

19 The PCPTs would be deployed based on direction from the IMT Incident
20 Commander (IC) when SCE’s Weather Services team forecasts extreme fire conditions and
21 monitoring of impacted areas begins. PCPTs would ideally be onsite at least 12-24 hours before
22 power is shutoff, and stay deployed until after the event ends and the IMT determines there is no
23 need for further outreach. If there is significant damage to SCE assets as a result of the storm
24 and it is safe to stay operational, the PCPT team may elect to stay in the community to
25 communicate about repair efforts and continue supporting the community until repairs can be
26 effected. Figure IV-23 shows the proposed deployment of the PCPTs.

**Figure IV-23
Portable Community Power Trailer Unit Deployment**



1. (85) Bishop/Mammoth Service Center
2. (51) Tulare Service Center
3. (52) Tehachapi Service Center
4. (49) Santa Barbara Service Center
5. (59) Valencia Service Center
6. (22) Montebello Service Center
7. (31) Redlands Service Center
8. (88) Wildomar Service Center

f) Alternatives Considered

SCE considered two lower cost alternatives. Alternative one consisted of a much smaller, single axle trailer, but this option provided minimal storage space for ancillary equipment and outreach materials and little to no space for staff to take a break from the elements, and for these reasons was deemed inadequate.

Alternative two consisted of the hybrid renewable generation system with backup generator and battery storage capability, but on a flatbed trailer with no enclosed storage space to hold and protect outreach materials/equipment or allow staff to take a break from the elements. For these reasons, Alternative two was also deemed inadequate.

E. Wildfire Mitigation Program Study Costs

Table IV-30 below summarizes the forecast incremental costs in SCE’s request for Wildfire Mitigation Program Studies.

**Table IV-30
2018-2020 Studies Costs¹⁷⁵**

| O&M (2018 Constant \$000) | | | | |
|--|---------------|---------------|---------------|-----------------|
| Deliverable | 2018 | 2019 | 2020 | Total |
| Distribution Fault Anticipation Technology Study | 198 | 68 | 40 | \$ 306 |
| Advanced Unmanned Aerial Systems Study | 113 | 453 | 340 | \$ 907 |
| High Resolution Weather Related Study | 200 | - | - | \$ 200 |
| Grand Total | \$ 512 | \$ 521 | \$ 380 | \$ 1,413 |

1. Distribution Fault Anticipation Technology Program Study

SCE plans to deploy and perform a program study on Distribution Fault Anticipation (DFA) technology for ten distribution circuits located in HFRA.¹⁷⁶ This technology was developed collaboratively by Texas A&M Engineering and the Electric Power Research Institute, Inc. (EPRI). SCE currently receives line circuit data from monitoring and protection systems and performs utility preventive maintenance accordingly. Data gained from the DFA deployment could be used to further assist with the diagnosis of potential system failures in support of equipment repair/replacement and reduction of potential fire ignition risks and reliability impacts.

DFA allows for continuously monitoring circuit current and voltage waveforms, from utility substation current and potential transformers (CT’s and PT’s, respectively) and

¹⁷⁵ Refer to Work Paper Vol. 2 (Forecast - High Resolution Weather Related Study; Forecast - Distribution Fault Anticipation Technology Program Study; Forecast - Advanced Unmanned Aerial Systems Study)

¹⁷⁶ The program study will be performed on a twelve month period.

1 applying digital signal processing, pattern matching, along with other software techniques to
2 report ongoing and developing circuit events and conditions that could be used in support of
3 maintenance decisions as appropriate.

4 The DFA module will be located within the substation and monitoring circuits
5 impacts as the circuits leave the station. SCE intends to study the information received from the
6 DFA program study in determining future deployment decisions to further assist in support of
7 equipment maintenance reviews. The DFA module will be located within the substation and will
8 monitor circuits impacts as the circuits leave the station. SCE intends to study the information
9 received from the DFA program study in determination of future deployment decisions to further
10 assist in support of equipment reviews.

11 **2. Advanced Unmanned Aerial Systems Study**

12 The Advanced Unmanned Aerial Systems (UAS) study project will inform and
13 advance SCE's existing UAS program by exploring the capabilities of Beyond Visual Line of
14 Sight (BVLOS) flight. SCE's UAS program is developing the capability to expedite patrolling
15 utility lines following a PSPS event or other extended outage, to more quickly and safely restore
16 power to its customers.¹⁷⁷ SCE plans to contract with an approved UAS vendor with significant
17 experience in BVLOS flight in order to explore these capabilities, better understand how to
18 successfully navigate the restrictive Federal Aviation Administration (FAA) regulations
19 governing BVLOS flight, and lay the foundation to establish an internal BVLOS UAS program.

20 Today, SCE's Aircraft Operations department currently owns and operates three
21 UAVs, in addition to a small fleet of helicopters, for conducting a wide variety of operations
22 (e.g., pole sets, inspections, line patrols, etc.) across the utility. Aircraft Operations is routinely
23 called upon to conduct circuit patrols of utility lines that are particularly long, traverse
24 mountainous or heavily vegetated terrain, and/or traverse terrain that is difficult to access via the
25 ground. SCE currently utilizes helicopters to conduct select circuit patrols following extreme

¹⁷⁷ Outages following extreme wind or weather events require a patrol of SCE's lines before they can be re-energized.

1 weather conditions when called upon by SCE's Grid Operations department, who may have
2 difficulty accessing these lines for a visual inspection or may otherwise be resource constrained.
3 It is particularly important to patrol lines prior to re-energization following an extreme wind or
4 weather event in case foreign objects have come into contact with electrical lines (which could
5 ignite fires upon re-energization) or lines have been knocked to the ground due to extreme
6 weather. UAVs are currently not used for circuit patrols due to FAA regulations that generally
7 require the UAV to be within line of sight of the operator or pilot.

8 As described earlier in this testimony, SCE may need to leverage the PSPS
9 protocol to address increasing wildfire risk. In some cases, SCE estimates that PSPS outages
10 could last up to 72 hours. Therefore, it is important to restore power to customers quickly and
11 safely following extreme fire and weather conditions. The ability to conduct circuit patrols via
12 UAV operating BVLOS is expected to be a more efficient and cost-effective means to inspect
13 electrical assets, especially for large-scale outages when resources may already be constrained.
14 Moreover, the lessons learned from the pilot project can be applied in the future for developing
15 an in-house BVLOS program to conduct other important utility work (e.g., equipment
16 inspections, asset mapping, etc.).

17 Since the areas or circuits SCE wishes to patrol are already difficult to access, this
18 currently precludes the use of drones as an efficient means of conducting a circuit patrol.
19 Additionally, while traditional aircraft can be an efficient means of inspecting assets, it is
20 relatively expensive (compared to a UAV) and helicopters are much better suited to fully utilize
21 their additional payload capability for more heavy-duty restoration efforts. UAVs take
22 advantage of the efficiency of traditional manned aircraft inspections but at a much lower cost
23 due to the lower cost of the resources required to operate and maintain them. Exploring, and
24 ultimately achieving, the ability to perform BVLOS flights via UAS would be a more efficient
25 and affordable way to conduct circuit patrols following a PSPS event or extended outage in an
26 effort to safely expedite the restoration of power to SCE customers. The ability to perform

1 BVLOS UAV flights could provide a valuable new tool given the diverse geography of SCE's
2 service area.

3 **3. High Resolution Weather Forecast Study**

4 From September 2018 through September 2019, SCE will perform a program
5 study in support of a high-resolution weather forecast tool providing near-real time, high-
6 resolution operational weather forecasts for weather parameters such as precipitation, wind speed
7 and direction, wind gust, temperature, and humidity. This study will gather weather information
8 and map it against SCE infrastructure, via an interactive web application. Furthermore, it is
9 expected to notify SCE personnel about potential weather hazards.

10 The high resolution forecast tool is expected to incorporate a combination of
11 traditional weather models and proprietary technology to increase forecast accuracy, confidence,
12 and resolution. More specifically, it utilizes information gained from cellular phone towers,
13 along with other inputs, to provide enhanced weather forecasting that is more accurate than
14 existing forecast capabilities. Forecast resolution and temporal granularity is expected to provide
15 unique information that existing forecast products do not currently offer. These data give the
16 user the ability to drill down to specific locations with high confidence and accuracy.

17 Forecasts produced under this program study are also expected to be easily
18 incorporated into and enhance many of SCE's system situational awareness reports utilized to
19 support emergency response and related planning efforts. This includes pre-staging response
20 personnel and/or taking preemptive action to provide for the safe operation of SCE's system by
21 cancelling planned outages or executing PSPS during dangerous or extreme weather. SCE's
22 main focus will be using the data to make wildfire mitigation-related operational decisions, such
23 as cancelling planned maintenance during high fire weather conditions (e.g., high winds coupled
24 with high temperatures and low humidity). The high-resolution data will also help SCE evaluate
25 new models, reports, and indices used to communicate risks around severe weather events.

26 SCE will track the accuracy of forecasts produced under this program study
27 against forecasts received from traditional weather models and vendors. These accuracy reports

- 1 will inform future decisions about forecast modeling use and supporting companies, and SCE's
- 2 long-term use of this product.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

V.

COST RECOVERY

A. Summary of SCE’s Ratemaking Proposal

This Chapter presents SCE’s ratemaking proposal for the GS&RP. SCE proposes to establish: (1) an initial GS&RPMA to be effective on September 10, 2018,¹⁷⁸ the date of this Application, and (2) the GS&RPBA, effective upon a final Commission decision. Both accounts will record the GS&RP incremental actual O&M expenses and capital-related revenue requirements (e.g., depreciation, return on rate base, property taxes, and income taxes) to provide for the recovery of all recorded GS&RP-related costs. Amounts recorded in the GS&RPMA would be transferred to the GS&RPBA upon a final Commission decision. Beginning in 2019, SCE requests to include in distribution rates a forecast GS&RP revenue requirement for each year up until the time these revenue requirements are included in SCE’s 2021 GRC.

SCE respectfully requests the Commission authorize the GS&RPMA immediately, so the utility can begin recording expenses associated with implementing critical program activities, including deploying covered conductor throughout circuits in HFRA. However, SCE will not recover in rates amounts recorded in the GS&RPMA until approved by the Commission in this proceeding.

Because the Commission will perform a full reasonableness review of the scope of the GS&RP activities and forecast costs in this proceeding, SCE requests the Commission establish a “reasonableness threshold” be set at 115% of the total GS&RP capital and O&M forecast of \$582 million (2018 \$) over the 2018 – 2020 time period, or \$670 million (2018 \$). SCE proposes that the total recorded spend up to the \$670 million (2018 \$) be deemed reasonable and any amount of total spend recorded in excess of these amounts will be subject to a traditional reasonableness review in a future application. To further support a “reasonableness threshold,” SCE proposes that no further reasonableness of the GS&RP is required if: (1) SCE GS&RP

¹⁷⁸ SCE’s forecast costs are as of September 10, 2018 filing date.

1 spending is less than or equal to the reasonableness threshold and (2) SCE manages the cost per
2 circuit mile for the covered conductor program to up to 115% of the estimated amount supported
3 in Chapter IV, Section B, or \$428k/mile in 2018. If the cost for the covered conductor program
4 exceeds \$493k/mile, escalated appropriately, then SCE will file an application to support why
5 the cost to install covered conductors were greater than that threshold.

6 In addition to a detailed description of the entries and operation of the GS&RPMA and
7 the GS&RPBA and proposed reasonableness standards, this chapter also presents an overview of
8 currently authorized or pending wildfire risk reduction ratemaking mechanisms.

9 **B. Overview of SCE's Currently Authorized or Pending Ratemaking Mechanisms**
10 **Associated with Wildfire Risk Reduction Cost Recovery**

11 To date, SCE has requested incremental costs as the result of wildfires (e.g., SCE's
12 March 14, 2018 "Z-Factor" advice letter for incremental wildfire insurance cost), and the
13 Commission has previously authorized ratemaking accounts associated with the recovery of
14 certain costs associated with mitigating fire risk (e.g., Fire Hazard Prevention Memorandum
15 Account (FHPMA)). This Chapter addresses where those costs, which do not include the costs
16 requested in this Application that are associated with the GS&RP, are being addressed.

17 **1. Z-Factor**

18 SCE's authorized Z-Factor mechanism is a post-test year ratemaking mechanism
19 for significant events outside of SCE's control and the normal course of business. Preliminary
20 Statement Part AAA provides for Z-Factor recovery through a Tier 3 advice filing with the
21 burden of proof on SCE to prove that its request satisfies stated Z-Factor criteria. Cost recovery
22 is first subject to a \$10 million deductible and costs must: be related to exogenous event; be
23 beyond management's control; not be a normal part of business; disproportionately impact the
24 company; be reasonable; and satisfy other, similar criteria.

25 On December 29, 2017, SCE sent a notification letter to the Commission's
26 Executive Director explaining the urgent need to replenish its wildfire insurance in 2017 and
27 provided notice of SCE's intent to establish a Z-factor for costs associated with incremental

1 wildfire-related liability insurance related to the December 2017 California wildfires. On March
2 14, 2018, SCE filed a Tier 3 Advice Letter 3768-E requesting Z-Factor recovery of \$107 million
3 of net premium costs incurred to obtain a 12-month, \$300 million wildfire insurance policy for
4 2018. SCE obtained the insurance policy from the only insurer in the global market willing to
5 provide this much capacity of sufficiently broad insurance coverage this low in the insurance
6 “tower” for a California private electric utility. Per SCE’s advice letter, this mechanism would
7 currently only cover SCE’s purchase of additional wildfire insurance in December 2017. Advice
8 Letter 3768-E remains pending before the Commission for approval.

9 **2. Wildfire Expense Memorandum Account (WEMA)**

10 On April 3, 2018, SCE filed an application to seek authority to establish the
11 WEMA. If approved by the Commission, this account will be used to track incremental
12 unreimbursed wildfire liability-related costs. Specifically, in its application, SCE proposed to
13 create a WEMA to track all amounts paid by SCE that are the result of a wildfire, and that were
14 not previously authorized in SCE’s GRC, including: (1) payments to satisfy wildfire claims,
15 including any co-insurance, deductibles, and other insurance expense paid by SCE; (2) outside
16 legal expenses incurred in the defense of wildfire claims; (3) payments made for wildfire
17 insurance and related risk-transfer mechanisms; and (4) the cost of financing these amounts.¹⁷⁹

18 The costs that will record to this account are inherently different from the costs
19 included in this application. Moreover, the Commission has not yet approved SCE’s WEMA
20 application. As such, no costs have been recorded to SCE’s proposed WEMA.

21 **3. Catastrophic Event Memorandum Account (CEMA) – 2015 – 2016 Drought**
22 **and 2016 Fires**

23 Commission Resolution ESRB-4 directed the IOUs to reduce the likelihood of
24 fires caused by their facilities by increasing vegetation inspections and removing hazardous,
25 dead and sick trees and other vegetation near power lines and poles. In addition the IOUs were

¹⁷⁹ A.18-04-001, p. 3.

1 directed to share resources with CalFire to staff lookouts near IOU property and to clear access
2 roads under power lines for fire truck access.

3 On March 1, 2018, SCE filed its CEMA Application (A.)18-03-004 requesting
4 that the Commission authorize SCE to recover costs recorded in SCE's CEMA associated with
5 the 2015-2016 drought, the 2016 Erskine Firestorm, the 2016 Sand Firestorm, and the 2016 Blue
6 Cut Firestorm. The Governor issued a State of Emergency Proclamation for each of these events
7 making them eligible for incremental cost recovery. Pursuant to California Public Utilities Code
8 Section 454.9, SCE only requested to recover the costs it incurred to: (1) restore service to
9 customers, (2) repair, replace, or restore damaged facilities, and (3) comply with governmental
10 agency orders in connection with events declared disasters by competent state or federal
11 authorities.¹⁸⁰

12 In its testimony, SCE (1) described the CEMA Drought and the efforts SCE took
13 to mitigate the effect of the Drought on SCE's systems; (2) described each of the CEMA
14 Firestorm Events referenced above and the extensive damage to SCE's infrastructure caused by
15 these severe storms; (3) described the actions SCE took to respond to these catastrophes,
16 including restoring service to its affected customers; (4) documented the incremental capital-
17 related costs SCE incurred in restoring service and repairing, replacing, or restoring its
18 infrastructure after each CEMA Firestorm Event; and (5) requested authority from the
19 Commission to recover in rates the incremental Drought O&M and Firestorm-related capital
20 revenue requirement recorded in its CEMA subaccounts.

21 The vegetation management activities as described in Section IV.D.1 of this
22 testimony are above and beyond the activities described in Resolution ESRB-4 and therefore
23 SCE is seeking recovery of these incremental vegetation management costs in the GS&RPBA
24 (or, as noted earlier, SCE believes that alternatively these costs could be recorded in the Drought
25 CEMA).

¹⁸⁰ State of Emergency Proclamations were issued by the Governor's Office for each of the CEMA events.

1 **4. Fire Hazard Prevention Memorandum Account (FHPMA)**

2 On October 1, 2009, SCE filed Advice Letter 2387-E to establish the FHPMA in
3 compliance with D.09-08-029.¹⁸¹ The original purpose of this account was to track the
4 difference between all fire hazard prevention costs that related to activities necessary to
5 implement the requirements of D.09-08-029, and the amounts previously authorized in SCE's
6 2009 GRC. Specifically, D.09-08-029 authorized SCE to track: (1) expenses associated with
7 vegetation management; (2) increased expenses related to the maintenance program, inspection
8 program and patrolling requirements; (3) expenses incurred in designing, constructing, and
9 maintaining facilities to mitigate fire hazards in high speed wind areas; and (4) other expenses
10 incurred in implementing D.09-08-029.

11 In SCE's 2012 GRC, SCE included a forecast for these activities. As such, after
12 the 2012 GRC Decision was issued, the FHPMA was no longer used to track the costs for these
13 activities. In January 2012, the Commission issued D.12-01-032 in Phase 2 of OIR 08-11-005.
14 Utilities were required to prepare and issue a fire prevention plan. In 2015, the Commission
15 issued R.15-05-006 to develop and adopt fire threat maps and fire safety regulations. This
16 rulemaking significantly lessened the scope of activities that SCE was authorized to track in the
17 FHPMA.

18 The Commission adopted D.17-12-024 on December 21, 2017 adopting new
19 regulations to enhance the fire safety of overhead electric power lines in high fire-threat areas.
20 Specifically, this decision added a new high fire-threat district to General Order (GO) 95. In
21 addition, it amends various GO 95 rules to increase line clearance and inspection cycles. It also
22 required each electric IOU to prepare a fire-prevention plan. This decision authorizes electric
23 IOUs to track the costs in the FHPMA incurred to implement the regulations adopted by D.17-
24 12-024.¹⁸² The FHPMA will remain open for R.15-05-006 costs until the first GRC after the

¹⁸¹ The Commission issued D.09-08-029, Measures to Reduce Fire Hazards in California before the 2009 Fall Fire Season, in Phase 1 of Order Instituting Rulemaking (OIR) 08-11-005.

¹⁸² See D.17-12-024 p. 4.

1 rulemaking proceeding is closed. Recovery of the FHPMA ending balance may be sought by
2 application.

3 The Commission closed R.15-05-006 in January 2018 and therefore SCE
4 currently anticipates it will seek recovery of amounts recorded in its FHPMA in the 2021 GRC.

5 **5. Wildfires Customer Protections Memorandum Account (WCPMA)**

6 On November 27, 2017, SCE filed Advice Letter 3707-E pursuant to Resolution
7 M-4833 to implement emergency residential protections for affected SCE residential customers
8 in Orange County affected by the two Canyon fires. In compliance with Ordering Paragraph 4 of
9 the Resolution, SCE established the Wildfires Customer Protections Memorandum Account
10 (WCPMA) to record costs associated with customer protections pursuant to Resolution M-4833.
11 These protections will be in effect for one year until November 9, 2018. Specifically, the
12 Resolution orders the implementation of the following emergency residential protections for one
13 year:

- 14 1. Waive Service Disconnection, Security Deposit, and Late Fees for affected
15 wildfire residents;
- 16 2. Expedite move-in and move-out service requests;
- 17 3. Stop estimated energy usage for billing attributed to the time when the
18 home/unit was unoccupied because of the wildfires;
- 19 4. Implement payment plan options; and
- 20 5. Support low-income customers affected by the December 2017 wildfires.

21 On January 26, 2018, the Commission's Executive Director issued a letter to the
22 energy utilities directing the utilities to propose similar relief as adopted by Resolution M-4833
23 for their non-residential customers as well. As such, SCE filed Advice Letter 3707-E-A to
24 provide protection measures for both residential and non-residential customers affected by the
25 wildfires in Orange County. Advice Letter 3707-E-A was approved by Energy Division on
26 January 2, 2018.

1 On January 26, 2018, SCE filed Advice Letter 3733-E to implement emergency
2 customer protections for residential and non-residential customers affected by the December
3 2017 wildfires and January 2018 mudslides pursuant to Resolution M-4835. As such, SCE
4 revised the WCPMA to include residential and non-residential customers affected by the Thomas
5 Fire, Montecito mudslides, Creek and Rye fires, and the Liberty fire. The WCPMA will remain
6 in effect for one year until January 11, 2019, unless otherwise specified or extended by order of
7 the Commission per Resolution M-4835. Advice Letter 3733-E was approved by the Energy
8 Division on March 7, 2018.

9 **6. 2018 GRC**

10 SCE did not include any GS&RP-related costs in its 2018 GRC revenue
11 requirement, therefore SCE will record GS&RP costs in the GS&RPBA over the 2018 GRC
12 period. In the 2021 GRC, SCE anticipates it will then include on-going GS&RP-related costs in
13 the test year revenue requirement, which will also include the on-going capital-related revenue
14 requirement for the capital expenditures incurred prior to 2021.

15 **C. Description of Grid Resiliency Program Memorandum Account**

16 To enable recovery of SCE's actual incremental revenue requirements, SCE seeks to
17 establish the GS&RPMA to be effective on the date SCE files its Application. The initial
18 revenue requirements associated with incremental costs incurred for the GS&RP will be recorded
19 in the GS&RPMA. Similar to all Commission-approved memorandum accounts, the
20 GS&RPMA will protect against retroactive ratemaking concerns yet will not guarantee recovery
21 in rates of any of the recorded costs prior to Commission review and approval in this application.
22 SCE proposes to only use this interim ratemaking (i.e., the GS&RPMA) to record incremental
23 costs prior to a Commission decision in the proceeding. Recovery of the balance in the
24 GS&RPMA will be through the GS&RPBA as discussed in the following section.

25 SCE requests that the GS&RPMA be made effective as of the date of this filing so that
26 SCE may expeditiously track costs in the account that it anticipates incurring during the
27 pendency of the Commission's disposition of this application.

1 **D. Description of Grid Resiliency Program Balancing Account**

2 The two-way GS&RPBA will record the actual O&M, payroll taxes, and capital-related
3 revenue requirement (e.g., depreciation, return on rate base, property taxes, and income taxes) on
4 a monthly basis. The GS&RPBA will be effective upon the Commission’s final decision in this
5 proceeding.

6 Each month, SCE will record in the GS&RPBA:

- 7 • An initial transfer of the recorded activity in the GS&RPMA (debit);
- 8 • Capital-related revenue requirements (debit), including depreciation, return on rate
9 base, property taxes, and income taxes based on recorded capital additions and rate
10 base; and
- 11 • Recorded incremental O&M costs (debit)

12 All recorded incremental costs will include provisions for overhead loadings on direct
13 labor dollars, to account for items such as benefits and payroll taxes.¹⁸³ In addition, interest
14 expense will accrue each month in the GS&RPBA at the three-month commercial paper rate
15 until the year-end transfer of the GS&RPBA balance to the BRRBA.

16 **E. Proposed Reasonableness Review of GS&RP Expenditures Forecast**

17 **1. Proposed Reasonableness Threshold**

18 Because the Commission will perform a full reasonableness review of the scope
19 of the GS&RP activities and forecast costs in this proceeding, SCE requests the Commission
20 establish a “reasonableness threshold” for all recorded amounts. In this Application, SCE
21 proposes a GS&RP reasonableness threshold be set at 115% of the total GS&RP capital and
22 O&M forecast of \$582 million (2018 \$) over the 2018 – 2020 time period, or \$670 million (2018
23 \$). SCE proposes that the total recorded spend up to the \$670 million (2018 constant \$) be

¹⁸³ Overhead loading factors will be based on authorized rates. The revenue requirements presented herein reflect all SCE labor loadings. However, to the extent a particular labor loading is currently accounted for in another balancing account (e.g., Pensions, Post-Employment Benefits Other Than Pensions (PBOPS), Medical, Dental and Vision), SCE will not include these labor loadings in the recorded operation of the GS&RPBA.

1 deemed reasonable and any amount of total spend recorded in excess of these amounts will be
2 subject to a traditional reasonableness review in a future application. To further support a
3 “reasonableness threshold,” SCE proposes that no further reasonableness of the GS&RP is
4 required if: (1) SCE GS&RP spending is less than or equal to the reasonableness threshold and
5 (2) SCE manages the cost per circuit mile for the covered conductor program to up to 115% of
6 the estimated amount supported in Chapter IV, Section B, or \$428k/circuit mile¹⁸⁴. If the cost
7 for the covered conductor program exceeds \$493k/mile, then SCE will file an application to
8 support why the cost to install covered conductors were greater than that threshold. The
9 threshold defined is supported by generally accepted cost engineering practices and considers the
10 level of scope definition, detailed engineering, detail of unit costs, and potential accuracy ranges.

11 **2. Proposed Review Process**

12 The Commission’s review of GS&RP program costs spent up to the
13 reasonableness threshold will occur in the annual ERRA Review proceedings to ensure account
14 entries are stated correctly and associated with GS&RP activities as defined and approved by the
15 Commission.

16 **F. Rate Recovery of Recorded GS&RP Revenue Requirements**

17 To help ensure that customers only pay the actual GS&RP revenue requirements, SCE
18 proposes to transfer the revenue requirement recorded in the GS&RPBA to the distribution sub-
19 account of the Base Revenue Requirement Balancing Account (BRRBA) on an annual basis.
20 Using this approach, any difference between the forecast GS&RP revenue requirements included
21 in rate levels and the actual recorded GS&RP revenue requirements will be trued up in the
22 BRRBA. This proposed ratemaking provides that no more and no less than the reasonable
23 revenue requirements associated with the GS&RP activities will ultimately be collected from
24 customers. Any over-collection recorded in the BRRBA at the end of each year will be refunded

¹⁸⁴ Based on 592 circuit miles.

to customers in the subsequent year. Similarly, any undercollection recorded in the BRRBA at the end of each year will be recovered from customers in the subsequent year.

G. Forecast GS&RP Revenue Requirements

Table V-31 below presents SCE’s forecast 2018-2020 revenue requirements for the GS&RP:

Table V-31
Forecast 2018-2020 GS&RP Programs Revenue Requirements
(in Millions of Nominal Dollars)¹⁸⁵

| Total Grid Resiliency Thousands of Nominal Dollars | | | | | |
|---|----------------------------------|-----------------|-----------------|------------------|------------------|
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | O&M | 8,138 | 54,643 | 118,314 | \$181,094 |
| 2 | Franchise Fees & Uncollectibles | 120 | 773 | 1,735 | \$2,629 |
| 3 | Depreciation | 1,551 | 5,904 | 14,162 | \$21,616 |
| 4 | Taxes | (1,298) | (1,991) | (4,048) | (\$7,337) |
| 5 | Return | 1,979 | 8,022 | 21,070 | \$31,071 |
| 6 | Total Revenue Requirement | \$10,490 | \$67,349 | \$151,233 | \$229,072 |

Beginning in 2019, SCE requests to include in distribution rates a forecast GS&RP revenue requirement for each year up until the time these revenue requirements are included in SCE’s 2021 GRC. SCE proposes to include the GS&RP forecast revenue requirement in an advice letter to be filed in November of each year beginning in November 2018. In the annual advice letters, SCE will update the GS&RP revenue requirements to reflect the prior year recorded capital expenditures, any forecast capital expenditure changes in the following year, and also the most recently adopted rate of return on rate base, franchise fees and uncollectible rates, and tax rates. SCE will then consolidate the changes in its distribution rates to reflect these updated GS&RP revenue requirements in conjunction with other authorized rate level changes in its January 1 consolidated revenue requirement and rate change advice letter.

1. Capital Expenditures and Additions

SCE’s forecasted revenue requirement as shown in Table V-31 above were derived based on estimated direct capital expenditures of \$407 million (2018 constant \$), as

¹⁸⁵ Refer to Work Paper Vol. 2 (Revenue Requirement)

supported in Section IV of this testimony and shows estimated direct capital expenditures escalated for each calendar year. The total estimated expenditures of \$407 million are forecast to close to plant-in-service as the assets are placed in service.

Table V-32
Forecast 2018-2020 GS&RP Capital Expenditures

| Capital (2018 Constant \$000) | | | | | |
|--------------------------------------|---|-----------------|------------------|------------------|------------------|
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | Grid Hardening | | | | |
| 2 | Wildfire Covered Conductor | 33,936 | 45,979 | 204,927 | \$ 284,842 |
| 3 | Remote-Control Automatic Reclosers | - | 8,789 | 18,076 | \$ 26,864 |
| 4 | Fusing Mitigation | 11,923 | 44,949 | 9,362 | \$ 66,235 |
| 5 | Total Grid Hardening | \$45,859 | \$ 99,716 | \$232,365 | \$377,941 |
| 6 | Enhanced Situational Awareness | | | | |
| 7 | HD Camera | 1,123 | 2,272 | 741 | \$ 4,136 |
| 8 | Weather Station | 1,066 | 5,922 | 6,345 | \$ 13,334 |
| 9 | Advanced Modeling Computer Hardware | 2,943 | 3,722 | 1,330 | \$ 7,995 |
| 10 | Asset Reliability and Risk Analytics | 3,380 | 505 | - | \$ 3,885 |
| 11 | Total Enhanced Situational Awareness | \$ 8,512 | \$ 12,421 | \$ 8,416 | \$ 29,349 |
| 12 | Capital Total | \$54,371 | \$112,137 | \$240,781 | \$407,290 |

a) Capital Additions and Plant-In-Service

Capital expenditures are not included in rate base until the assets are ready for service. The accounting for this is prescribed by the Federal Energy Regulatory Commission (“FERC”) Uniform System of Accounts (“USoA”). When incurred, capital expenditures record to FERC Account 107, Construction Work In Progress (“CWIP”). While in CWIP, costs typically accrue capitalized financing costs (known as Allowance for Funds Used During Construction (“AFUDC”) at rates based on a prescribed formula in the FERC USoA. Once ready for service, cumulative costs, including AFUDC, are transferred from CWIP to Plant-In-Service¹⁸⁶ as Capital Additions. At this same time, AFUDC accruals are stopped, the cumulative balance is included in rate base, and depreciation expense begins.

¹⁸⁶ Plant-In-Service includes FERC Accounts 106 (Completed Construction Not Classified) and 101 (Electric Plant-In-Service).

1 For purposes of forecasting capital for the GS&RP, SCE has assumed that
2 AFUDC accruals will be zero. However, on a recorded basis, the GS&RPBA will reflect actual
3 recorded revenue requirements, including all applicable overheads and AFUDC to the extent that
4 they are incurred.

5 b) Depreciation Expense and Accumulated Depreciation

6 Line 3 of 6 in Table V-32 above shows forecast total annual depreciation
7 expense of \$21.6 million over the 2018 – 2020 period. Annual depreciation expense in this
8 application are based on the authorized depreciation rates in SCE’s 2015 GRC.¹⁸⁷ On a recorded
9 basis, SCE will utilize its 2015 GRC authorized depreciation rates. When a Final 2018 GRC
10 Decision is available, SCE will true-up the recorded depreciation expenses in the GS&RPBA to
11 reflect its then authorized depreciation rates.

12 **2. Rate of Return**

13 SCE calculated the return on rate base using SCE’s current authorized rate of
14 return of 7.61 percent established in D.17-07-005 and subsequently approved in Advice Letter
15 3665-E. On a recorded basis, SCE will update its rate of return on rate base to be consistent with
16 the then-currently authorized rate of return.

17 **3. O&M Expenses**

18 SCE’s forecasted revenue requirements as shown in Table V-31 were derived
19 based on estimated O&M expenses of \$175 million (2018 constant \$) supported in Section IV
20 and summarized in Table V-33 below. O&M labor expenses include all applicable overheads.

¹⁸⁷ D.15-11-021.

Table V-33
Forecast 2018-2020 GS&RP O&M Expenses

| O&M (2018 Constant \$000) | | | | | |
|--------------------------------------|---|-----------------|------------------|-------------------|------------------|
| Line | Description | 2018 | 2019 | 2020 | Total |
| 1 | Grid Hardening | | | | |
| 2 | Wildfire Covered Conductor Program | 747 | 951 | 4,201 | \$ 5,899 |
| 3 | Remote-Control Automatic Reclosers | 845 | 457 | 371 | \$ 1,673 |
| 4 | Fusing Mitigation | 271 | 2,640 | 21,138 | \$ 24,049 |
| 5 | Total Grid Hardening | \$ 1,862 | \$ 4,049 | \$ 25,710 | \$ 31,621 |
| 6 | Enhanced Situational Awareness | | | | |
| 7 | HD Camera | 618 | 2,572 | 3,197 | \$ 6,387 |
| 8 | Weather Station | 142 | 631 | 1,200 | \$ 1,973 |
| 9 | Advanced Weather Modeling Tool | 384 | 604 | 604 | \$ 1,592 |
| 10 | Advanced Modeling Computer Hardware | 50 | 120 | 120 | \$ 290 |
| 11 | Asset Reliability and Risk Analytics | 7 | 9 | - | \$ 16 |
| 12 | Additional Staffing Required | 115 | 480 | 480 | \$ 1,074 |
| 13 | Total Enhanced Situational Awareness | \$ 1,317 | \$ 4,416 | \$ 5,600 | \$ 11,333 |
| 14 | Enhanced Operational Practices | | | | |
| 15 | Vegetation Management | - | 40,148 | 77,921 | \$118,069 |
| 16 | Infrared Inspection Program | - | 459 | 459 | \$ 918 |
| 17 | PSPS Protocol Support Functions | 3,165 | 3,497 | 3,497 | \$ 10,159 |
| 18 | Mobile Generator Deployment | 137 | 137 | 137 | \$ 411 |
| 19 | Portable Community Power Trailers | 1,102 | 9 | 9 | \$ 1,120 |
| 20 | Total Enhanced Operational Practices | \$ 4,404 | \$ 44,249 | \$ 82,023 | \$130,676 |
| 21 | Wildfire Mitigation Program Study | \$ 512 | \$ 521 | \$ 380 | \$ 1,413 |
| 22 | O&M Total | \$ 8,095 | \$ 53,235 | \$ 113,712 | \$175,042 |

4. Income Taxes

SCE estimates income taxes by following the rules and methods adopted in the Company's GRCs. SCE will use flow-through tax rate making as required by this Commission, unless normalization treatment is required by the Internal Revenue Service or previously allowed by this Commission. This rate proceeding includes the following tax adjustments.¹⁸⁸ Based on the nature of the GS&RP costs, SCE has assumed that the additions are not eligible for tax repair

¹⁸⁸ 2018 GRC (A.16-09-001), SCE-09, Vol. 2, at pp. 22-28.

1 deductions. To the extent SCE finds that certain additions are eligible for tax repair deductions,
2 the revenue requirement impact will be accounted for in the operation of the GS&RPBA:

- 3 a) Tax Depreciation
- 4 b) Ad Valorem Lien Date Adjustment
- 5 c) Removal Costs
- 6 d) Synchronized Interest
- 7 e) Capitalized Software
- 8 f) Deduction of State Income Taxes

9 SCE computes tax expense using the applicable federal corporate tax rate of 21
10 percent and the state corporate tax rate of 8.84 percent.

Appendix A
Acronym List

Acronym List

| | |
|----------|---|
| A. | Application |
| AB | Assembly Bill |
| ABC | Aerial Bundled Cable |
| AFUDC | Allowance for Funds Used During Construction |
| AL | Advice Letter |
| AOC | Automated Outage Communications |
| ACSR | Aluminum Conductor Steel Reinforced |
| AGM | Absorbent Glass Mat (Battery) |
| BLF | Branch Line Fuse |
| BLR | Branch Line Recloser |
| BRRBA | Base Revenue Requirement Balancing Account |
| BVLOS | Beyond Visual Line of Sight |
| Cal Fire | California Department of Forestry and Fire Protection |
| CBs | Circuit Brakers |
| CEMA | Catastrophic Event Memorandum Account |
| CEOPBA | CEOP Balancing Account |
| CFO | Contact from Object |
| CLFs | Current Limiting Fuse |
| CWIP | Construction Work in Progress |
| D. | Decision |
| DACs | Disadvantaged Communities |
| DEER | Database for Energy Efficiency Resources |
| DERs | Distributed Energy Resources |
| DFA | Distribution Fault Anticipation |
| DIMP | Distribution Inspection Maintenance Program |
| DSM | Demand Side Management |
| ED | Energy Division |
| EDC | Energized Downed Conductor |
| EOC | Emergency Operations Center |
| EONS | Emergency Outage Notification System |
| ERRA | Energy Resource Recovery Account |
| ESIMT | Electrical Services Incident Management Team |
| FAA | Federal Aviation Administration |
| FEMA | Federal Emergency Management Agency |
| FERC | Federal Energy Regulatory Commission |
| FHPMA | Fire Hazard Prevention Memorandum Account |
| FRP | Fiber Reinforced Polymer |
| GO | General Order |

| | |
|---------|---|
| GOV. | Governor |
| GRC | General Rate Case |
| GS&RP | Grid Safety and Resiliency Program |
| GS&RPBA | Grid Safety and Resiliency Program Balancing Account |
| GS&RPMA | Grid Safety and Resiliency Program Memorandum Account |
| HD | High Definition |
| HFRA | High Fire Risk Areas |
| ICS | Incident Command System |
| IOUs | Investor Owned Utilities |
| IPIP | Intrusive Pole Inspection Program |
| IR | Infrared Inspection |
| kW | Kilowatt |
| kWh | Kilowatt hour |
| mA | Milliamps |
| MW | Megawatts |
| NEETRAC | National Electric Energy Testing Research and Applications Center |
| NIFC | National Interagency Fire Center |
| OCP | Overhead Conductor Program |
| OIR | Order Instituting Rulemaking |
| ODIP | Overhead Detailed Inspection Program |
| ODRM | Outage Database and Reliability Metrics System |
| O&M | Operation and Maintenance |
| ORA | Office of Ratepayer Advocates |
| PCPTs | Portable Community Power Trailers |
| PLP | Pole Loading Program |
| PMO | Program Management Office |
| PSPS | Public Safety Power Shutoff |
| PPA | Power Purchase Agreement |
| PTZ | Pan Tilt Zoom |
| PUC | California Public Utilities Code |
| PV | Photovoltaic |
| R. | Rulemaking |
| RAMP | Risk Assessment and Mitigation Phase |
| RARs | Remote Controlled Automatic Reclosers |
| RCS | Remote Controlled Switches |
| SB | Senate Bill |
| SCADA | Smart meter, supervisory control and acquisition data |
| SCD | Short Circuit Duty |
| SCE | Southern California Edison |
| XL-HDPE | Crosslinked low density polyethylene |

| | |
|-------|--|
| TURN | The Utility Reform Network |
| UAV | The Advanced Unmanned Aerial Systems |
| USoA | Uniform System of Accounts |
| WCCP | Wildfire Covered Conductor Program |
| WCPMA | Wildfires Customer Protection Memorandum |
| WEMA | Wildfire Expense Memorandum Account |
| WRF | Weather Research and Forecasting |
| WWG | Western Weather Group |

Appendix B

Witness Qualifications

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF BILL CHIU**

4 Q. Please state your name and business address for the record.

5 A. My name is Bill Chiu, and my business address is One Innovation Way, Pomona,
6 California, 91768.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am the Director of Grid Resiliency & Public Safety Program Management Office
9 (PMO) within Southern California Edison Company’s Transmission and Distribution
10 operating unit. In this capacity, I oversee the enterprise-wide operational mitigation to
11 address the wildfire and public safety risk.

12 Q. Briefly describe your educational and professional background.

13 A. I have a Master’s degree in business administration and a Master of Science in Electrical
14 Engineering from University of Southern California, and a Bachelor of Science degree in
15 Electrical Engineering from Cal Poly Pomona. I am a licensed Professional Engineer in
16 the State of California and Texas. I joined Southern California Edison in 1998 and have
17 held various engineering and management positions, including the Director of
18 Engineering, prior to my current role as the Director of PMO. Prior to joining SCE in
19 1998, I held various roles in planning, engineering, project management, and technical
20 supervisory capacities for Bechtel Power Corporation, Los Angeles Department of Water
21 & Power, and Austin Energy. I am a senior member of IEEE Power & Energy Society
22 (IEEE PES) and have served as executive officers for the IEEE PES Transformers
23 Committee from 2004 to 2015.

24 Q. What is the purpose of your testimony in this proceeding?

1 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
2 entitled *Prepared Testimony in Support of Southern California Edison Company's*
3 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
4 Table of Contents thereto.

5 Q. Was this material prepared by you or under your supervision?

6 A. Yes, it was.

7 Q. Insofar as this material is factual in nature, do you believe it to be correct?

8 A. Yes, I do.

9 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
10 judgment?

11 A. Yes, it does.

12 Q. Does this conclude your qualifications and prepared testimony?

13 A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF DON DAIGLER**

4 Q. Please state your name and business address for the record.

5 A. My name is Don Daigler, and my business address is 8631 Rush Street, Rosemead, CA
6 91770.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am the Director of Business Resiliency under the Operational Services Organizational
9 Unit (OU). I am responsible for Southern California Edison's overall Business
10 Resiliency activities. I also manage the company's emergency management functions for
11 all hazards facing the company's business lines, facilities, and people and lead the
12 development and implementation of corporate Business Continuity Plans and Disaster
13 Recovery Plans.

14 Q. Briefly describe your educational and professional background.

15 A. I have a Bachelor of Science in Liberal Studies with an educational focus on Health
16 Physics and have more than 30 years of experience in the areas of national security and
17 emergency management. My career includes 26 years of service in the federal
18 government, where I have held several senior leadership positions, both in the field and at
19 the policy level in Washington, D.C. Immediately prior to joining SCE, I was the
20 Response Planning Director for the Federal Emergency Management Agency (FEMA),
21 where I led all national and regional response planning activities and was the planning
22 lead during several large scale disasters, such as hurricanes Sandy, Isaac, and Irene. In
23 that capacity, I was also responsible for leading the agency's chemical, biological,
24 radiological, nuclear, and explosives programs as well as the National Hurricane Program
25 and Remote Sensing Program. Previously, I ran the Technology Integration Program for
26 the Department of Energy's National Nuclear Security Administration, which developed

1 specialized emergency response equipment. Before moving to Washington, D.C., I held
2 leadership roles for the Department of Energy's Nevada Site Office, including the
3 position of Director of the Homeland Security and Defense Division. My federal
4 government experience also includes experience with the Environmental Protection
5 Agency and the Department of Defense.

6 Q. What is the purpose of your testimony in this proceeding?

7 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
8 entitled *Prepared Testimony in Support of Southern California Edison Company's*
9 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
10 Table of Contents thereto.

11 Q. Was this material prepared by you or under your supervision?

12 A. Yes, it was.

13 Q. Insofar as this material is factual in nature, do you believe it to be correct?

14 A. Yes, I do.

15 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
16 judgment?

17 A. Yes, it does.

18 Q. Does this conclude your qualifications and prepared testimony?

19 A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF PHILIP R. HERRINGTON**

4 Q. Please state your name and business address for the record.

5 A. My name is Philip R. Herrington, and my business address is 8631 Rush Street,
6 Rosemead, California 91770.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am Senior Vice President of Transmission and Distribution responsible for the
9 operation, maintenance and modernization of SCE's electrical grid that covers a 50,000
10 square-mile service area.

11 Q. Briefly describe your educational and professional background.

12 A. I have a Bachelor of Science degree in chemical engineering from the University of
13 California, Santa Barbara, and a Master's degree in business administration from the
14 University of Southern California's Marshall School of Business.

15 Q. What is the purpose of your testimony in this proceeding?

16 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
17 entitled *Prepared Testimony in Support of Southern California Edison Company's*
18 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
19 Table of Contents thereto.

20 Q. Was this material prepared by you or under your supervision?

21 A. Yes, it was.

22 Q. Insofar as this material is factual in nature, do you believe it to be correct?

23 A. Yes, I do.

24 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
25 judgment?

26 A. Yes, it does.

27 Q. Does this conclude your qualifications and prepared testimony?

1

A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF MELANIE JOCELYN**

4 Q. Please state your name and business address for the record.

5 A. My name is Melanie Jocelyn, and my business address is 1 Innovation Way, Pomona, CA
6 91768.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am a Vegetation Management Principal Manager in SCE's Distribution & Maintenance
9 group. I oversee the prevention of vegetation from coming into contact with SCE's
10 electrical facilities by scheduling the trimming and removal of trees in proximity to
11 transmission and distribution rights-of-way.

12 Q. Briefly describe your educational and professional background.

13 A. I have a Bachelor of Science in Environmental Policy Analysis and Planning from the
14 University of California Davis. I have been employed by Southern California Edison
15 since 2009.

16 Q. What is the purpose of your testimony in this proceeding?

17 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
18 entitled *Prepared Testimony in Support of Southern California Edison Company's*
19 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
20 Table of Contents thereto.

21 Q. Was this material prepared by you or under your supervision?

22 A. Yes, it was.

23 Q. Insofar as this material is factual in nature, do you believe it to be correct?

24 A. Yes, I do.

25 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
26 judgment?

27 A. Yes, it does.

1 Q. Does this conclude your qualifications and prepared testimony?

2 A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF LINDA R. LETIZIA**

4 Q. Please state your name and business address for the record.

5 A. My name is Linda R. Letizia, and my business address is 8631 Rush Street, Rosemead,
6 California 91770.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company
8 ("SCE").

9 A. I am the Principal Manager of the CPUC Revenue Requirements and Tariffs group in the
10 State Regulatory Operations Department, and have overall responsibility for the
11 management, development, and presentation of revenue requirements and ratemaking
12 showings before the California Public Utilities Commission.

13 Q. Briefly describe your educational and professional background.

14 A. I graduated from the University of California at Davis in 1980 with a Bachelor of Science
15 degree in Mathematics. I have been employed by Southern California Edison Company
16 since 1984. Since joining Edison, I have held various positions in the Regulatory Policy
17 and Affairs and Regulatory Operations departments. My responsibilities have included
18 revenue allocation and rate design, the preparation of pricing studies and analyses, and
19 the development of revenue requirements and ratemaking proposals for numerous
20 regulatory proceedings before the California Public Utilities Commission. I have also
21 been employed in the Capital Recovery Section and Corporate Budgets Section of the
22 Controller's Department. I have previously testified before the California Public Utilities
23 Commission.

24 Q. What is the purpose of your testimony in this proceeding?

1 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
2 entitled *Prepared Testimony in Support of Southern California Edison Company's*
3 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
4 Table of Contents thereto.

5 Q. Was this material prepared by you or under your supervision?

6 A. Yes, it was.

7 Q. Insofar as this material is factual in nature, do you believe it to be correct?

8 A. Yes, I do.

9 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
10 judgment?

11 A. Yes, it does.

12 Q. Does this conclude your qualifications and prepared testimony?

13 A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF DOUGLAS A. TESSLER**

4 Q. Please state your name and business address for the record.

5 A. My name is Douglas A. Tessler, and my business address is 8631 Rush Street, Rosemead,
6 California 91770.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am the Senior Manager of CPUC Revenue Requirements in the Financial Planning &
9 Analysis section of the Treasurer's Department. I am primary responsible for
10 development of the Standardized Operations and Maintenance (O&M) and Capital
11 Expenditure workpapers for all GRC and non-GRC CPUC Revenue Requirements. I am
12 also responsible for maintaining the Results of Operations (RO) model used to calculate
13 the CPUC revenue requirement.

14 Q. Briefly describe your educational and professional background.

15 A. I received a Bachelor of Science Degree in Accounting from California State Polytechnic
16 University, Pomona in 1999 and Master of Science Degree in Business Administration
17 from California State University, Fullerton in 2006. I am also a Certified Public
18 Accountant (inactive). I began my career at Southern California Edison in 1997 as an
19 Accounting Assistant in the Property Accounting area of the Controller's Department.
20 From 1999 to 2005, I worked in various accounting positions within the Controller's
21 Department. In 2005, I moved to the Audit Services Department where I worked as a
22 Corporate Auditor. In 2008, I transferred to the Investor Relations Department at Edison
23 International (the parent and holding company of Southern California Edison) where I
24 worked as a Senior Financial Analyst. In 2010, I began working in the Revenue
25 Requirements & Forecasting group in State Regulatory Operations as a project manager

1 where I assumed my current position in 2015. In early 2018, the CPUC Revenue
2 Requirements function was transferred from State Regulatory Operations to Treasurers.

3 Q. What is the purpose of your testimony in this proceeding?

4 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
5 entitled *Prepared Testimony in Support of Southern California Edison Company's*
6 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
7 Table of Contents thereto.

8 Q. Was this material prepared by you or under your supervision?

9 A. Yes, it was.

10 Q. Insofar as this material is factual in nature, do you believe it to be correct?

11 A. Yes, I do.

12 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
13 judgment?

14 A. Yes, it does.

15 Q. Does this conclude your qualifications and prepared testimony?

16 A. Yes, it does.

1 **SOUTHERN CALIFORNIA EDISON COMPANY**
2 **QUALIFICATIONS AND PREPARED TESTIMONY**
3 **OF THUAN Q. TRAN**

4 Q. Please state your name and business address for the record.

5 A. My name is Thuan Q. Tran, and my business address is 1 Innovation Way, Pomona, CA
6 91768.

7 Q. Briefly describe your present responsibilities at the Southern California Edison Company.

8 A. I am a Principal Manager of T&D Apparatus and Standards Engineering. I help to
9 develop engineering talents, lead many new developments in substation, automation and
10 apparatus engineering projects, and manage the T&D Apparatus & Standards Engineer
11 group of nine managers and approximately 80 engineers, project managers, technical
12 advisers. The group is responsible for performing technical studies, testing, qualifying,
13 specifying new electrical equipment, such as transformer, cable, wire, capacitors, etc. for
14 Transmission, substation and distribution. The group prepares and facilitate approvals of
15 design, construction standards and operations and maintenance manuals. In addition, the
16 group also has the responsibility of performing root cause analysis of equipment failures
17 and making mitigation recommendation.

18 Q. Briefly describe your educational and professional background.

19 A. I joined Southern California Edison in 1989 after graduating from the University of
20 California at Irvine with a Bachelor of Science degree in Electrical Engineering. I also
21 received a Master of Engineering in Electrical Engineering with an emphasis in Power
22 Systems at University of Idaho, Moscow in 2004 and Master of Business Administration
23 (MBA), University of La Verne, La Verne in 1992. I am also a certified Professional
24 Engineer (PE) in Electrical Engineering in California. Since joining the company in 1989
25 and through 2003, I worked as a distribution engineer, automation engineer and
26 substation apparatus engineer. I led a number of projects from distribution automation
27 development to commissioning transmission voltage-level static VAR systems. I moved

1 to a leadership capacity as a supervising engineer in Distribution Apparatus Engineering,
2 Senior Manager of Substation Engineering, Senior Manager of Protection and
3 Automation.

4 Q. What is the purpose of your testimony in this proceeding?

5 A. The purpose of my testimony in this proceeding is to sponsor portions of Exhibit SCE-01,
6 entitled *Prepared Testimony in Support of Southern California Edison Company's*
7 *Application for Approval of Its Grid Safety and Resiliency Program* as identified in the
8 Table of Contents thereto.

9 Q. Was this material prepared by you or under your supervision?

10 A. Yes, it was.

11 Q. Insofar as this material is factual in nature, do you believe it to be correct?

12 A. Yes, I do.

13 Q. Insofar as this material is in the nature of opinion or judgment, does it represent your best
14 judgment?

15 A. Yes, it does.

16 Q. Does this conclude your qualifications and prepared testimony?

17 A. Yes, it does.